



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: May 20, 2024

Inspection Result: PARTIAL PASS

Permit Number: PRSF221403

Issuance Date: Apr 10, 2023

Property Address: 26730 COUNTY ROAD 14, ROUTT, CO 80467;

Applicant: SUSTAINABLE BUILDING SOLUTIONS

Contractor: SUSTAINABLE BUILDING SOLUTIONS P.O. BOX 770578 STEAMBOAT
SPGS,, CO 80477 (970) 819-4311

To construct: New Single Family Home With Attached Garage at 26730 County Road 14.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Roof and wall sheeting complete

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371