



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 05, 2024

Inspection Result: PARTIAL PASS

Permit Number: PRSF240568

Issuance Date: Aug 15, 2024

Property Address: 32755 COUNTY ROAD 5, ROUTT, CO 80479;

Applicant: Yutzy Builders LLC

Contractor: Yutzy Builders LLC PO Box 246 Toponas, CO 80479

To construct: 2 Bed, 1 bath, 1600 SF Single Family Home

On this day we have inspected your construction for **Footing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Monolithic slab, two # in footer, tied into 24" oc mat for slab, per plan detail. ok to pour

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371