



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 05, 2024

Inspection Result: PARTIAL PASS

Permit Number: PRPL240926

Issuance Date: Aug 20, 2024

Property Address:

Applicant: Elam SwareyElam Swarey

Contractor:

To construct: Plumbing for new build

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: In slab drains, complete and holding 5 psi

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371