



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 09, 2024

Inspection Result: PARTIAL PASS

Permit Number: PRAB230603

Issuance Date: Aug 08, 2024

Property Address: 39610 AMETHYST DR, ROUTT, CO 80487;

Applicant:

Contractor: Makeover Colorado 6637 west Kenyon Ave 80235, CO 80235 (720) 675-9947

To construct: A 200 seat outdoor performance space on the campus of the Strawberry Elementary School campus. Acoustic reflector surfaces, Upstage wall, seating

On this day we have inspected your construction for **Footing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Footer pads are formed to approved plans. Rebar detail was missing on plans, (3)#4 bars each way were installed. Approved to pour.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347