



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Sep 13, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRSF240568

**Issuance Date:** Aug 15, 2024

**Property Address:** 32755 COUNTY ROAD 5, ROUTT, CO 80479;

**Applicant:** Yutzy Builders LLC

**Contractor:** Yutzy Builders LLC PO Box 246 Toponas, CO 80479

**To construct:** 2 Bed, 1 bath, 1600 SF Single Family Home

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** 2' OF CORE BOND ON FOOTERS AND UNDER SLAB

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us  
(970) 870-5371