



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Oct 07, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRMH240395

**Issuance Date:** Aug 19, 2024

**Property Address:** 26105 COUNTY ROAD 37B, ROUTT, CO 81639;

**Applicant:** Peace Plumbing

**Contractor:** Peace Plumbing 420 E 57th Loveland, CO 80538

**To construct:** Mechanical for New Single Family Dwelling  
STOP WORK ORDER generated on 08/19/2024 by username 'Nick Neiberger'.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Hydronic heat tubing has been installed and fastened correctly. Pressure test good at 10 0psi for 15 minutes. Gas lines are installed correctly, pressure test still to be done. Partial approved.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347