



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Oct 08, 2024

Inspection Result: PASSED

Permit Number: PRAB230603

Issuance Date: Aug 08, 2024

Property Address: 39620 AMETHYST DR, ROUTT, CO 80487;

Applicant:

Contractor: Makeover Colorado 6637 west Kenyon Ave 80235, CO 80235 (720) 675-9947

To construct: A 200 seat outdoor performance space on the campus of the Strawberry Elementary School campus. Acoustic reflector surfaces, Upstage wall, seating

On this day we have inspected your construction for **Footing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Pier extensions and sonotube piers are formed to approved plans with all rebar sized and spaced correctly. Approved to pour.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347