



AquaWorks DBO, Inc.
3252 Williams Street
Denver, Colorado 80205

(303) 477-5915
www.aquaworksdbo.com
info@aquaworksdbo.com

Todd Carr
Routt County Building Official
Routt County Regional Building Department
136 6th St. Suite 201
Steamboat Springs, CO

October 3, 2024

RE: Town of Phippsburg Wastewater Treatment Plant
Building Permit Application Summary Letter
PRPF231764 - 22158 COUNTY ROAD 12, ROUTT, CO 80469

Dear Todd and Plan Reviewers,

Please accept this resubmittal package as part of application for construction of a prefabricated, containerized wastewater treatment facility for the community of Phippsburg.

RCRBD provided a Corrections Notice dated 5/3/2024 to the previously submitted permit package. Those corrections along with a response indicating the proposed resolution to the requested information is provided herein in hopes of aiding rereview of the permit package and potential issuance of a building permit.

1. *While the structural calculations submitted indicates anchor types and diameter for lid embeds at container legs, RCRBD inspectors will need the plans to specify fastening design data such as field weld size(s) and length, or post installed bolt alternate as applicable.*

Please find weld detail and calculations for container fastening to tank deck embeds as part of this resubmittal package. As an appendix to this letter find a clarification on the embed plate size.

2. *State Approved Plans for Manufactured-Factory Built Buildings - submitted*
3. *Heat Load Calculations - submitted*
4. *Installation Authorization Form - submitted*

Please do not hesitate to reach out if you have any questions related to this permit application. I can be reached at ben@aquaworksdbo.com or 970-846-1513.

Sincerely,

AQUAWORKS DBO, INC.

Ben Beall, P.E.

**REVIEWED
FOR CODE
COMPLIANCE**

10/10/2024