



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Oct 17, 2024

Inspection Result: PASSED

Permit Number: PRGS241431

Issuance Date: Oct 15, 2024

Property Address:

Applicant: SCHRADER PROPANE LLC

Contractor: SCHRADER PROPANE LLC P.O. BOX 775450 STEAMBOAT SPGS, CO
80477 (970) 819-7363

To construct: UNDERGROUND TANK SET & EXTERIOR, UNDERGROUND GAS LINE
INSTALLATION

On this day we have inspected your construction for **Gas Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Two tank set, gas line complete, in trench with locate wire, holding 11 psi

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371