



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Oct 21, 2024

Inspection Result: PASSED

Permit Number: PRPL241460

Issuance Date: Oct 20, 2024

Property Address: 47025 COUNTY ROAD 129, ROUTT, CO 80487;

Applicant: Backcountry Plumbing & Heating

Contractor: Backcountry Plumbing & Heating 27894 Silver Spur Street Steamboat Springs , CO 80487 (970) 846-9790

To construct: plumbing system for new residence

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: DWV and water lines are installed, protected and supported correctly. Pressure tests good for 15 minutes. Rough plumbing approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347