



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Oct 22, 2024

Inspection Result: PARTIAL PASS

Permit Number: PREL240742

Issuance Date: Jul 09, 2024

Property Address: 22158 COUNTY ROAD 12, ROUTT, CO 80469;

Applicant: Grasmick Electric Corp

Contractor: Duckels Construction Inc. 3500 DUCKELS CT. Steamboat Springs, 80487

To construct: Temp Power - New 400A 240V 1P electrical service New Generator Power Control conduit wire.

On this day we have inspected your construction for **Electrical Underground/Underslab** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Service lateral from Pole to tank approved

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339