



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Oct 31, 2024

Inspection Result: PASSED

Permit Number: PRMH241519

Issuance Date: Oct 30, 2024

Property Address: 31555 GREEN RIDGE DR, ROUTT, CO 80467;

Applicant: ELLSWORTH PLUMBING & SERVICE

Contractor: ELLSWORTH PLUMBING & SERVICE P.O. BOX 772238 Steamboat Springs, CO 80477 (970) 457-0813

To construct: Adding LP lines for fire places that were converted from wood burning.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Gas line for future fire pit, holding 15 psi

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371