



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Nov 05, 2024

Inspection Result: PASSED

Permit Number: PREL240503

Issuance Date: May 22, 2024

Property Address: 29775 DRY CREEK TRL, ROUTT, CO 80467;

Applicant: RIDGELINE ELECTRIC LLC

Contractor: MORTON BUILDINGS, INC 252 W. ADAMS ST. MORTON, IL 61550 (970) 281-2439

To construct: Electric for New residential horse barn

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Correction made inspection performed via video final electrical approved

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339