



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Nov 05, 2024

Inspection Result: PASSED

Permit Number: PRPF241028

Issuance Date: Sep 17, 2024

Property Address: 27210 GOLDEN VIEW TRL, ROUTT, CO 80428;

Applicant: KEN FINCH PLUMBING

Contractor:

To construct: New Manufactured/Modular Single Family Dwelling with attached garage.
2250 SF Finished, 750 SF Attached Garage
3 Bedroom, 3 Bathrooms
FOUNDATION ONLY 08.29.2027

On this day we have inspected your construction for **Footing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Deep pier holes have sonotubes and rebar sized and spaced per approved plans. Ok to pour.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347