



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Nov 06, 2024

Inspection Result: PASSED

Permit Number: PRWD240916

Issuance Date: Aug 07, 2024

Property Address: 57880 GOLDEN TIDE PL, ROUTT, CO 80428;

Applicant: RENEWAL BY ANDERSEN

Contractor: RENEWAL BY ANDERSEN 1401 W BAYAUD AVE DENVER, CO 80223
(303) 945-1519

To construct: Replacing 31 windows and 2 doors like for like. u factor will be .30 or better

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Windows and doors are installed, flashed and foamed correctly. All U factors and glazing are correct. Approved to finish windows.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347