



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Dec 03, 2024

Inspection Result: PARTIAL PASS

Permit Number: PRAB241364

Issuance Date: Oct 29, 2024

Property Address: 26200 FSR 409, ROUTT, CO 80428;

Applicant: Greg lafeliece

Contractor: Shamrock Buildings 3801 Weicker Dr. Fort Collins , Co 80524 (970) 305-7086

To construct: Building a 30'x40' pole barn. Non heated and no electrical at this time.

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: See corrections, all other framing and trusses are installed correctly. Partial approved.

Corrections:

- 1 1. Add blocking between OSB panel edges and at columns between purlins and add more nails to meet 4" edge nailing schedule.
2. Add 2x4 wind bracing to roof purlins

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347