



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Dec 04, 2024

Inspection Result: PARTIAL PASS

Permit Number: PREL241545

Issuance Date: Nov 06, 2024

Property Address: 50310 MOON HILL DR, ROUTT, CO 80487;

Applicant: Dome Mountain Electric Inc

Contractor: Dome Mountain Electric Inc <NO STREET ADDRESS> (970) 819-2496

To construct: New power and lighting and electrical to detached garage
Mater permit number PRAB210091

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 406-9a receptacles installed outdoor locations protected from weather or in other damp location she'll have an enclosure for receptacle that is weatherproof or receptacle is covered hinge cover acceptable.
334.15b type NM c cable requires protection from physical damage OSB strip acceptable

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339