



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Dec 06, 2024

Inspection Result: PASSED

Permit Number: PREL240676

Issuance Date: Jun 24, 2024

Property Address: 23620 FRAYSHER LN, ROUTT, CO 80467;

Applicant: BANNING ELECTRIC

Contractor: Dovetail Designs LLC 23595 Youngs Creek Way, Unit B Oak Creek, CO 80467

To construct: Residential

On this day we have inspected your construction for **Electrical Perm Service** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Permanent electrical service conditionally approved for construction use only all energized circuits to remain on exterior of dwelling or adjacent interior stud Bay. No need to call in Clarence as meter is already set in permanent service pedestal at bottom of Hill

Corrections:

Sincerely,

Tom Cook
Electrical Plan Reviewer/Inspector
tcook@co.routt.co.us
(970) 870-5339