



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Dec 17, 2024

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRSF221403

**Issuance Date:** Apr 10, 2023

**Property Address:** 26730 COUNTY ROAD 14, ROUTT, CO 80467;

**Applicant:** SUSTAINABLE BUILDING SOLUTIONS

**Contractor:** SUSTAINABLE BUILDING SOLUTIONS P.O. BOX 770578 STEAMBOAT  
SPGS., CO 80477 (970) 819-4311

**To construct:** New Single Family Home With Attached Garage at 26730 County Road 14.

On this day we have inspected your construction for **Shower Pan Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Backer installed and cement sealed, no visible leaks

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us  
(970) 870-5371