



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Dec 19, 2024

**Inspection Result:** PASSED

**Permit Number:** PRPL230942

**Issuance Date:** Aug 03, 2023

**Property Address:** 27315 HOME RANCH RD, UNIT A, ROUTT, CO 80428;

**Applicant:** ACTION MECHANICAL INC.

**Contractor:** ACTION MECHANICAL INC. P.O. BOX 698 CLARK, CO 80428 (970) 819-1174

**To construct:** complete plbg system

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** DWV and water lines for fitness addition have been installed, supported and protected correctly. Pressure tests good for 15 minutes. Rough plumbing approved.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347