



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Dec 19, 2024

Inspection Result: PASSED

Permit Number: PRMH230943

Issuance Date: Aug 03, 2023

Property Address: 27315 HOME RANCH RD, UNIT A, ROUTT, CO 80428;

Applicant: ACTION MECHANICAL INC.

Contractor: ACTION MECHANICAL INC. P.O. BOX 698 CLARK, CO 80428 (970) 819-1174

To construct: in-floor htg

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Hydronic heat tubing in warm board and supply and return and gas lines are installed, supported and protected correctly. Pressure tests good for 15 minutes. Rough approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347