



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Feb 04, 2025

**Inspection Result:** PASSED

**Permit Number:** PREL240741

**Issuance Date:** Jul 09, 2024

**Property Address:** 38700 MAIN ST, ROUTT, CO 80487;

**Applicant:** Grasmick Electric Corp

**Contractor:** Duckels Construction Inc. 3500 DUCKELS CT. Steamboat Springs, 80487

**To construct:** Temp Power , New 400A 240 V 1P electrical service New Generator Power control conduit wire

On this day we have inspected your construction for **Electrical Underground/Underslab** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Underground approved. Service lateral exits Building Extremely shallow depth will require Concrete protection prior to final

**Corrections:**

Sincerely,

Tom Cook  
Electrical Plan Reviewer/Inspector  
tcook@co.routt.co.us  
(970) 870-5339