



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Feb 05, 2025

**Inspection Result:** PASSED

**Permit Number:** PRWD241586

**Issuance Date:** Dec 05, 2024

**Property Address:** 24045 COUNTY ROAD 25, ROUTT, CO 80467;

**Applicant:** RENEWAL BY ANDERSEN

**Contractor:** RENEWAL BY ANDERSEN 1401 W BAYAUD AVE DENVER, CO 80223  
(303) 945-1519

**To construct:** Replacing 3 doors like for like. u factor will be .30 or better

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Doors trimmed, sealed and complete

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us  
(970) 870-5371