



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School

INSPECTION REPORT

Report Issued: Mar 12, 2025

Inspection Result: PARTIAL PASS

Permit Number: PRPF231763

Issuance Date: Apr 23, 2024

Property Address: 38700 MAIN ST, ROUTT, CO 80487;

Applicant: Ben Beall

Contractor: Diane Dwire 3500 DUCKELS CT. STEAMBOAT SPGS, CO 80487 (970) 879-6072 Duckels Construction Inc. 3500 DUCKELS CT. Steamboat Springs, 80487 Nicholle Douglas 3500 Duckels Court Steamboat Springs, CO 80487 (970) 879-6072 Ext: 306

To construct: Construction of Town of Milner wastewater treatment plant including site-built, below-ground tanks that also serve as the foundation for placement of factory-built, modular, containerized treatment facility on top of tanks.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Welds do not need to be special inspected as previously requested, as we did receive the Weld Structural calcs and this document will suffice in lieu of special inspections as the loads on these welds are very minimal.

Corrections:

Sincerely,

A handwritten signature in black ink that reads "Todd Carr".

Todd Carr
Building Official
tcarr@co.routt.co.us
(970) 870-5330