



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School

INSPECTION REPORT

Report Issued: Mar 28, 2025

Inspection Result: PASSED

Permit Number: PRMH250155

Issuance Date: Mar 13, 2025

Property Address: 54173 COUNTY ROAD 129, ROUTT, CO 80428;

Applicant: FIN'S TIN

Contractor: FIN'S TIN PO BOX 697 CLARK, CO 80428 (970) 846-7640

To construct: Install one Bath fan & one Dryer vent.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Dryer and ventilation fan ducts are installed correctly. Nail plate on dryer vent needs to be installed, will see at insulation inspection.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347