

Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School

INSPECTION REPORT

Report Issued:	Apr 02, 2025	Inspection Result:	PASSED	
Permit Number:	PRPL240679			
Issuance Date:	Jun 24, 2024			
Property Address:	23620 FRAYSHER LN, ROUTT, CO 80467;			
Applicant:	ELLSWORTH PLUM	BING & SERVICE		
Contractor:	ELLSWORTH PLUM	BING & SERVICE P.O. BO	X 772238	Steamboat
	Springs, CO 80477	(970) 457-0813		
To construct:	All plumbing for new	build		

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Al supported and protected, all DWV stacks over 5 psi, water at 70 psi, no issues

Corrections:

Sincerely,

Jeff Yeiser Inspector jyeiser@co.routt.co.us (970) 870-5371