



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School

INSPECTION REPORT

Report Issued: Apr 10, 2025

Inspection Result: PASSED

Permit Number: PRAD250104

Issuance Date: Mar 31, 2025

Property Address: 30385 BLACKTAIL LN, ROUTT, CO 80467;

Applicant: Amplify Architecture

Contractor:

To construct: New garage with large mudroom + laundry on main level. Second level to have new primary suite.

On this day we have inspected your construction for **Footing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Footings all two #5, pads 6" oc, voids placed per plan, ok to pour

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371