



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School

INSPECTION REPORT

Report Issued: Apr 14, 2025

Inspection Result: PARTIAL PASS

Permit Number: PRRN250275

Issuance Date: Apr 10, 2025

Property Address: 6710 MOORES RD, ROUTT, CO 81639;

Applicant: SATHER, JERRY L. & DIANE G. (JT)

Contractor:

To construct: Replace all windows on second floor- like for like, .32 U Factor or better.
Overlay existing wood siding with metal on Second floor.

On this day we have inspected your construction for **Framing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Walk and talk. Approved to move forward as discussed.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347