



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School

# INSPECTION REPORT

**Report Issued:** Apr 15, 2025

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRSF240344

**Issuance Date:** May 09, 2024

**Property Address:** 23620 FRAYSHER LN, ROUTT, CO 80467;

**Applicant:** Dovetail Designs LLC

**Contractor:** Dovetail Designs LLC 23595 Youngs Creek Way, Unit B Oak Creek, CO 80467

**To construct:** New Single Family Dwelling  
3 Bedroom, 3.5 Bathroom  
3800 Ft² Finished, 833 Ft² Unfinished

On this day we have inspected your construction for **Roofing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Roof sheeting , SIPS , nailed at seams per instructions, Lag cap screws installed. ok for fire paper and underlayment

**Corrections:**

Sincerely,

Jeff Yeiser  
Inspector  
jyeiser@co.routt.co.us  
(970) 870-5371