



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School

INSPECTION REPORT

Report Issued: Apr 15, 2025

Inspection Result: PASSED

Permit Number: PRGS250298

Issuance Date: Apr 14, 2025

Property Address: 61325 COUNTY ROAD 62, ROUTT, CO 80428;

Applicant: IQ PLUMBING & HEATING

Contractor: IQ PLUMBING & HEATING 895 RANNEY ST CRAIG, CO 81625 (970) 629-5125

To construct: Gas piping to Tankless water heater.

On this day we have inspected your construction for **Gas Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Gas line has been installed correctly. Pressure test good at 15 psi for 15 minutes.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347