



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School

INSPECTION REPORT

Report Issued: May 05, 2025

Inspection Result: PARTIAL PASS

Permit Number: PRSF241611

Issuance Date: Jan 16, 2025

Property Address: 33170 MEADOW CREEK DR, ROUTT, CO 80487;

Applicant: Alpine Master Builders, LLC

Contractor: Alpine Master Builders, LLC 100 E RiverCenter Boulevard Ste 1100
Covington, Ky 41001-1 (970) 819-6729

To construct: New single family home on lot 41 of Alpine Mountain Ranch and Club. The home is 5 bedrooms, 5 full baths and two 1/2 baths. Finished Interior 6,663 /Sq Ft, Garage 1,363 Sq Ft, Mechanical/storage 630, Exterior Decks and Patios, 2339 Sq feet

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Low walls #5 12" mats, tall walls #5 9" mats, laps and bent ins per plan. Piers 8 #4, tied 12" oc, two at the top. No issues, ok to pour

Corrections:

Sincerely,

Jeff Yeiser
Inspector
jyeiser@co.routt.co.us
(970) 870-5371