

R C R B D
RECORD SET

[illegible]

RCRBD
RECORD SET





R C R B D RECORD SET

1.R321.1 Premises identification. Approved numbers or addresses shall be provided for all new buildings in such a position as to be plainly visible and legible from the street or road fronting the property.

2.The builder shall leave the National Fenestration Rating Council (NFRC) labels on all windows and doors with glazing at time of rough inspections so inspectors can verify the glazing requirements.

3.R308 Glazing. Except as indicated in Section R308.1.1, each pane of glazing installed in hazardous locations as defined in SectionR308.4 shall be provided with a manufacturer's or installer's label, designating the type and thickness of glass and the safety glazing standard with which it complies, which is visible in the final installation. The label shall be acid etched, sandblasted, ceramic-fired, embossed mark, or shall be of a type which once applied cannot be removed without being destroyed. Exceptions: Tempered spandrel glass may be identified by the manufacturer with a removable paper label.

4.Smoke Alarms. Provide smoke alarms per R313.1. Where work requiring a permit occurs in existing dwellings that have attached garages or in existing dwellings within which fuel-fired appliances exist, carbon monoxide alarms shall be provided in accordance with Section R315.1.

✓ Items noted above are required and will be checked by field inspectors.



RCRBD
RECORD SET





R C R B D
RECORD SET