


## SECTION 000107 - SEALS PAGE


ARCHITECT:  
GREG MACIK  
TAB ASSOCIATES, INC  
56 EDWARDS VILLAGE BLVD  
SUITE 210  
EDWARDS, CO 81632  
DIVISIONS: 00,01, 02, 04, 05, 06, 07, 08, 09,  
10, 11, 12




CIVIL ENGINEER:  
MATT WADEY  
ALPINE ENGINEER  
34510 US HIGHWAY 6  
UNIT A-9  
EDWARDS, CO 81632  
DIVISIONS: 02, 31, 32, 33





LANDSCAPE ARCHITECT:  
MARK WILCOX  
900 SOUTH BROADWAY  
SUITE 300 DENVER, CO  
80229  
DIVISIONS: 11, 12, 31, 32



STRUCTURAL ENGINEER:  
MATTHEW HOOD  
JIRSA HEDRICK STRUCTURAL ENGINEERS  
P.O. BOX 4989  
EAGLE, CO 81631  
DIVISIONS: 03, 04, 05



<p>MECHANICAL AND PLUMBING ENGINEER: DAVID LYLE BG WORKS P.O. BOX 9650 22 CHAPEL PLACE AVON, CO 81620 DIVISIONS: 21, 22, 23</p>	
<p>ELECTRICAL ENGINEER: MARC SACCONI BG WORKS P.O. BOX 9650 22 CHAPEL PLACE AVON, CO 81620 DIVISIONS: 26</p>	

END OF SECTION

**RCRBD Record Set  
T.A.****05/14/2020**

# TAB Associates, Inc.

## *The Architectural Balance*

0056 Edwards Village Boulevard  
Suite 210, Edwards, Colorado 81632  
(970) 766-1470 (970) 766-1471 fax  
www.tabassociates.com tab@vail.net



## Memo

Project: Strawberry Park Elementary

Project No: **TAB: 1935.02 RCRBD: TB-20-258**

Date: May 6, 2020

**RE: Routt County Regional Building Department Permit Comments**

**FROM:**

**Warner Hopkins**, Project Manager

**TO:**

**Ted Allen**, Plans Examiner/ Inspector,  
Routt County Regional Building Department

**Remarks:**

**Permit Comment Letter from RCRBD:**

VIA: Bluebeam Studio Session and Email  
**RCRBD Record Set**  
**T.A.**

**05/14/2020**

- 1. Should existing construction documents be available for any of the subject buildings, please share with RCRBD for reference, electronic or scanned files preferred but paper is acceptable.**  
Response: Existing SP Elementary drawings have been uploaded to the TB-20-258 MS Bluebeam Studio Session with RCRBD.
- 2. When submitting plans for construction, only documents that are complete and ready for construction shall be submitted to RCRBD for building permit. RCRBD interprets this to include all documents such as the shade structure.**  
Response: This will be included in the Deferred Submittals.
- 3. All plans submitted to RCRBD for review shall be signed and sealed in accordance with Colorado State Law. RCRBD interprets this to include all documents such as the food service plans and specifications where the Table of Contents is typically signed and sealed by each registered design professional of record if applicable as no specifications were submitted.**  
Response: All Design Engineers have stamped and signed the Project Manual's seals page that is now included within the MS Project Manual. The food service drawings were prepared by a non-licensed professional. These have been coordinated with all stamped drawings.
- 4. While there are exceptions, combustible materials shall not be permitted in concealed spaces of buildings of Type I or II construction. Please furnish explain how material(s) material testing to comply with IBC 603.1 Allowable materials use of combustible materials in concealed spaces of buildings of Type I or II construction shall be limited to the applications indicated in Section 718.5 (similar to Thermax ESR 1659 for foam plastic insulation).**  
Response: According to 2015 IBC 603.1.3 "Combustible materials shall be permitted in the buildings of Type 1 or 2 construction in the following applications: Item 3. Foam plastics in accordance with Chapter 26". At Chapter 2603.3 foam plastic insulation is allowed when "the flame spread index is not more than 75 and a smoke-developed index of not more than 450 where tested in the maximum thickness intended for use in accordance with ASTM E84." When referencing the Project Manual specification 07-2100-3 Thermal Insulation calls out that the installed foam board insulation product must meet the code listed requirements to be installed. Class 1, Flame Spread Index: Class A – 0-25, when tested in accordance with ASTM E84, Smoke Developed Index: 450 or less, when tested in accordance with ASTM E84.
- 5. Snow- and ice-melting systems shall include automatic controls capable of shutting off the system when the pavement temperature is above 50°F (10°C) and no precipitation is falling and an**

automatic or manual control that will allow shutoff when the outdoor temperature is above 40°F (4°C) per IECC C403.2.4.5 Snow- and ice-melt system controls. Also, radiant piping utilized in slab-on-grade applications shall be provided with insulating materials installed beneath the piping having a minimum R-value of 5 as per IMC 1209.5.1 Slab-on-grade installation. Provide details of snow/ice sensor(s) along with details of slab on grade installation per codes referenced above, as applicable.

Response: Under the Existing Building Energy Code we are tying into existing systems with existing controls. We have R-10 insulation called out below new heated slabs.

**6. Provide details of the location of boiler, fire rating per incidental uses, floor drain, as applicable.**

Response: Under the Existing Building Energy Code we are tying into existing systems with existing controls. No new Boiler is proposed.

**7. Deferred submittals shall be approved by the building official and otherwise processed in accordance with the provisions of IBC Section 107.3.4.1. Electronic copies of each deferred submittal shall be submitted to the design professional in responsible charge who shall review them and forward them to the Routt County Regional Building (RCRBD) official with a notation indicating that the deferred submittal documents have been reviewed and found to be in general conformance to the design of the building without any corrections.**

Below is a list of deferred submittals that will be submitted to the RCRBD for review:

- Installation (and removal of the existing) Modular Classroom
- Playground Equipment
- Playground Shade Structure
- Playground Shed

**2020 0406 Strawberry Park Elementary CD's – Stamp.pdf Markup Summary**

**1. Callout #1**

Response: There was no text included in this note but it appears to be pointing to a 90min door. This exterior wall is a 2 hour fire rated wall providing Building Separation.

**2. Provide a narrative to explain calculation of occupants.**

Response: No additional occupants are being added to the Building. The new Cafeteria is being located where two existing classrooms are currently. These two classrooms are being removed for the Cafeteria and are proposed to be included in the new addition. The Cafeteria being an accessory use for the building.

**3. Callout #3**

Response: There was no text included in this note but it appears to be pointing to an existing wall. This wall is to remain and is not included as a Building Separation wall.

**4. In order to eliminate confusion, please remove future work for future phase from this construction set.**

Background: Late in the design process TAB Associates was notified the Pre-K work would be delayed until next spring/summer. We added these notes and the drawings were not removed from the set due to a request from the Contractor to have them included for bidding purposes.

Response: We can see where the confusion came from with the vague 'future work' term but we are requesting this area be permitted at this time and then the School could operate for the coming school year under a TCO and then recommence Construction in the Pre-K area next spring/summer.

The Pre-K area would not have any work done this year, so the existing egress from this area would not be affected.



**5. Comment #5 Food Service Drawing Type 1 Hood.**

Response: This is a warming kitchen. All food preparation is done offsite and meals are simply delivered to this location. No cooking will occur here. This will be included in the Deferred Submittals.

**6. Comment #6 Factory Built commercial exhaust hood.**

Response: This is a warming kitchen. All food preparation is done offsite and meals are simply delivered to this location. No cooking will occur here. This will be included in the Deferred Submittals.

**7. Comment #7 507.6 Performance Test.**

Response: This is a warming kitchen. All food preparation is done offsite and meals are simply delivered to this location. No cooking will occur here. This will be included in the Deferred Submittals. Make up air for the hood is supplied through the kitchen to Cafeteria countertop opening and through a supply air duct in the ceiling.

**8. Comment #8 Existing drawing request.**

Response: Existing drawings have been uploaded to the Bluebeam Session.

**9. Comment #9 Provide narrative detailing why existing 1-HR wall needs up-rating to 2-HR.**

Response: The single door in this CMU wall is being removed and the opening infilled with CMU to match existing. This wall is being used as a Building Fire Separation wall to separate the Gym from the rest of the structure.

**10. Comment #10 While there are exceptions, combustible materials shall not be permitted in concealed spaces of buildings of Type I or II construction. Please furnish explain how material(s) material testing to comply with IBC 603.1 Allowable materials use of combustible materials in concealed spaces of buildings of Type I or II construction shall be limited to the applications indicated in Section 718.5 (similar to Thermax ESR 1659 for foam plastic insulation).**

Response: According to 2015 IBC 603.1.3 "Combustible materials shall be permitted in the buildings of Type 1 or 2 construction in the following applications: Item 3. Foam plastics in accordance with Chapter 26". At Chapter 2603.3 foam plastic insulation is allowed when "the flame spread index is not more than 75 and a smoke-developed index of not more than 450 where tested in the maximum thickness intended for use in accordance with ASTM E84." When referencing the Project Manual specification 07-2100-3 Thermal Insulation calls out that the installed foam board insulation product must meet the code listed requirements to be installed. Class 1, Flame Spread Index: Class A – 0-25, when tested in accordance with ASTM E84, Smoke Developed Index: 450 or less, when tested in accordance with ASTM E84.

**11. Comment #11 Any discrepancy between the operational description and proposed function shall be accompanied with a narrative of explanation with details of code references in reference to Sheet A0.02 and specifications (if applicable as no specifications were submitted).**

Response: This note was added due to a question from the Contractor on some lock features which were associated with existing doors which have a key card integral with the lockset and are being utilized in the Pre-K area.

Please let me know if there are any additional question.

## TAB Associates, Inc.

### *The Architectural Balance*

0056 Edwards Village Boulevard  
Suite 210, Edwards, Colorado 81632  
(970) 766-1470 (970) 766-1471 fax  
www.tabassociates.com tab@vail.net



## Memo

Project: Steamboat Springs Strawberry Park Elementary

Project No: **1935.02**

Date: May 13<sup>th</sup>, 2020

**RE: Kitchen Drawings**

FROM:

**Greg Macik**, Project Architect

TO:

**Ted Allen**, Senior Plans Examiner

VIA: Email: [tallen@co.routt.co.us](mailto:tallen@co.routt.co.us)

### Remarks:

Concerning the kitchen drawings, FS201, FS202, FS203, and FS502.

While the drawings were prepared by a non-licensed professional, the drawings have been reviewed by the design team and they fit into the design intent.

**RCRBD Record Set  
T.A.**

**05/14/2020**

## TAB Associates, Inc.

### *The Architectural Balance*

0056 Edwards Village Boulevard  
Suite 210, Edwards, Colorado 81632  
(970) 766-1470 (970) 766-1471 fax  
www.tabassociates.com tab@vail.net



## Memo

Project: Strawberry Park Elementary

Project No: **TAB: 1935.02 RCRBD: TB-20-258**

Date: May 14, 2020

**RE: Routt County Regional Building Department Permit Comments**

**FROM:**

**Warner Hopkins**, Project Manager

**TO:**

**Ted Allen**, Plans Examiner/ Inspector,  
Routt County Regional Building Department

VIA: Bluebeam Studio Session and Email

### Remarks:

#### Permit Comment Letter from RCRBD:

- All plans submitted to RCRBD for review shall be signed and sealed in accordance with Colorado State Law. RCRBD interprets this to include all documents such as the food service plans and specifications where the Table of Contents is typically signed and sealed by each registered design professional of record if applicable as no specifications were submitted.**

Response: All Design Engineers have stamped and signed the Project Manual's seals page that is now included within the MS Project Manual. The food service drawings were prepared by a non-licensed professional. These have been coordinated with all stamped drawings.

**TAB Response:** Refer to enclosed letter stating the Kitchen drawings have been coordinated.

Please let me know if there are any additional question.

**RCRBD Record Set  
T.A.**

**05/14/2020**



## Interior Lighting Compliance Certificate

## Project Information

Energy Code:

Project Title:

Project Type:

Construction Site:

39620 Amethyst Drive  
Steamboat Springs, CO

2015 IECC

Addition

05/14/2020

Owner/Agent:

Designer/Contractor:

BG Buildingworks  
222 Chapel Place  
Unit AC-201  
Avon, CO 66213  
970-949-6108

## Allowed Interior Lighting Power

A Area Category	B Floor Area (ft <sup>2</sup> )	C Allowed Watts / ft <sup>2</sup>	D Allowed Watts (B X C)
1-School/University	8312	0.87	7231
Total Allowed Watts =			7231

## Proposed Interior Lighting Power

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixtures	D Fixture Watt.	E (C X D)
1-School/University				
LED 1: P1: Other:	1	6	128	768
LED 2: P2E: Other:	1	2	192	384
LED 3: P5: Other:	1	1	61	61
LED 4: P6/P6E: Other:	1	6	64	384
LED 5: R1E: Other:	1	12	11	132
LED 6: R2/R2E: Other:	1	36	49	1764
LED 7: R3/R3E: Other:	1	36	44	1584
LED 8: R4/R4E: Other:	1	3	44	132
LED 9: S1: Other:	1	3	41	123
LED 10: S2: Other:	1	1	36	36
LED 11: S3: Other:	1	2	53	106
LED 13: W1E: Other:	1	3	36	108
LED 14: W2: Other:	1	1	53	53
LED 14: S4: Other:	1	40	28	1120
Total Proposed Watts =				6755

## Interior Lighting PASSES: Design 7% better than code

## Interior Lighting Compliance Statement


*Compliance Statement:* The proposed interior lighting design represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed interior lighting systems have been designed to meet the 2015 IECC requirements in COMcheck Version 4.1.1.0 and to comply with any applicable mandatory

requirements listed in the Inspection Checklist.

Marc Sacconi, PE

Name - Title

Signature



04-6-20

Date

**RCRBD Record Set  
T.A.**

**05/14/2020**



## Exterior Lighting Compliance Certificate

## Project Information

Energy Code:

Project Title:

Project Type:

Exterior Lighting Zone

Construction Site:

39620 Amethyst Drive  
Steamboat Springs, CO

RCRBD Record Set

T.A.

2015 IECC

Addition

2 (Residentially zoned area)

05/14/2020

Owner/Agent:

Designer/Contractor:

BG Buildingworks  
222 Chapel Place  
Unit AC-201  
Avon, CO 66213  
970-949-6108

## Allowed Exterior Lighting Power

A Area/Surface Category	B Quantity	C Allowed Watts / Unit	D Tradable Wattage	E Allowed Watts (B X C)
Other door (not main entry)	12 ft of door	20	Yes	240
Total Tradable Watts (a) =				240
Total Allowed Watts =				240
Total Allowed Supplemental Watts (b) =				600

(a) Wattage tradeoffs are only allowed between tradable areas/surfaces.

(b) A supplemental allowance equal to 600 watts may be applied toward compliance of both non-tradable and tradable areas/surfaces.

## Proposed Exterior Lighting Power

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixtures	D Fixture Watt.	E (C X D)
Other door (not main entry) (12 ft of door width): Tradable Wattage				
LED 1: ZW1E: Other:	1	4	44	176
Total Tradable Proposed Watts =				176

Exterior Lighting PASSES: Design 79% better than code

## Exterior Lighting Compliance Statement

*Compliance Statement:* The proposed exterior lighting design represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed exterior lighting systems have been designed to meet the 2015 IECC requirements in COMcheck Version 4.1.1.0 and to comply with any applicable mandatory requirements listed in the Inspection Checklist.


Marc Sacconi, PE

Name - Title

Signature

04-6-20

Date



4-6-20

Project Title:

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software  
Files\Energy\Calcs\10182.00 - COMcheck.cck

Report date: 04/04/20

Page 3 of 8





# Inspection Checklist

Energy Code: 2015 IECC

Requirements: 64.0% were addressed directly in the COMcheck software

Text in the "Comments/Assumptions" column is provided by the user in the COMcheck Requirements screen. For each requirement, the user certifies that a code requirement will be met and how that is documented, or that an exception is being claimed. Where compliance is itemized in a separate table, a reference to that table is provided.

Section # & Req.ID	Plan Review	Complies?	Comments/Assumptions
C103.2 [PR4] <sup>1</sup>	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the interior lighting and electrical systems and equipment and document where exceptions to the standard are claimed. Information provided should include interior lighting power calculations, wattage of bulbs and ballasts, transformers and control devices.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C103.2 [PR8] <sup>1</sup>	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the exterior lighting and electrical systems and equipment and document where exceptions to the standard are claimed. Information provided should include exterior lighting power calculations, wattage of bulbs and ballasts, transformers and control devices.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C406 [PR9] <sup>1</sup>	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the additional energy efficiency package options.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

**Additional Comments/Assumptions:**

1	High Impact (Tier 1)	2	Medium Impact (Tier 2)	3	Low Impact (Tier 3)
---	----------------------	---	------------------------	---	---------------------

Section # & Req.ID	Rough-In Electrical Inspection	Complies?	Comments/Assumptions
C405.2.1 [EL15] <sup>1</sup>	Lighting controls installed to uniformly reduce the lighting load by at least 50%.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> E0.1, E2.11, E2.12
C405.2.1 [EL18] <sup>1</sup>	Occupancy sensors installed in required spaces.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> E0.1, E2.11, E2.12
C405.2.1, C405.2.2, 3 [EL23] <sup>2</sup>	Independent lighting controls installed per approved lighting plans and all manual controls readily accessible and visible to occupants.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> E0.1, E2.11, E2.12
C405.2.2.1 [EL22] <sup>2</sup>	Automatic controls to shut off all building lighting installed in all buildings.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Lighting controlled by occupancy sensors. <b>Location on plans/spec:</b> E0.1, E2.11, E2.12
C405.2.3 [EL16] <sup>2</sup>	Daylight zones provided with individual controls that control the lights independent of general area lighting.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> E0.1, E2.11, E2.12
C405.2.3, C405.2.3.1, C405.2.3.2 [EL20] <sup>1</sup>	Primary sidelighted areas are equipped with required lighting controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> E0.1, E2.11, E2.12
C405.2.3, C405.2.3.1, C405.2.3.3 [EL21] <sup>1</sup>	Enclosed spaces with daylight area under skylights and rooftop monitors are equipped with required lighting controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C405.2.4 [EL4] <sup>1</sup>	Separate lighting control devices for specific uses installed per approved lighting plans.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> E0.1, E2.11, E2.12
C405.2.4 [EL8] <sup>1</sup>	Additional interior lighting power allowed for special functions per the approved lighting plans and is automatically controlled and separated from general lighting.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> E0.1, E2.11, E2.12
C405.2.5 [EL25] <sup>null</sup>	Automatic lighting controls for exterior lighting installed. Controls will be daylight controlled, set based on business operation time-of-day, or reduce connected lighting > 30%.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> E0.1, E2.11
C405.3 [EL6] <sup>1</sup>	Exit signs do not exceed 5 watts per face.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> E0.1

**Additional Comments/Assumptions:**

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title:

Report date: 04/04/20

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software Files\Energy\Calcs\10182.00 - COMcheck.cck

Page 5 of 8

# RCRBD Record Set T.A.

05/14/2020

1	High Impact (Tier 1)	2	Medium Impact (Tier 2)	3	Low Impact (Tier 3)
---	----------------------	---	------------------------	---	---------------------

Project Title:

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software  
Files\Energy\Calcs\10182.00 - COMcheck.cck

Report date: 04/04/20

Page 6 of 8

Section # & Req.ID	Final Inspection	Complies?	Comments/Assumptions
C303.3, C408.2.5.2 [FI17] <sup>3</sup>	Furnished O&M instructions for systems and equipment to the building owner or designated representative.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C405.4.1 [FI18] <sup>1</sup>	Interior installed lamp and fixture lighting power is consistent with what is shown on the approved lighting plans, demonstrating proposed watts are less than or equal to allowed watts.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Interior Lighting fixture schedule for values.
C405.5.1 [FI19] <sup>1</sup>	Exterior lighting power is consistent with what is shown on the approved lighting plans, demonstrating proposed watts are less than or equal to allowed watts.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Exterior Lighting fixture schedule for values.
C408.2.5.1 [FI16] <sup>3</sup>	Furnished as-built drawings for electric power systems within 90 days of system acceptance.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C408.3 [FI33] <sup>1</sup>	Lighting systems have been tested to ensure proper calibration, adjustment, programming, and operation.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

**Additional Comments/Assumptions:**

1	High Impact (Tier 1)	2	Medium Impact (Tier 2)	3	Low Impact (Tier 3)
---	----------------------	---	------------------------	---	---------------------

Project Title:

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software Files\Energy\Calcs\10182.00 - COMcheck.cck

Report date: 04/04/20

Page 7 of 8

**RCRBD Record Set  
T.A.**

**05/14/2020**



# Mechanical Compliance Certificate

**RCRBD Record Set**

**T.A.**

2015 IECC

Yampa, Colorado

7

Addition

**05/14/2020**

## Project Information

Energy Code:

Project Title:

Location:

Climate Zone:

Project Type:

Construction Site:

39620 Amethyst Drive  
Steamboat Springs, CO

Owner/Agent:

Designer/Contractor:

BG Buildingworks  
222 Chapel Place  
Unit AC-201  
Avon, CO 66213  
970-949-6108

## Mechanical Systems List

### Quantity System Type & Description

- |   |  |
|---|--|
| 1 | VAV-01 (Single Zone):<br>Heating: 1 each - Hydronic or Steam Coil, Hot Water, Capacity = 16 kBtu/h<br>No minimum efficiency requirement applies<br>Fan System: None  |
| 1 | VAV-02 (Single Zone):<br>Heating: 1 each - Hydronic or Steam Coil, Hot Water, Capacity = 90 kBtu/h<br>No minimum efficiency requirement applies<br>Fan System: None  |
| 1 | VAV-03 (Single Zone):<br>Heating: 1 each - Hydronic or Steam Coil, Hot Water, Capacity = 5 kBtu/h<br>No minimum efficiency requirement applies<br>Fan System: None   |
| 1 | VAV-04 (Single Zone):<br>Heating: 1 each - Hydronic or Steam Coil, Hot Water, Capacity = 28 kBtu/h<br>No minimum efficiency requirement applies<br>Fan System: None  |
| 1 | VAV-05 (Single Zone):<br>Heating: 1 each - Hydronic or Steam Coil, Hot Water, Capacity = 28 kBtu/h<br>No minimum efficiency requirement applies<br>Fan System: None  |
| 1 | AHU-1 HW Coil (Multiple-Zone):<br>Heating: 1 each - Hydronic or Steam Coil, Hot Water, Capacity = 263 kBtu/h<br>No minimum efficiency requirement applies<br>Fan System: AHU-1 Supply Fan   Cafeteria, Art, Music -- Compliance (Brake HP method) : Passes<br><br>Fans:<br>FAN 1 Supply, Multi-Zone VAV, 6500 CFM, 5.0 motor nameplate hp, 3.0 design brake hp (3.0 max. BHP), 89.5 fan efficiency grade |
| 1 | AHU-1 DX Coil (Multiple-Zone):<br>Cooling: 1 each - Split System, Capacity = 156 kBtu/h, Air-Cooled Condenser, Air Economizer<br>Proposed Efficiency = 13.40 EER, Required Efficiency: 11.00 EER + 12.4 IEER<br>Fan System: AHU-1 Supply Fan   Cafeteria, Art, Music -- Compliance (Brake HP method) : Passes  |



## Quantity System Type & Description

Fans:

FAN 1 Supply, Multi-Zone VAV, 6500 CFM, 5.0 motor nameplate hp, 3.0 design brake hp (3.0 max. BHP), 89.5 fan efficiency grade

1 (E) FPB-1-9 (Single Zone):

Heating: 1 each - Hydronic or Steam Coil, Hot Water, Capacity = 40 kBtu/h

No minimum efficiency requirement applies

Fan System: (E) FPB-1-9 | Pre-K East - Compliance (Brake HP method) : Passes

Fans:

FAN 2 Supply, Single-Zone VAV, 480 CFM, 0.8 motor nameplate hp, 0.8 design brake hp (0.8 max. BHP), 70.0 fan efficiency grade

1 (E) FPB-1-10 (Single Zone):

Heating: 1 each - Hydronic or Steam Coil, Hot Water, Capacity = 39 kBtu/h

No minimum efficiency requirement applies

Fan System: (E) FPB-1-10 | Pre-K West - Compliance (Brake HP method) : Passes

Fans:

FAN 4 Supply, Single-Zone VAV, 450 CFM, 0.8 motor nameplate hp, 0.8 design brake hp (0.8 max. BHP), 70.0 fan efficiency grade

## Mechanical Compliance Statement

*Compliance Statement:* The proposed mechanical design represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed mechanical systems have been designed to meet the 2015 IECC requirements in COMcheck Version 4.1.1.0 and to comply with any applicable mandatory requirements listed in the Inspection Checklist.


David Lyle - Principal, PE

Name - Title

Signature

04.06.2020

Date





# Inspection Checklist

Energy Code: 2015 IECC

Requirements: 90.0% were addressed directly in the COMcheck software

Text in the "Comments/Assumptions" column is provided by the user in the COMcheck Requirements screen. For each requirement, the user certifies that a code requirement will be met and how that is documented, or that an exception is being claimed. Where compliance is itemized in a separate table, a reference to that table is provided.

Section # & Req.ID	Plan Review	Complies?	Comments/Assumptions
C103.2 [PR2] <sup>1</sup>	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the mechanical systems and equipment and document where exceptions to the standard are claimed. Load calculations per acceptable engineering standards and handbooks.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C406 [PR9] <sup>1</sup>	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the additional energy efficiency package options.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.

**Additional Comments/Assumptions:**

1	High Impact (Tier 1)	2	Medium Impact (Tier 2)	3	Low Impact (Tier 3)
---	----------------------	---	------------------------	---	---------------------

Section # & Req.ID	Footing / Foundation Inspection	Complies?	Comments/Assumptions
C403.2.4.5, C403.2.4.6 [FO9] <sup>3</sup>	Snow/ice melting system sensors for future connection to controls. Freeze protection systems have automatic controls installed.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams

**Additional Comments/Assumptions:**

**RCRBD Record Set**

**T.A.**

**05/14/2020**

1	High Impact (Tier 1)	2	Medium Impact (Tier 2)	3	Low Impact (Tier 3)
---	----------------------	---	------------------------	---	---------------------

Project Title:

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software Files\Energy\Calcs\10182.00 - COMcheck.cck

Report date: 04/04/20

Page 4 of 20

Section # & Req.ID	Plumbing Rough-In Inspection	Complies?	Comments/Assumptions
C404.5, C404.5.1, C404.5.2 [PL6] <sup>3</sup>	Heated water supply piping conforms to pipe length and volume requirements. Refer to section details.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C404.5, C404.5.1, C404.5.2 [PL6] <sup>3</sup>	Heated water supply piping conforms to pipe length and volume requirements. Refer to section details.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C404.5, C404.5.1, C404.5.2 [PL6] <sup>3</sup>	Heated water supply piping conforms to pipe length and volume requirements. Refer to section details.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C404.5, C404.5.1, C404.5.2 [PL6] <sup>3</sup>	Heated water supply piping conforms to pipe length and volume requirements. Refer to section details.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C404.5, C404.5.1, C404.5.2 [PL6] <sup>3</sup>	Heated water supply piping conforms to pipe length and volume requirements. Refer to section details.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C404.5, C404.5.1, C404.5.2 [PL6] <sup>3</sup>	Heated water supply piping conforms to pipe length and volume requirements. Refer to section details.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C404.5, C404.5.1, C404.5.2 [PL6] <sup>3</sup>	Heated water supply piping conforms to pipe length and volume requirements. Refer to section details.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C404.5, C404.5.1, C404.5.2 [PL6] <sup>3</sup>	Heated water supply piping conforms to pipe length and volume requirements. Refer to section details.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C404.5, C404.5.1, C404.5.2 [PL6] <sup>3</sup>	Heated water supply piping conforms to pipe length and volume requirements. Refer to section details.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C404.5, C404.5.1, C404.5.2 [PL6] <sup>3</sup>	Heated water supply piping conforms to pipe length and volume requirements. Refer to section details.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C404.6.3 [PL7] <sup>3</sup>	Pumps that circulate water between a heater and storage tank have controls that limit operation from startup to <= 5 minutes after end of heating cycle.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C404.6.3 [PL7] <sup>3</sup>	Pumps that circulate water between a heater and storage tank have controls that limit operation from startup to <= 5 minutes after end of heating cycle.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title:

Report date: 04/04/20

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software Files\Energy\Calcs\10182.00 - COMcheck.cck

Page 5 of 20

Section # & Req.ID	Plumbing Rough-In Inspection	Complies?	Comments/Assumptions
C404.6.3 [PL7] <sup>3</sup>	Pumps that circulate water between a heater and storage tank have controls that limit operation from startup to <= 5 minutes after end of heating cycle.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C404.6.3 [PL7] <sup>3</sup>	Pumps that circulate water between a heater and storage tank have controls that limit operation from startup to <= 5 minutes after end of heating cycle.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C404.6.3 [PL7] <sup>3</sup>	Pumps that circulate water between a heater and storage tank have controls that limit operation from startup to <= 5 minutes after end of heating cycle.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C404.6.3 [PL7] <sup>3</sup>	Pumps that circulate water between a heater and storage tank have controls that limit operation from startup to <= 5 minutes after end of heating cycle.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C404.6.3 [PL7] <sup>3</sup>	Pumps that circulate water between a heater and storage tank have controls that limit operation from startup to <= 5 minutes after end of heating cycle.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C404.6.3 [PL7] <sup>3</sup>	Pumps that circulate water between a heater and storage tank have controls that limit operation from startup to <= 5 minutes after end of heating cycle.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C404.6.3 [PL7] <sup>3</sup>	Pumps that circulate water between a heater and storage tank have controls that limit operation from startup to <= 5 minutes after end of heating cycle.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C404.7 [PL8] <sup>3</sup>	Water distribution system that pumps water from a heated-water supply pipe back to the heated-water source through a cold-water supply pipe is a demand recirculation water system. Pumps within this system have controls that start the pump upon receiving a signal from the action of a user of a fixture or appliance and limits the temperature of the water entering the cold-water piping to 104°F.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C404.7 [PL8] <sup>3</sup>	Water distribution system that pumps water from a heated-water supply pipe back to the heated-water source through a cold-water supply pipe is a demand recirculation water system. Pumps within this system have controls that start the pump upon receiving a signal from the action of a user of a fixture or appliance and limits the temperature of the water entering the cold-water piping to 104°F.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title:

Report date: 04/04/20

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software Files\Energy\Calcs\10182.00 - COMcheck.cck

Page 6 of 20

Section # & Req.ID	Plumbing Rough-In Inspection	Complies?	Comments/Assumptions
C404.7 [PL8] <sup>3</sup>	Water distribution system that pumps water from a heated-water supply pipe back to the heated-water source through a cold-water supply pipe is a demand recirculation water system. Pumps within this system have controls that start the pump upon receiving a signal from the action of a user of a fixture or appliance and limits the temperature of the water entering the cold-water piping to 104°F.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C404.7 [PL8] <sup>3</sup>	Water distribution system that pumps water from a heated-water supply pipe back to the heated-water source through a cold-water supply pipe is a demand recirculation water system. Pumps within this system have controls that start the pump upon receiving a signal from the action of a user of a fixture or appliance and limits the temperature of the water entering the cold-water piping to 104°F.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C404.7 [PL8] <sup>3</sup>	Water distribution system that pumps water from a heated-water supply pipe back to the heated-water source through a cold-water supply pipe is a demand recirculation water system. Pumps within this system have controls that start the pump upon receiving a signal from the action of a user of a fixture or appliance and limits the temperature of the water entering the cold-water piping to 104°F.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C404.7 [PL8] <sup>3</sup>	Water distribution system that pumps water from a heated-water supply pipe back to the heated-water source through a cold-water supply pipe is a demand recirculation water system. Pumps within this system have controls that start the pump upon receiving a signal from the action of a user of a fixture or appliance and limits the temperature of the water entering the cold-water piping to 104°F.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C404.7 [PL8] <sup>3</sup>	Water distribution system that pumps water from a heated-water supply pipe back to the heated-water source through a cold-water supply pipe is a demand recirculation water system. Pumps within this system have controls that start the pump upon receiving a signal from the action of a user of a fixture or appliance and limits the temperature of the water entering the cold-water piping to 104°F.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title:

Report date: 04/04/20

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software Files\Energy\Calcs\10182.00 - COMcheck.cck

Page 7 of 20



Section # & Req.ID	Plumbing Rough-In Inspection	Complies?	Comments/Assumptions
C404.7 [PL8] <sup>3</sup>	Water distribution system that pumps water from a heated-water supply pipe back to the heated-water source through a cold-water supply pipe is a demand recirculation water system. Pumps within this system have controls that start the pump upon receiving a signal from the action of a user of a fixture or appliance and limits the temperature of the water entering the cold-water piping to 104°F.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C404.7 [PL8] <sup>3</sup>	Water distribution system that pumps water from a heated-water supply pipe back to the heated-water source through a cold-water supply pipe is a demand recirculation water system. Pumps within this system have controls that start the pump upon receiving a signal from the action of a user of a fixture or appliance and limits the temperature of the water entering the cold-water piping to 104°F.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.

**Additional Comments/Assumptions:**

1	High Impact (Tier 1)	2	Medium Impact (Tier 2)	3	Low Impact (Tier 3)
---	----------------------	---	------------------------	---	---------------------

Project Title:

Report date: 04/04/20

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software Files\Energy\Calcs\10182.00 - COMcheck.cck

Page 8 of 20

Section # & Req.ID	Mechanical Rough-In Inspection	Complies?	Comments/Assumptions
C402.2.6 [ME41] <sup>3</sup>	Thermally ineffective panel surfaces of sensible heating panels have insulation $\geq R-3.5$	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C403.2.12 .1 [ME65] <sup>3</sup>	HVAC fan systems at design conditions do not exceed allowable fan system motor nameplate hp or fan system bhp.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply. <i>See the Mechanical Systems list for values.</i>
C403.2.12 .1 [ME65] <sup>3</sup>	HVAC fan systems at design conditions do not exceed allowable fan system motor nameplate hp or fan system bhp.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply. <i>See the Mechanical Systems list for values.</i>
C403.2.12 .1 [ME65] <sup>3</sup>	HVAC fan systems at design conditions do not exceed allowable fan system motor nameplate hp or fan system bhp.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply. <i>See the Mechanical Systems list for values.</i>
C403.2.12 .1 [ME65] <sup>3</sup>	HVAC fan systems at design conditions do not exceed allowable fan system motor nameplate hp or fan system bhp.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply. <i>See the Mechanical Systems list for values.</i>
C403.2.12 .1 [ME65] <sup>3</sup>	HVAC fan systems at design conditions do not exceed allowable fan system motor nameplate hp or fan system bhp.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply. <i>See the Mechanical Systems list for values.</i>
C403.2.12 .3 [ME117] <sup>2</sup>	Fans have efficiency grade (FEG) $\geq 67$ . The total efficiency of the fan at the design point of operation $\leq 15\%$ of maximum total efficiency of the fan.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams - No fan powered box on new VAV-01 thru VAV-05
C403.2.12 .3 [ME117] <sup>2</sup>	Fans have efficiency grade (FEG) $\geq 67$ . The total efficiency of the fan at the design point of operation $\leq 15\%$ of maximum total efficiency of the fan.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams - No fan powered box on new VAV-01 thru VAV-05
C403.2.12 .3 [ME117] <sup>2</sup>	Fans have efficiency grade (FEG) $\geq 67$ . The total efficiency of the fan at the design point of operation $\leq 15\%$ of maximum total efficiency of the fan.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams - No fan powered box on new VAV-01 thru VAV-05
C403.2.12 .3 [ME117] <sup>2</sup>	Fans have efficiency grade (FEG) $\geq 67$ . The total efficiency of the fan at the design point of operation $\leq 15\%$ of maximum total efficiency of the fan.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams - No fan powered box on new VAV-01 thru VAV-05
C403.2.12 .3 [ME117] <sup>2</sup>	Fans have efficiency grade (FEG) $\geq 67$ . The total efficiency of the fan at the design point of operation $\leq 15\%$ of maximum total efficiency of the fan.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams - No fan powered box on new VAV-01 thru VAV-05
C403.2.13 [ME71] <sup>2</sup>	Unenclosed spaces that are heated use only radiant heat.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Section # & Req.ID	Mechanical Rough-In Inspection	Complies?	Comments/Assumptions
C403.2.3 [ME55] <sup>2</sup>	HVAC equipment efficiency verified.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Mechanical Systems list for values.
C403.2.4.4 [ME112] <sup>3</sup>	Zone isolation devices and controls installed where applicable.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C403.2.4.4 [ME112] <sup>3</sup>	Zone isolation devices and controls installed where applicable.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C403.2.4.7 [ME113] <sup>2</sup>	Fault detection and diagnostics installed with air-cooled unitary DX units having economizers.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: M2.1 Main Level Area A Mechanical Plan
C403.2.6.1 [ME59] <sup>1</sup>	Demand control ventilation provided for spaces >500 ft <sup>2</sup> and >25 people/1000 ft <sup>2</sup> occupant density and served by systems with air side economizer, auto modulating outside air damper control, or design airflow >3,000 cfm.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Multiple-zone systems without DDC. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C403.2.6.2 [ME115] <sup>3</sup>	Enclosed parking garage ventilation has automatic contaminant detection and capacity to stage or modulate fans to 50% or less of design capacity.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C403.2.7 [ME57] <sup>1</sup>	Exhaust air energy recovery on systems meeting Table C403.2.7(1) and C403.2.7(2).	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Where the largest exhaust source is less than 75% of the design outdoor airflow. <b>Location on plans/spec:</b> RE: M2.2 Pre-K Plan Area B Mechanical Plan
C403.2.8 [ME116] <sup>3</sup>	Kitchen exhaust systems comply with replacement air and conditioned supply air limitations, and satisfy hood rating requirements and maximum exhaust rate criteria.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C403.2.9 [ME60] <sup>2</sup>	HVAC ducts and plenums insulated. Where ducts or plenums are installed in or under a slab, verification may need to occur during Foundation Inspection.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: M2.2 Pre-K Plan Area B Mechanical Plan
C403.2.9 [ME10] <sup>2</sup>	Ducts and plenums sealed based on static pressure and location.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.2.9.1.3 [ME11] <sup>3</sup>	Ductwork operating >3 in. water column requires air leakage testing.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.2.9.1.3 [ME11] <sup>3</sup>	Ductwork operating >3 in. water column requires air leakage testing.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title:

Report date: 04/04/20

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software Files\Energy\Calcs\10182.00 - COMcheck.cck

Page 10 of 20

Section # & Req.ID	Mechanical Rough-In Inspection	Complies?	Comments/Assumptions
C403.2.9.1.3 [ME11] <sup>3</sup>	Ductwork operating >3 in. water column requires air leakage testing.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.2.9.1.3 [ME11] <sup>3</sup>	Ductwork operating >3 in. water column requires air leakage testing.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.2.9.1.3 [ME11] <sup>3</sup>	Ductwork operating >3 in. water column requires air leakage testing.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.2.9.1.3 [ME11] <sup>3</sup>	Ductwork operating >3 in. water column requires air leakage testing.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C403.2.9.1.3 [ME11] <sup>3</sup>	Ductwork operating >3 in. water column requires air leakage testing.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.3 [ME62] <sup>1</sup>	Air economizers provided where required, meet the requirements for design capacity, control signal, ventilation controls, high-limit shut-off, integrated economizer control, and provide a means to relieve excess outside air during operation.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C403.4.1.1 [ME75] <sup>2</sup>	Hydronic and multizone HVAC system controls are VAV fans driven by mechanical or electrical variable speed drive per Table C403.4.1.1.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C403.4.1.1 [ME75] <sup>2</sup>	Hydronic and multizone HVAC system controls are VAV fans driven by mechanical or electrical variable speed drive per Table C403.4.1.1.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C403.4.1.2 [ME67] <sup>2</sup>	VAV fans have static pressure sensors located so controller setpoint ≤ 1.2 w.c..	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C403.4.1.2 [ME67] <sup>2</sup>	VAV fans have static pressure sensors located so controller setpoint ≤ 1.2 w.c..	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C403.4.1.3 [ME24] <sup>2</sup>	Reset static pressure setpoint for DDC controlled VAV boxes reporting to central controller based on the zones requiring the most pressure.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.
C403.4.1.3 [ME24] <sup>2</sup>	Reset static pressure setpoint for DDC controlled VAV boxes reporting to central controller based on the zones requiring the most pressure.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.

☐ 1 High Impact (Tier 1)
 ☒ 2 Medium Impact (Tier 2)
 ☐ 3 Low Impact (Tier 3)

Project Title:

Report date: 04/04/20

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software Files\Energy\Calcs\10182.00 - COMcheck.cck

Page 11 of 20

Section # & Req.ID	Mechanical Rough-In Inspection	Complies?	Comments/Assumptions
C403.4.2.1 [ME50] <sup>2</sup>	Three-pipe hydronic systems using a common return for hot and chilled water are not used.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.4.2.1 [ME50] <sup>2</sup>	Three-pipe hydronic systems using a common return for hot and chilled water are not used.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.4.2.1 [ME50] <sup>2</sup>	Three-pipe hydronic systems using a common return for hot and chilled water are not used.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.4.2.1 [ME50] <sup>2</sup>	Three-pipe hydronic systems using a common return for hot and chilled water are not used.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.4.2.1 [ME50] <sup>2</sup>	Three-pipe hydronic systems using a common return for hot and chilled water are not used.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.4.2.1 [ME50] <sup>2</sup>	Three-pipe hydronic systems using a common return for hot and chilled water are not used.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.4.2.1 [ME50] <sup>2</sup>	Three-pipe hydronic systems using a common return for hot and chilled water are not used.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.4.2.1 [ME50] <sup>2</sup>	Three-pipe hydronic systems using a common return for hot and chilled water are not used.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.4.2.6 [ME26] <sup>3</sup>	Chilled water plants with multiple chillers have capability to reduce flow automatically through the chiller plant when a chiller is shut down. Boiler plants with multiple boilers have the capability to reduce flow automatically through the boiler plant when a boiler is shut down.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.4.2.6 [ME26] <sup>3</sup>	Chilled water plants with multiple chillers have capability to reduce flow automatically through the chiller plant when a chiller is shut down. Boiler plants with multiple boilers have the capability to reduce flow automatically through the boiler plant when a boiler is shut down.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.4.2.6 [ME26] <sup>3</sup>	Chilled water plants with multiple chillers have capability to reduce flow automatically through the chiller plant when a chiller is shut down. Boiler plants with multiple boilers have the capability to reduce flow automatically through the boiler plant when a boiler is shut down.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title:

Report date: 04/04/20

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software Files\Energy\Calcs\10182.00 - COMcheck.cck

Page 12 of 20

Section # & Req.ID	Mechanical Rough-In Inspection	Complies?	Comments/Assumptions
C403.4.2.6 [ME26] <sup>3</sup>	Chilled water plants with multiple chillers have capability to reduce flow automatically through the chiller plant when a chiller is shut down. Boiler plants with multiple boilers have the capability to reduce flow automatically through the boiler plant when a boiler is shut down.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.4.2.6 [ME26] <sup>3</sup>	Chilled water plants with multiple chillers have capability to reduce flow automatically through the chiller plant when a chiller is shut down. Boiler plants with multiple boilers have the capability to reduce flow automatically through the boiler plant when a boiler is shut down.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.4.2.6 [ME26] <sup>3</sup>	Chilled water plants with multiple chillers have capability to reduce flow automatically through the chiller plant when a chiller is shut down. Boiler plants with multiple boilers have the capability to reduce flow automatically through the boiler plant when a boiler is shut down.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C403.4.2.6 [ME26] <sup>3</sup>	Chilled water plants with multiple chillers have capability to reduce flow automatically through the chiller plant when a chiller is shut down. Boiler plants with multiple boilers have the capability to reduce flow automatically through the boiler plant when a boiler is shut down.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C403.4.2.6 [ME26] <sup>3</sup>	Chilled water plants with multiple chillers have capability to reduce flow automatically through the chiller plant when a chiller is shut down. Boiler plants with multiple boilers have the capability to reduce flow automatically through the boiler plant when a boiler is shut down.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C403.4.4.6 [ME110] <sup>3</sup>	Multiple zone VAV systems with DDC of individual zone boxes have static pressure setpoint reset controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams - No fan powered box on new VAV-01 thru VAV-05  <i>See the Mechanical Systems list for values.</i>
C403.4.4.6 [ME110] <sup>3</sup>	Multiple zone VAV systems with DDC of individual zone boxes have static pressure setpoint reset controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams - No fan powered box on new VAV-01 thru VAV-05  <i>See the Mechanical Systems list for values.</i>
C403.4.4.6 [ME110] <sup>3</sup>	Multiple zone VAV systems with DDC of individual zone boxes have static pressure setpoint reset controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams - No fan powered box on new VAV-01 thru VAV-05  <i>See the Mechanical Systems list for values.</i>

1 High Impact (Tier 1)    2 Medium Impact (Tier 2)    3 Low Impact (Tier 3)



Section # & Req.ID	Mechanical Rough-In Inspection	Complies?	Comments/Assumptions
C403.4.4.6 [ME110] <sup>3</sup>	Multiple zone VAV systems with DDC of individual zone boxes have static pressure setpoint reset controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams - No fan powered box on new VAV-01 thru VAV-05 <i>See the Mechanical Systems list for values.</i>
C403.4.4.6 [ME110] <sup>3</sup>	Multiple zone VAV systems with DDC of individual zone boxes have static pressure setpoint reset controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams - No fan powered box on new VAV-01 thru VAV-05 <i>See the Mechanical Systems list for values.</i>
C403.4.4.6 [ME110] <sup>3</sup>	Multiple zone VAV systems with DDC of individual zone boxes have static pressure setpoint reset controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams <i>See the Mechanical Systems list for values.</i>
C403.4.4.6 [ME110] <sup>3</sup>	Multiple zone VAV systems with DDC of individual zone boxes have static pressure setpoint reset controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams <i>See the Mechanical Systems list for values.</i>
C403.4.4.6 [ME110] <sup>3</sup>	Multiple zone VAV systems with DDC of individual zone boxes have static pressure setpoint reset controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply. <i>See the Mechanical Systems list for values.</i>
C403.4.4.6 [ME110] <sup>3</sup>	Multiple zone VAV systems with DDC of individual zone boxes have static pressure setpoint reset controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply. <i>See the Mechanical Systems list for values.</i>
C403.4.5 [ME31] <sup>3</sup>	Condenser heat recovery system that can heat water to 85 °F or provide 60% of peak heat rejection is installed for preheating of service hot water.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Design SWH load = 1 MMBtu/h. <b>Location on plans/spec:</b> RE: Terminal Box Schedule on M0.1 Mechanical Schedules
C403.4.5 [ME31] <sup>3</sup>	Condenser heat recovery system that can heat water to 85 °F or provide 60% of peak heat rejection is installed for preheating of service hot water.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Design SWH load = 1 MMBtu/h. <b>Location on plans/spec:</b> RE: Terminal Box Schedule on M0.1 Mechanical Schedules
C403.4.5 [ME31] <sup>3</sup>	Condenser heat recovery system that can heat water to 85 °F or provide 60% of peak heat rejection is installed for preheating of service hot water.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Design SWH load = 1 MMBtu/h. <b>Location on plans/spec:</b> RE: Terminal Box Schedule on M0.1 Mechanical Schedules
C403.4.5 [ME31] <sup>3</sup>	Condenser heat recovery system that can heat water to 85 °F or provide 60% of peak heat rejection is installed for preheating of service hot water.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Design SWH load = 1 MMBtu/h. <b>Location on plans/spec:</b> RE: Terminal Box Schedule on M0.1 Mechanical Schedules
C403.4.5 [ME31] <sup>3</sup>	Condenser heat recovery system that can heat water to 85 °F or provide 60% of peak heat rejection is installed for preheating of service hot water.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Design SWH load = 1 MMBtu/h. <b>Location on plans/spec:</b> RE: Terminal Box Schedule on M0.1 Mechanical Schedules

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title:

Report date: 04/04/20

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software Files\Energy\Calcs\10182.00 - COMcheck.cck

Page 14 of 20

Section # & Req.ID	Mechanical Rough-In Inspection	Complies?	Comments/Assumptions
C403.4.5 [ME31] <sup>3</sup>	Condenser heat recovery system that can heat water to 85 °F or provide 60% of peak heat rejection is installed for preheating of service hot water.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Design SWH load = 1 MMBtu/h. <b>Location on plans/spec:</b> RE: Hydronic Air Handling Unit Schedule on M0.1 Mechanical Schedules
C403.4.5 [ME31] <sup>3</sup>	Condenser heat recovery system that can heat water to 85 °F or provide 60% of peak heat rejection is installed for preheating of service hot water.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Design SWH load = 1 MMBtu/h. <b>Location on plans/spec:</b> RE: Hydronic Air Handling Unit Schedule on M0.1 Mechanical Schedules
C403.4.5 [ME31] <sup>3</sup>	Condenser heat recovery system that can heat water to 85 °F or provide 60% of peak heat rejection is installed for preheating of service hot water.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Design SWH load = 1 MMBtu/h. <b>Location on plans/spec:</b> RE: Hydronic Air Handling Unit Schedule on M0.1 Mechanical Schedules
C408.2.2.1 [ME53] <sup>3</sup>	Air outlets and zone terminal devices have means for air balancing.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: M2.1 Main Level Area A Mechanical Plan
C408.2.2.2 [ME54] <sup>3</sup>	HVAC hydronic heating and cooling coils have means to balance and have pressure test connections.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C408.2.2.2 [ME54] <sup>3</sup>	HVAC hydronic heating and cooling coils have means to balance and have pressure test connections.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C408.2.2.2 [ME54] <sup>3</sup>	HVAC hydronic heating and cooling coils have means to balance and have pressure test connections.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C408.2.2.2 [ME54] <sup>3</sup>	HVAC hydronic heating and cooling coils have means to balance and have pressure test connections.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C408.2.2.2 [ME54] <sup>3</sup>	HVAC hydronic heating and cooling coils have means to balance and have pressure test connections.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C408.2.2.2 [ME54] <sup>3</sup>	HVAC hydronic heating and cooling coils have means to balance and have pressure test connections.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C408.2.2.2 [ME54] <sup>3</sup>	HVAC hydronic heating and cooling coils have means to balance and have pressure test connections.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C408.2.2.2 [ME54] <sup>3</sup>	HVAC hydronic heating and cooling coils have means to balance and have pressure test connections.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Section # & Req.ID	Mechanical Rough-In Inspection	Complies?	Comments/Assumptions
C403.5, C403.5.1, C403.5.2 [ME123] <sup>3</sup>	Refrigerated display cases, walk-in coolers or walk-in freezers served by remote compressors and remote condensers not located in a condensing unit, have free-flowing condensers that comply with Sections C403.5.1 and refrigeration compressor systems that comply with C403.5.2..	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	<b>Exception:</b> Requirement does not apply.

RCRBD Record Set  
T.A.

**Additional Comments/Assumptions:**

05/14/2020

1	High Impact (Tier 1)	2	Medium Impact (Tier 2)	3	Low Impact (Tier 3)
---	----------------------	---	------------------------	---	---------------------

Project Title:

Report date: 04/04/20

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software Files\Energy\Calcs\10182.00 - COMcheck.cck

Page 16 of 20

Section # & Req.ID	Final Inspection	Complies?	Comments/Assumptions
C303.3, C408.2.5.3 [FI8] <sup>3</sup>	Furnished O&M manuals for HVAC systems within 90 days of system acceptance.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C403.2.2 [FI27] <sup>3</sup>	HVAC systems and equipment capacity does not exceed calculated loads.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.
C403.2.4.1 [FI47] <sup>3</sup>	Heating and cooling to each zone is controlled by a thermostat control. Minimum one humidity control device per installed humidification/dehumidification system.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: M2.1 Main Level Area A Mechanical Plan
C403.2.4.1 [FI47] <sup>3</sup>	Heating and cooling to each zone is controlled by a thermostat control. Minimum one humidity control device per installed humidification/dehumidification system.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: M2.1 Main Level Area A Mechanical Plan
C403.2.4.1 [FI47] <sup>3</sup>	Heating and cooling to each zone is controlled by a thermostat control. Minimum one humidity control device per installed humidification/dehumidification system.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: M2.1 Main Level Area A Mechanical Plan
C403.2.4.1 [FI47] <sup>3</sup>	Heating and cooling to each zone is controlled by a thermostat control. Minimum one humidity control device per installed humidification/dehumidification system.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: M2.1 Main Level Area A Mechanical Plan
C403.2.4.1 [FI47] <sup>3</sup>	Heating and cooling to each zone is controlled by a thermostat control. Minimum one humidity control device per installed humidification/dehumidification system.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: M2.1 Main Level Area A Mechanical Plan
C403.2.4.1 [FI47] <sup>3</sup>	Heating and cooling to each zone is controlled by a thermostat control. Minimum one humidity control device per installed humidification/dehumidification system.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: M2.1 Main Level Area A Mechanical Plan
C403.2.4.1 [FI47] <sup>3</sup>	Heating and cooling to each zone is controlled by a thermostat control. Minimum one humidity control device per installed humidification/dehumidification system.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met. <b>Location on plans/spec:</b> RE: M2.2 Pre-K Plan Area B Mechanical Plan

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Project Title:

Report date: 04/04/20

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software Files\Energy\Calcs\10182.00 - COMcheck.cck

Page 17 of 20

Section # & Req.ID	Final Inspection	Complies?	Comments/Assumptions
C403.2.4.1 [FI47] <sup>3</sup>	Heating and cooling to each zone is controlled by a thermostat control. Minimum one humidity control device per installed humidification/dehumidification system.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: M2.2 Pre-K Plan Area B Mechanical Plan
C403.2.4.1.2 [FI38] <sup>3</sup>	Thermostatic controls have a 5 °F deadband.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C403.2.4.1.3 [FI20] <sup>3</sup>	Temperature controls have setpoint overlap restrictions	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C403.2.4.2 [FI39] <sup>3</sup>	Each zone equipped with setback controls using automatic time clock or programmable control system.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C403.2.4.2.1, C403.2.4.2.2 [FI40] <sup>3</sup>	Automatic Controls: Setback to 55°F (heat) and 85°F (cool); 7-day clock, 2-hour occupant override, 10-hour backup	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C403.2.4.2.3 [FI41] <sup>3</sup>	Systems include optimum start controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C403.2.4.2.3 [FI41] <sup>3</sup>	Systems include optimum start controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C403.2.4.2.3 [FI41] <sup>3</sup>	Systems include optimum start controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C403.2.4.2.3 [FI41] <sup>3</sup>	Systems include optimum start controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	Requirement will be met.  <b>Location on plans/spec:</b> RE: Control Diagrams on M4.0 Series Mechanical Diagrams
C408.2.1 [FI28] <sup>1</sup>	Commissioning plan developed by registered design professional or approved agency.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C408.2.3.1 [FI31] <sup>1</sup>	HVAC equipment has been tested to ensure proper operation.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C408.2.3.2 [FI10] <sup>1</sup>	HVAC control systems have been tested to ensure proper operation, calibration and adjustment of controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Section # & Req.ID	Final Inspection	Complies?	Comments/Assumptions
C408.2.3.3 [FI32] <sup>1</sup>	Economizers have been tested to ensure proper operation.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C408.2.4 [FI29] <sup>1</sup>	Preliminary commissioning report completed and certified by registered design professional or approved agency.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C408.2.5.1 [FI7] <sup>3</sup>	Furnished HVAC as built drawings submitted within 90 days of system acceptance.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C408.2.5.3 [FI43] <sup>1</sup>	An air and/or hydronic system balancing report is provided for HVAC systems.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C408.2.5.4 [FI30] <sup>1</sup>	Final commissioning report due to building owner within 90 days of receipt of certificate of occupancy.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

RCRBD Record Set

T.A.

05/14/2020

**Additional Comments/Assumptions:**

1	High Impact (Tier 1)	2	Medium Impact (Tier 2)	3	Low Impact (Tier 3)
---	----------------------	---	------------------------	---	---------------------

Project Title:

Data filename: S:\BGProjects\10182.00 SSSD Strawberry Park Elementary School\Engineering Software Files\Energy\Calcs\10182.00 - COMcheck.cck

Report date: 04/04/20


Page 19 of 20

**RCRBD Record Set  
T.A.**

**05/14/2020**

## Structural Engineering Calculations

# Strawberry Park Elementary Steamboat Springs, CO



**RCRBD Record Set  
T.A.**

**05/14/2020**

---

**SUPPORTING YOUR VISION**

---

**JIRSA | HEDRICK**  
Structural Engineers

Prepared For: TAB Associates

Date: April 6, 2020



**Table of Contents**

**Strawberry Park**

Calculation Index

<u>Item</u>	<u>Pages</u>
Design Loads.....	1 – 8
Gravity Framing.....	1 – 46
Lateral Analysis.....	1 – 69
Miscellaneous.....	1 – 5

# Design Loads



PROJECT NO. 20191103 SHEET \_\_\_\_\_ OF \_\_\_\_\_  
 PROJECT Steamboat Schools BY VSW  
 SUBJECT Design Loads - SP DATE 4/6/2020

**Design Code:** 2015 IBC w/ Routt County Amendments

## Design Loads - Gravity

### Roof

#### Dead Load

Roofing	3 psf	*
Insulation	2 psf	*
Metal Deck	3 psf	
Joists	3 psf	*
Beams	2 psf	
MEP/Sprinklers	5 psf	*
Miscellaneous	7 psf	*
Total =	<b>25 psf</b>	<b>20 psf SDL*</b>

#### Mechanical Area (as req'd)

Mechanical Equipment	40 psf
6" concrete	75 psf
Roof DL	25 psf
Total =	<b>140 psf</b> <b>135 psf SDL</b>

#### Snow Load

Uniform roof snow	<b>65 psf</b> (plus drift)
Ground snow	<b>90 psf</b>


## Design Loads - Lateral

### Wind Loads

Occupancy Category	III
Wind Speed	120 mph (ASCE 7-10)
Exposure	C

### Seismic Loads

$I_E = 1.25$
Seismic Design Category B
Site Class D
$T_L = 4 \text{ sec}$
$S_S = 0.27$
$S_1 = 0.074$
$S_{MS} = 0.428$
$S_{M1} = 0.178$
$S_{DS} = 0.285$
$S_{D1} = 0.119$

 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project <b>Steamboat Schools</b>				Job Ref. <b>20191103</b>	
	Section <b>Strawberry Park Snow Drift</b>				Sheet no./rev. <b>1</b>	
	Calc. by <b>VSW</b>	Date <b>3/11/2020</b>	Chk'd by	Date	App'd by	Date

## **SNOW LOADING**

**In accordance with ASCE7-10**

Tedds calculation version 1.0.09

### **Building details**


Roof type **Flat**  
Width of roof **b = 46.00 ft**


### **Ground snow load**


Ground snow load (Figure 7-1)  **$p_g = 94.00 \text{ lb/ft}^2$**   
Density of snow  **$\gamma = \min(0.13 \times p_g / 1 \text{ ft} + 14 \text{ lb/ft}^3, 30 \text{ lb/ft}^3) = 26.22 \text{ lb/ft}^3$**   
Terrain type **Sect. 26.7**  
Exposure condition (Table 7-2) **C**  
Exposure factor (Table 7-2)  **$C_e = 0.90$**   
Thermal condition (Table 7-3) **Fully exposed**  
Thermal factor (Table 7-3)  **$C_t = 1.10$**   
Importance category (Table 1.5-1) **III**  
Importance factor (Table 1.5-2)  **$I_s = 1.10$**   
Min snow load for low slope roofs (Sect 7.3.4)  **$p_{f\_min} = I_s \times 20 \text{ lb/ft}^2 = 22.00 \text{ lb/ft}^2$**   
Flat roof snow load (Sect 7.3)  **$p_f = 0.7 \times C_e \times C_t \times I_s \times p_g = 71.66 \text{ lb/ft}^2$**

### **Left parapet**

Balanced snow load height  **$h_b = p_f / \gamma = 2.73 \text{ ft}$**   
Height of left parapet  **$h_{pptL} = 10.00 \text{ ft}$**   
Height from balance load to top of left parapet  **$h_{c\_pptL} = h_{pptL} - h_b = 7.27 \text{ ft}$**   
Length of roof - left parapet  **$l_{u\_pptL} = b = 46.00 \text{ ft}$**   
Drift height windward drift - left parapet  **$h_{d\_l\_pptL} = 0.75 \times (0.43 \times (\max(20 \text{ ft}, l_{u\_pptL}) \times 1 \text{ ft}^2)^{1/3} \times (p_g / 1 \text{ lb/ft}^2 + 10)^{1/4} - 1.5 \text{ ft}) = 2.57 \text{ ft}$**   
Drift height - left parapet  **$h_{d\_pptL} = \min(h_{d\_l\_pptL}, h_{pptL} - h_b) = 2.57 \text{ ft}$**   
Drift width  **$W_{d\_pptL} = \min(4 \times h_{d\_l\_pptL}, 8 \times (h_{pptL} - h_b), b) = 10.26 \text{ ft}$**   
Drift surcharge load - left parapet  **$p_{d\_pptL} = h_{d\_pptL} \times \gamma = 67.26 \text{ lb/ft}^2$**

 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project <b>Steamboat Schools</b>				Job Ref. <b>20191103</b>	
	Section <b>Strawberry Park Snow Drift</b>				Sheet no./rev. <b>2</b>	
	Calc. by <b>VSW</b>	Date <b>3/11/2020</b>	Chk'd by	Date	App'd by	Date



 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project <b>Steamboat Schools</b>				Job Ref. <b>20191103</b>	
	Section <b>Strawberry Park Snow Drift</b>				Sheet no./rev. <b>1</b>	
	Calc. by <b>VSW</b>	Date <b>3/11/2020</b>	Chk'd by	Date	App'd by	Date

## **SNOW LOADING**

**In accordance with ASCE7-10**

Tedds calculation version 1.0.09

### **Building details**

Roof type Flat  
Width of roof b = **46.00** ft


### **Ground snow load**

Ground snow load (Figure 7-1)  $p_g = \mathbf{94.00}$  lb/ft<sup>2</sup>  
Density of snow  $\gamma = \min(0.13 \times p_g / 1\text{ft} + 14\text{lb/ft}^3, 30\text{lb/ft}^3) = \mathbf{26.22}$  lb/ft<sup>3</sup>  
Terrain type Sect. 26.7 C  
Exposure condition (Table 7-2) Fully exposed  
Exposure factor (Table 7-2)  $C_e = \mathbf{0.90}$   
Thermal condition (Table 7-3) Unheated structures  
Thermal factor (Table 7-3)  $C_t = \mathbf{1.20}$   
Importance category (Table 1.5-1) III  
Importance factor (Table 1.5-2)  $I_s = \mathbf{1.10}$   
Min snow load for low slope roofs (Sect 7.3.4)  $p_{f\_min} = I_s \times 20 \text{ lb/ft}^2 = \mathbf{22.00}$  lb/ft<sup>2</sup>  
Flat roof snow load (Sect 7.3)  $p_r = 0.7 \times C_e \times C_t \times I_s \times p_g = \mathbf{78.17}$  lb/ft<sup>2</sup>

Balanced load



78.2 psf



Roof elevation

Search Information

**Address:** 39620 Amethyst Dr, Steamboat Springs, CO 80487, USA

**Coordinates:** 40.5009297, -106.8213135

**Elevation:** 6878 ft

**Timestamp:** 2020-03-19T21:25:26.261Z

**Hazard Type:** Seismic


**Reference Document:** ASCE7-10

**Risk Category:** III


**Site Class:** D



MCE<sub>R</sub> Horizontal Response Spectrum



Design Horizontal Response Spectrum



Basic Parameters

Name	Value	Description
S <sub>S</sub>	0.27	MCE <sub>R</sub> ground motion (period=0.2s)
S <sub>1</sub>	0.074	MCE <sub>R</sub> ground motion (period=1.0s)
S <sub>MS</sub>	0.428	Site-modified spectral acceleration value
S <sub>M1</sub>	0.178	Site-modified spectral acceleration value
S <sub>DS</sub>	0.285	Numeric seismic design value at 0.2s SA
S <sub>D1</sub>	0.119	Numeric seismic design value at 1.0s SA

Additional Information

Name	Value	Description
SDC	B	Seismic design category
F <sub>a</sub>	1.584	Site amplification factor at 0.2s
F <sub>v</sub>	2.4	Site amplification factor at 1.0s

$CR_S$	0.901	Coefficient of risk (0.2s)
$CR_1$	0.9	Coefficient of risk (1.0s)
PGA	0.15	$MCE_G$ peak ground acceleration
$F_{PGA}$	1.499	Site amplification factor at PGA
$PGA_M$	0.225	Site modified peak ground acceleration
$T_L$	4	Long-period transition period (s)
SsRT	0.27	Probabilistic risk-targeted ground motion (0.2s)
SsUH	0.3	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)
SsD	1.5	Factored deterministic acceleration value (0.2s)
S1RT	0.074	Probabilistic risk-targeted ground motion (1.0s)
S1UH	0.083	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)
S1D	0.6	Factored deterministic acceleration value (1.0s)
PGAd	0.5	Factored deterministic acceleration value (PGA)


*The results indicated here DO NOT reflect any state or local amendments to the values or any delineation lines made during the building code adoption process. Users should confirm any output obtained from this tool with the local Authority Having Jurisdiction before proceeding with design.*

## Disclaimer

Hazard loads are provided by the U.S. Geological Survey [Seismic Design Web Services](#).

While the information presented on this website is believed to be correct, ATC and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in the report should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. ATC does not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the report provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the building site described by latitude/longitude location in the report.



 Jirsa Hedrick Structural Engineers 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project Steamboat Springs				Job Ref. 20191103	
	Section Strawberry Park Seismic Loads				Sheet no./rev. 1	
	Calc. by VSW	Date 1/21/2020	Chk'd by	Date	App'd by	Date

## SEISMIC FORCES (ASCE 7-10)

Tedds calculation version 3.1.00

### Site parameters

Site class	D
Mapped acceleration parameters (Section 11.4.1)	
at short period	$S_S = 0.27$
at 1 sec period	$S_1 = 0.074$
Site coefficient at short period (Table 11.4-1)	$F_a = 1.584$
at 1 sec period (Table 11.4-2)	$F_v = 2.400$

### Spectral response acceleration parameters

at short period (Eq. 11.4-1)	$S_{MS} = F_a \times S_S = 0.428$
at 1 sec period (Eq. 11.4-2)	$S_{M1} = F_v \times S_1 = 0.178$

### Design spectral acceleration parameters (Sect 11.4.4)

at short period (Eq. 11.4-3)	$S_{DS} = 2 / 3 \times S_{MS} = 0.285$
at 1 sec period (Eq. 11.4-4)	$S_{D1} = 2 / 3 \times S_{M1} = 0.118$

### Seismic design category

Risk category (Table 1.5-1)	II
-----------------------------	----

Seismic design category based on short period response acceleration (Table 11.6-1)

B

Seismic design category based on 1 sec period response acceleration (Table 11.6-2)

B

Seismic design category B

### Approximate fundamental period

Height above base to highest level of building	$h_n = 18$ ft
--	---------------


From Table 12.8-2:

Structure type	All other systems
Building period parameter $C_t$	$C_t = 0.02$
Building period parameter $x$	$x = 0.75$

Approximate fundamental period (Eq 12.8-7)	$T_a = C_t \times (h_n)^x \times 1 \text{ sec} / (1 \text{ ft})^x = 0.175$ sec
Building fundamental period (Sect 12.8.2)	$T = T_a = 0.175$ sec
Long-period transition period	$T_L = 4$ sec

### Seismic response coefficient

Seismic force-resisting system (Table 12.2-1)	A. Bearing_Wall_Systems 8. Intermediate reinforced masonry shear walls
Response modification factor (Table 12.2-1)	$R = 3.5$
Seismic importance factor (Table 1.5-2)	$I_e = 1.000$
Seismic response coefficient (Sect 12.8.1.1)	
Calculated (Eq 12.8-3)	$C_{s\_calc} = S_{DS} / (R / I_e) = 0.0815$
Maximum (Eq 12.8-3)	$C_{s\_max} = S_{D1} / ((T / 1 \text{ sec}) \times (R / I_e)) = 0.1936$
Minimum (Eq 12.8-5)	$C_{s\_min} = \max(0.044 \times S_{DS} \times I_e, 0.01) = 0.0125$

 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project <b>Steamboat Springs</b>				Job Ref. <b>20191103</b>	
	Section <b>Strawberry Park Seismic Loads</b>				Sheet no./rev. <b>2</b>	
	Calc. by <b>VSW</b>	Date <b>1/21/2020</b>	Chk'd by	Date	App'd by	Date

Seismic response coefficient

$$C_s = \mathbf{0.0815}$$

**Seismic base shear (Sect 12.8.1)**

Effective seismic weight of the structure

$$W = \mathbf{1029.0 \text{ kips}}$$

Seismic response coefficient

$$C_s = \mathbf{0.0815}$$

Seismic base shear (Eq 12.8-1)

$$V = C_s \times W = \mathbf{83.8 \text{ kips}}$$


# Gravity Framing



# Floor Map

Floor Type: Roof

Beam Designs













Surface Loads		Label	DL	CDL	LL Reduction	PLL	CLL	Mass DL
		Dead	psf 20.0	psf 0.0	psf Type 0.0 Reducible	psf 0.0	psf 0.0	psf 20.0
		RTU + Dead	54.0	0.0	0.0 Reducible	0.0	0.0	54.0





Snow Loads

	<b>Label</b>	<b>Type</b>	<b>Magnitude 1</b> psf	<b>Magnitude 2</b> psf	<b>Magnitude 3</b> psf
	Snow	Constant	72.000	---	---
	Snow Drift 1	Drift	150.000	150.000	72.000
	Snow Drift 1	Drift	150.000	150.000	72.000
	Snow Drift 1	Drift	150.000	150.000	72.000
	Snow Drift 2	Drift	72.000	72.000	150.000
	Snow Drift 2	Drift	72.000	72.000	150.000
	Snow Drift 2	Drift	72.000	72.000	150.000



RAM Steel 17.00.01.09

DataBase: Strawberry Park - East Addition

Bentley Building Code: IBC

## Floor Map

04/03/20 10:38:33


Steel Code: AISC 360-16 LRFD

Floor Type: Roof

Beam Designs

SPANDREL GIRDER

INTERIOR GIRDER







RAM Structural System



RAM Steel 17.00.01.09

# Gravity Beam Design

INTERIOR GIRDER

DataBase: Strawberry Park - East Addition

04/03/20 10:38:33

Building Code: IBC

Steel Code: AISC 360-16 LRFD

**Floor Type: Roof****Beam Number = 10****SPAN INFORMATION (ft): I-End (21.33,54.00) J-End (21.33,32.00)**

Beam Size (Optimum) = W16X26 Fy = 50.0 ksi  
 Total Beam Length (ft) = 22.00  
 Mp (kip-ft) = 184.17

**POINT LOADS (kips):**

Dist	DL	RedLL	Red%	NonRLL	StorLL	Red%	RoofLL	Red%	PartL
3.750	0.82	0.00	0.0	0.00	0.00	0.0	2.56	Snow	0.00
7.500	0.94	0.00	0.0	0.00	0.00	0.0	2.94	Snow	0.00
12.333	1.06	0.00	0.0	0.00	0.00	0.0	3.31	Snow	0.00
17.167	1.06	0.00	0.0	0.00	0.00	0.0	3.31	Snow	0.00

**LINE LOADS (k/ft):**

Load	Dist	DL	LL	Red%	Type	PartL
1	0.000	0.007	0.000	---	NonR	0.000
	22.000	0.007	0.000			0.000
2	0.000	0.045	0.000	0.0%	Red	0.000
	22.000	0.045	0.000			0.000
3	0.000	0.000	0.161	---	Snow	0.000
	21.000	0.000	0.161			0.000
4	21.000	0.000	0.124	---	Snow	0.000
	21.333	0.000	0.112			0.000
5	21.000	0.000	0.037	---	Snow	0.000
	21.333	0.000	0.051			0.000
6	21.334	0.000	0.112	---	Snow	0.000
	21.666	0.000	0.098			0.000
7	21.334	0.000	0.051	---	Snow	0.000
	21.666	0.000	0.067			0.000
8	21.667	0.000	0.098	---	Snow	0.000
	22.000	0.000	0.082			0.000
9	21.667	0.000	0.067	---	Snow	0.000
	22.000	0.000	0.086			0.000
10	0.000	0.026	0.000	---	NonR	0.000
	22.000	0.026	0.000			0.000

**SHEAR (Ultimate): Max Vu (1.2DL+1.6LL) = 16.24 kips 0.90Vn = 105.97 kips****MOMENTS (Ultimate):**

Span	Cond	LoadCombo	Mu kip-ft	@ ft	Lb ft	Cb	Phi	Phi*Mn kip-ft
Center	Max +	1.2DL+1.6LL	101.8	12.3	0.0	1.00	0.90	165.75
Controlling		1.2DL+1.6LL	101.8	12.3	0.0	1.00	0.90	165.75

**REACTIONS (kips):**

	Left	Right
DL reaction	2.85	2.73
Max +LL reaction	8.01	7.65
Max +total reaction (factored)	16.24	15.51



RAM Structural System



## Gravity Beam Design

RAM Steel 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 2/2

04/03/20 10:38:33

Steel Code: AISC 360-16 LRFD

---

### DEFLECTIONS:

				Ratio
Dead load (in)	at 11.00 ft =	-0.174	L/D = 1516	
Live load (in)	at 11.00 ft =	-0.496	L/D = 533 > 360	0.68
Net Total load (in)	at 11.00 ft =	-0.670	L/D = 394	



RAM Structural System



RAM Steel 17.00.01.09

**Gravity Beam Design**

SPANDREL GIRDER

DataBase: Strawberry Park - East Addition

04/03/20 10:38:33

Building Code: IBC

Steel Code: AISC 360-16 LRFD

**Floor Type: Roof****Beam Number = 43****SPAN INFORMATION (ft): I-End (46.25,48.00) J-End (65.58,48.00)**

Beam Size (User Selected) = W18X35 Fy = 50.0 ksi

Total Beam Length (ft) = 19.33

Mp (kip-ft) = 277.08

**POINT LOADS (kips):**

Dist	DL	RedLL	Red%	NonRLL	StorLL	Red%	RoofLL	Red%	PartL
4.833	1.33	0.00	0.0	0.00	0.00	0.0	4.37	Snow	0.00
9.667	1.33	0.00	0.0	0.00	0.00	0.0	4.37	Snow	0.00
14.500	1.33	0.00	0.0	0.00	0.00	0.0	4.37	Snow	0.00

**LINE LOADS (k/ft):**

Load	Dist	DL	LL	Red%	Type	PartL
1	0.000	0.003	0.000	---	NonR	0.000
	19.333	0.003	0.000			0.000
2	0.000	0.020	0.000	0.0%	Red	0.000
	19.333	0.020	0.000			0.000
3	0.000	0.000	0.073	---	Snow	0.000
	19.333	0.000	0.073			0.000
4	0.000	0.035	0.000	---	NonR	0.000
	19.333	0.035	0.000			0.000

**SHEAR (Ultimate): Max Vu (1.2DL+1.6LL) = 14.68 kips 1.00Vn = 159.30 kips****MOMENTS (Ultimate):**

Span	Cond	LoadCombo	Mu kip-ft	@ ft	Lb ft	Cb	Phi	Phi*Mn kip-ft
Center	Max +	1.2DL+1.6LL	91.7	9.7	4.8	1.11	0.90	249.38
Controlling		1.2DL+1.6LL	91.7	9.7	4.8	1.11	0.90	249.38

**REACTIONS (kips):**

	Left	Right
DL reaction	2.56	2.56
Max +LL reaction	7.25	7.25
Max +total reaction (factored)	14.68	14.68

**DEFLECTIONS:**

				Ratio
Dead load (in)	at	9.67 ft = -0.068	L/D = 3407	
Live load (in)	at	9.67 ft = -0.198	L/D = 1173 > 360	0.31
Net Total load (in)	at	9.67 ft = -0.266	L/D = 872	



RAM Structural System



# Gravity Column Design Summary

RAM Steel 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

04/06/20 08:53:51

Steel Code: AISC360-16 LRFD

## Column Line I.2-11.7

Level	Pu	Mux	Muy	LC	Interaction Eq.	Angle	Fy	Size
Roof	24.7	9.2	0.0	1	0.68 Eq H1-1a	90.0	50	HSS4X4X5/16

## Column Line I.2-13

Level	Pu	Mux	Muy	LC	Interaction Eq.	Angle	Fy	Size
Roof	25.7	-6.4	1.3	12	0.62 Eq H1-1a	90.0	50	HSS4X4X5/16

## Column Line 2.33ft-46.50ft

Level	Pu	Mux	Muy	LC	Interaction Eq.	Angle	Fy	Size
Roof	18.7	-2.3	2.2	1	0.41 Eq H1-1a	90.0	50	HSS4X4X5/16

## Column Line I.2-14.9

Level	Pu	Mux	Muy	LC	Interaction Eq.	Angle	Fy	Size
Roof	7.7	-1.2	1.6	1	0.18 Eq H1-1b	90.0	50	HSS4X4X5/16

## Column Line 9.17ft-8.00ft

Level	Pu	Mux	Muy	LC	Interaction Eq.	Angle	Fy	Size
Penthouse	11.0	1.1	-3.0	1	0.24 Eq H1-1b	0.0	50	HSS4X4X5/16

## Column Line 9.17ft-24.00ft

Level	Pu	Mux	Muy	LC	Interaction Eq.	Angle	Fy	Size
Penthouse	11.0	1.1	3.0	1	0.24 Eq H1-1b	0.0	50	HSS4X4X5/16

## Column Line 16.92ft-11.60ft

Level	Pu	Mux	Muy	LC	Interaction Eq.	Angle	Fy	Size
Roof	39.9	0.0	0.0	1	0.47 Eq Axial	0.0	46	HSS4X4X5/16

## Column Line 16.92ft-24.00ft

Level	Pu	Mux	Muy	LC	Interaction Eq.	Angle	Fy	Size
Roof	32.1	0.0	0.0	1	0.38 Eq Axial	0.0	46	HSS4X4X5/16

## Column Line 21.33ft-32.00ft

Level	Pu	Mux	Muy	LC	Interaction Eq.	Angle	Fy	Size
Roof	21.5	5.4	-1.7	8	0.55 Eq H1-1a	90.0	50	HSS4X4X5/16

## Column Line 21.33ft-54.00ft

Level	Pu	Mux	Muy	LC	Interaction Eq.	Angle	Fy	Size
Roof	34.1	-6.8	6.3	6	0.57 Eq H1-1a	90.0	50	HSS5X5X5/16

## Column Line M-14.9

Level	Pu	Mux	Muy	LC	Interaction Eq.	Angle	Fy	Size
-------	----	-----	-----	----	-----------------	-------	----	------



RAM Structural System



# Gravity Column Design Summary

RAM Steel 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 2/2

04/06/20 08:53:51

Steel Code: AISC360-16 LRFD

Roof	18.1	-6.1	0.5	1	0.49	Eq H1-1a	0.0	50	HSS4X4X5/16
------	------	------	-----	---	------	----------	-----	----	-------------

## Column Line N-14.3

Level	Pu	Mux	Muy	LC	Interaction Eq.	Angle	Fy	Size
Roof	25.7	-4.5	3.0	12	0.62 Eq H1-1a	0.0	50	HSS4X4X5/16



RAM Structural System



## Base Plate Design Summary

RAM Steel 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

04/06/20 08:54:38

Steel Code: AISC360-16 LRFD

### BASE PLATES:

Design Code: AISC360-16 LRFD

Plate Fy (ksi) \_\_\_\_\_ 36.000

Minimum Dimension From Face of Column to Edge of Plate (in) \_\_\_\_\_ 1.000

Minimum Dimension From Side of Column to Edge of Plate (in) \_\_\_\_\_ 1.000

Increment of Plate Dimensions (in) \_\_\_\_\_ 0.500

Increment of Plate Thickness (in) \_\_\_\_\_ 0.250

Minimum Footing Dimension Parallel to Web (ft) \_\_\_\_\_ 10.00

Minimum Footing Dimension Perpendicular to Web (ft) \_\_\_\_\_ 10.00

Keep Base Plate Square: \_\_\_\_\_ Y

Column Line	Column Size	Fy (ksi)	N (in)	B (in)	tp (in)
I.2-11.7	HSS4X4X5/16	36	6.00	6.00	0.250
I.2-13	HSS4X4X5/16	36	6.00	6.00	0.500
2.33ft-46.50ft	HSS4X4X5/16	36	6.00	6.00	0.250
I.2-14.9	HSS4X4X5/16	36	6.00	6.00	0.250
16.92ft-11.60ft	HSS4X4X5/16	36	6.00	6.00	0.500
16.92ft-24.00ft	HSS4X4X5/16	36	6.00	6.00	0.500
21.33ft-32.00ft	HSS4X4X5/16	36	6.00	6.00	0.250
21.33ft-54.00ft	HSS5X5X5/16	36	7.00	7.00	0.250
M-14.9	HSS4X4X5/16	36	6.00	6.00	0.250
N-14.3	HSS4X4X5/16	36	6.00	6.00	0.500



# Spread Footing Design Summary

RAM Foundation v17.00.01.09

DataBase: Strawberry Park - East Addition


Building Code: IBC

Date: 04/06/20 09:21:32

Design Code: ACI318-14

Grid	Orientation Col/Foot	Dimensions (ft)		f'c/fy ksi	Bottom Reinforcement		Top Reinforcement	
		Length	Width		Parallel to Length	Parallel to Width	Parallel to Length	Parallel to Width
(I.2 - 11.7)	90.00/90.00	3.50	3.50	4.00/60.00	5-#5	5-#5	5-#5	5-#5
(I.2 - 13)	90.00/90.00	3.50	3.50	4.00/60.00	5-#5	5-#5	None	None
(2.33 - 46.50)	90.00/90.00	3.50	3.50	4.00/60.00	5-#5	5-#5	None	None
(I.2 - 14.9)	90.00/90.00	3.50	3.50	4.00/60.00	5-#5	5-#5	None	None
(21.33 - 54.00)	90.00/90.00	3.50	3.50	4.00/60.00	5-#5	5-#5	None	None
(21.33 - 32.00)	90.00/90.00	3.50	3.50	4.00/60.00	5-#5	5-#5	None	None
(M - 14.9)	0.00/ 0.00	3.50	3.50	4.00/60.00	5-#5	5-#5	None	None
(N - 14.3)	0.00/ 0.00	3.50	3.50	4.00/60.00	5-#5	5-#5	None	None
(16.92 - 11.60)	0.00/ 0.00	3.50	3.50	4.00/60.00	5-#5	5-#5	None	None
(16.92 - 24.00)	0.00/ 0.00	3.50	3.50	4.00/60.00	5-#5	5-#5	None	None

Note: Number between () in reinforcement is quantity of bars in center strip of rectangular footing

 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project			Job Ref.		
	Steamboat Schools			20191103		
	Section			Sheet no./rev.		
	SP - Footings on Grid K			1		
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

## FOOTING AT I.2/11.5


### FOUNDATION ANALYSIS & DESIGN (ACI318)

In accordance with ACI318-14

Tedds calculation version 3.2.09

### FOOTING ANALYSIS

Length of foundation	$L_x = 4.5$ ft	Width of foundation	$L_y = 4.5$ ft
Foundation area	$A = 20.25$ ft <sup>2</sup>	Depth of foundation	$h = 12$ in
Depth of soil over foundation	$h_{\text{soil}} = 42$ in	Density of concrete	$\gamma_{\text{conc}} = 150.0$ lb/ft <sup>3</sup>




### Column no.1 details

Length of column	$l_{x1} = 10.00$ in	Width of column	$l_{y1} = 10.00$ in
position in x-axis	$x_1 = 27.00$ in	position in y-axis	$y_1 = 9.00$ in

### Soil properties

Net allow. bearing press.	$q_{\text{allow\_Net}} = 3$ ksf	Density of soil	$\gamma_{\text{soil}} = 120.0$ lb/ft <sup>3</sup>
Angle of internal friction	$\phi_b = 30.0$ deg	Design base friction angle	$\delta_{bb} = 30.0$ deg
Coefficient of base friction	$\tan(\delta_{bb}) = 0.577$		
Self weight	$F_{\text{swt}} = 150$ psf	Soil weight	$F_{\text{soil}} = 420$ psf



 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project			Job Ref.		
	Steamboat Schools			20191103		
	Section			Sheet no./rev.		
	SP - Footings on Grid K			2		
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

#### Column no.1 loads

Dead load in z  $F_{Dz1} = 3.7$  kips

Snow load in z  $F_{Sz1} = 12.7$  kips

#### Footing analysis for soil and stability

##### Load combinations per ASCE 7-10

1.0D (0.318)

1.0D + 1.0L (0.318)

1.0D + 1.0S (0.853)

##### Combination 4 results: 1.0D + 1.0S

#### Forces on foundation

Force in z-axis  $F_{dz} = 27.9$  kips

#### Moments on foundation

Moment in x-axis, about x is 0  $M_{dx} = 62.8$  kip\_ft

Moment in y-axis, about y is 0  $M_{dy} = 38.3$  kip\_ft

#### Uplift verification

Vertical force  $F_{dz} = 27.933$  kips

**PASS - Foundation is not subject to uplift**

#### Bearing resistance

##### Eccentricity of base reaction

Eccentricity in x-axis  $e_{dx} = 0$  in

Eccentricity in y-axis  $e_{dy} = -10.562$  in

Length of bearing, y-axis  $L'_{yd} = 49.314$  in

##### Pad base pressures

Min. base press.  $q_{min} = 0$  ksf

Max. base press.  $q_{max} = 3.021$  ksf

##### Allowable bearing capacity

Allowable bearing capacity  $q_{allow} = 3.54$  ksf  
0.853

$q_{max} / q_{allow} =$

**PASS - Allowable bearing capacity exceeds design base pressure**

#### FOOTING DESIGN (ACI318)

##### In accordance with ACI318-14

##### Material details

Compr. strength of concrete  $f'_c = 4000$  psi

Yield strength of reinforcement  $f_y = 60000$  psi

Cover to reinforcement  $c_{nom} = 3$  in

Concrete type Normal weight

Concrete modification factor  $\lambda = 1.00$


Column type Concrete

##### Analysis and design of concrete footing

##### Load combinations per ASCE 7-10

1.4D (0.049)

1.2D + 1.0L + 1.6S (0.250)

 Jirsa Hedrick Structural Engineers 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project			Job Ref.		
	Steamboat Schools			20191103		
	Section			Sheet no./rev.		
	SP - Footings on Grid K			3		
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

### Combination 6 results: 1.2D + 1.0L + 1.6S

#### Forces on foundation

Ultimate force in z-axis  $F_{uz} = 38.6$  kips

#### Moments on foundation

Ultimate moment in x-axis, about x is 0  $M_{ux} = 86.8$  kip\_ft Ultimate

moment in y-axis, about y is 0  $M_{uy} = 49.7$  kip\_ft

#### Eccentricity of base reaction


Eccentricity in x-axis  $e_{ux} = 0$  in Eccentricity in y-axis  $e_{uy} = -11.537$  in

Length of bearing, y-axis  $L'_{yu} = 46.388$  in


#### Pad base pressures

Min. ultimate base press.  $q_{umin} = 0$  ksf Max. ultimate base press.  $q_{umax} = 4.436$  ksf

Shear diagram, x axis (kips)



Moment diagram, x axis (kip\_ft)



#### Moment design, x direction, positive moment

Ultimate bending moment  $M_{u,x,max} = 9.235$  kip\_ft Tension reinf. provided 5 No.5 bot. bars  
(11.8 in c/c)

Area of tension reinf. provided  $A_{sx,bot,prov} = 1.55$  in<sup>2</sup> Min. area of reinforcement  $A_{s,min} = 1.166$  in<sup>2</sup>

**PASS - Area of reinforcement provided exceeds minimum**

Maximum spacing of reinf.  $s_{max} = 18$  in

**PASS - Maximum permissible reinforcement spacing exceeds actual spacing**

Depth to tension reinf.  $d = 8.688$  in Depth of compression block  $a = 0.507$  in

Neutral axis factor  $\beta_1 = 0.85$  Depth to neutral axis  $c = 0.596$  in

Strain in tensile reinf.  $\epsilon_t = 0.04073$


**PASS - Tensile strain exceeds minimum required, 0.004**

Nominal moment capacity  $M_n = 65.365$  kip\_ft Flexural strength red. factor  $\phi_f = 0.900$

Design moment capacity  $\phi M_n = 58.829$  kip\_ft  $M_{u,x,max} / \phi M_n =$

**0.157**

**PASS - Design moment capacity exceeds ultimate moment load**


 Jirsa Hedrick Structural Engineers 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project			Job Ref.		
	Steamboat Schools			20191103		
	Section			Sheet no./rev.		
	SP - Footings on Grid K			4		
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

### One-way shear design, x direction


Ultimate shear force	$V_{u,x} = 6.382$ kips	Depth to reinforcement	$d_v = 8.062$ in
Shear strength red. factor	$\phi_v = 0.75$	Nominal shear capacity	$V_n = 55.071$ kips
Design shear capacity	$\phi V_n = 41.303$ kips	$V_{u,x} / \phi V_n = 0.155$	

**PASS - Design shear capacity exceeds ultimate shear load**

### Shear diagram, y axis (kips)



### Moment diagram, y axis (kip\_ft)



### Moment design, y direction, positive moment

Ultimate bending moment	$M_{u,y,max} = 0.906$ kip_ft	Tension reinf. provided	5 No.5 bot. bars
(11.8 in c/c)			
Area of tension reinf. provided	$A_{s,bot,prov} = 1.55$ in <sup>2</sup>	Min. area of reinforcement	$A_{s,min} = 1.166$ in <sup>2</sup>

**PASS - Area of reinforcement provided exceeds minimum**

Maximum spacing of reinf.	$s_{max} = 18$ in
---------------------------	-------------------

**PASS - Maximum permissible reinforcement spacing exceeds actual spacing**

Depth to tension reinf.	$d = 8.062$ in	Depth of compression block	$a = 0.507$ in
Neutral axis factor	$\beta_1 = 0.85$	Depth to neutral axis	$c = 0.596$ in
Strain in tensile reinf.	$\epsilon_t = 0.03759$		

**PASS - Tensile strain exceeds minimum required, 0.004**

Nominal moment capacity	$M_n = 60.522$ kip_ft	Flexural strength red. factor	$\phi_f = 0.900$
Design moment capacity	$\phi M_n = 54.469$ kip_ft	$M_{u,y,max} / \phi M_n =$	
	0.017		

**PASS - Design moment capacity exceeds ultimate moment load**

### Moment design, y direction, negative moment


Ultimate bending moment	$M_{u,y,min} = -4.165$ kip_ft	Tension reinf. provided	5 No.5 top bars
(11.8 in c/c)			
Area of tension reinf. provided	$A_{s,top,prov} = 1.55$ in <sup>2</sup>	Min. area of reinforcement	$A_{s,min} = 1.166$ in <sup>2</sup>

**PASS - Area of reinforcement provided exceeds minimum**

Maximum spacing of reinf.	$s_{max} = 18$ in
---------------------------	-------------------

**PASS - Maximum permissible reinforcement spacing exceeds actual spacing**

Depth to tension reinf.	$d = 8.688$ in	Depth of compression block	$a = 0.507$ in
-------------------------	----------------	----------------------------	----------------

 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project				Job Ref.	
	Steamboat Schools				20191103	
	Section				Sheet no./rev.	
	SP - Footings on Grid K				5	
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

Neutral axis factor  $\beta_1 = 0.85$  Depth to neutral axis  $c = 0.596$  in

Strain in tensile reinf.  $\epsilon_t = 0.04073$

**PASS - Tensile strain exceeds minimum required, 0.004**

Nominal moment capacity  $M_n = 65.365$  kip\_ft Flexural strength red. factor  $\phi_f = 0.900$

Design moment capacity  $\phi M_n = 58.829$  kip\_ft  $\text{abs}(M_{u,y,\min}) /$

$\phi M_n = 0.071$

**PASS - Design moment capacity exceeds ultimate moment load**

#### One-way shear design, y direction

Ultimate shear force  $V_{u,y} = 2.87$  kips Depth to reinforcement  $d_v = 8.688$  in

Shear strength red. factor  $\phi_v = 0.75$  Nominal shear capacity  $V_n = 59.34$  kips

Design shear capacity  $\phi V_n = 44.505$  kips  $V_{u,y} / \phi V_n = 0.064$

**PASS - Design shear capacity exceeds ultimate shear load**

#### Two-way shear design at column 1

Depth to reinforcement  $d_{v2} = 8.375$  in Shear perimeter length  $l_{xp} = 18.375$  in

Shear perimeter width  $l_{yp} = 18.188$  in Shear perimeter  $b_o = 54.750$  in

Shear area  $A_p = 334.195$  in<sup>2</sup> Surcharge loaded area  $A_{sur} = 234.195$  in<sup>2</sup>

Ult. bearing press.  $q_{up,avg} = 1.827$  ksf Ultimate shear load  $F_{up} = 21.725$  kips


Ult. shear stress, vertical load  $v_{ug} = 47.381$  psi Column geometry factor  $\beta = 1.00$


Column location factor  $\alpha_s = 30$  Concrete shear strength  $v_{cp} = 252.982$  psi

Shear strength red. factor  $\phi_v = 0.75$  Nominal shear stress capacity  $v_n = 252.982$  psi

Design shear stress capacity  $\phi v_n = 189.737$  psi  $v_{ug} / \phi v_n = 0.250$

**PASS - Design shear stress capacity exceeds ultimate shear stress load**

 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project			Job Ref.		
	Steamboat Schools			20191103		
	Section			Sheet no./rev.		
	SP - Footings on Grid K			6		
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				



## **FOOTING AT N.5/12.6**

### **FOUNDATION ANALYSIS & DESIGN (ACI318)**

**In accordance with ACI318-14**

Tedds calculation version 3.2.09


#### **FOOTING ANALYSIS**

Length of foundation	$L_x = 4 \text{ ft}$	Width of foundation	$L_y = 4 \text{ ft}$
Foundation area	$A = 16 \text{ ft}^2$	Depth of foundation	$h = 12 \text{ in}$
Depth of soil over foundation	$h_{\text{soil}} = 42 \text{ in}$	Density of concrete	$\gamma_{\text{conc}} = 150.0$
lb/ft <sup>3</sup>			



Jirsa Hedrick Structural Engineers  
8490 E Crescent Pkwy Suite 250  
Greenwood Village, CO 80111

Project Steamboat Schools				Job Ref. 20191103	
Section SP - Footings on Grid K				Sheet no./rev. 7	
Calc. by VSW	Date 4/3/2020	Chk'd by	Date	App'd by	Date



#### Column no.1 details

Length of column	$l_{x1} = 10.00$ in	Width of column	$l_{y1} = 10.00$ in
position in x-axis	$x_1 = 24.00$ in	position in y-axis	$y_1 = 9.00$ in

#### Soil properties

Net allow. bearing press.	$q_{allow\_Net} = 3$ ksf	Density of soil	$\gamma_{soil} = 120.0$ lb/ft <sup>3</sup>
Angle of internal friction	$\phi_b = 30.0$ deg	Design base friction angle	$\delta_{bb} = 30.0$ deg
Coefficient of base friction	$\tan(\delta_{bb}) = 0.577$		
Self weight	$F_{swt} = 150$ psf	Soil weight	$F_{soil} = 420$ psf

#### Column no.1 loads

Dead load in z	$F_{Dz1} = 0.9$ kips	Snow load in z	$F_{Sz1} = 2.9$ kips
----------------	----------------------	----------------	----------------------

#### Footing analysis for soil and stability

##### Load combinations per ASCE 7-10

- 1.0D (0.204)
- 1.0D + 1.0L (0.204)
- 1.0D + 1.0S (0.349)


##### Combination 4 results: 1.0D + 1.0S

#### Forces on foundation

Force in z-axis	$F_{dz} = 12.8$ kips
-----------------	----------------------

#### Moments on foundation

Moment in x-axis, about x is 0	$M_{dx} = 25.7$ kip_ft	Moment in y-axis, about y is 0	$M_{dy} = 21.0$ kip_ft
--------------------------------	------------------------	--------------------------------	------------------------

 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project			Job Ref.		
	Steamboat Schools			20191103		
	Section			Sheet no./rev.		
	SP - Footings on Grid K			8		
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

### Uplift verification

Vertical force  $F_{dz} = 12.83$  kips

**PASS - Foundation is not subject to uplift**

### Bearing resistance

#### Eccentricity of base reaction

Eccentricity in x-axis  $e_{dx} = 0$  in      Eccentricity in y-axis  $e_{dy} = -4.337$  in

#### Pad base pressures

Min. base press.  $q_{min} = 0.367$  ksf      Max. base press.  $q_{max} = 1.237$  ksf

#### Allowable bearing capacity

Allowable bearing capacity  $q_{allow} = 3.54$  ksf       $q_{max} / q_{allow} = 0.349$

**PASS - Allowable bearing capacity exceeds design base pressure**

### FOOTING DESIGN (ACI318)

#### In accordance with ACI318-14

#### Material details

Compr. strength of concrete	$f'_c = 4000$ psi	Yield strength of reinforcement	$f_y = 60000$ psi
Cover to reinforcement	$c_{nom} = 3$ in	Concrete type	Normal weight
Concrete modification factor	$\lambda = 1.00$	Column type	Concrete

#### Analysis and design of concrete footing

#### Load combinations per ASCE 7-10

1.4D (0.008)  
1.2D + 1.0L + 1.6S (0.053)

#### Combination 6 results: 1.2D + 1.0L + 1.6S

#### Forces on foundation

Ultimate force in z-axis  $F_{uz} = 16.5$  kips

#### Moments on foundation

Ultimate moment in x-axis, about x is 0       $M_{ux} = 33.1$  kip\_ft      Ultimate  
moment in y-axis, about y is 0       $M_{uy} = 26.1$  kip\_ft


#### Eccentricity of base reaction


Eccentricity in x-axis  $e_{ux} = 0$  in      Eccentricity in y-axis  $e_{uy} = -5.075$  in

#### Pad base pressures


Min. ultimate base press.  $q_{umin} = 0.378$  ksf      Max. ultimate base press.  $q_{umax} = 1.69$  ksf

#### Shear diagram, x axis (kips)



 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project			Job Ref.		
	Steamboat Schools			20191103		
	Section			Sheet no./rev.		
	SP - Footings on Grid K			9		
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

**Moment diagram, x axis (kip\_ft)**



**Moment design, x direction, positive moment**

Ultimate bending moment  $M_{u,x,max} = 1.754$  kip\_ft      Tension reinf. provided      4 No.5 bot. bars  
(13.7 in c/c)

Area of tension reinf. provided  $A_{s,bot,prov} = 1.24$  in<sup>2</sup>      Min. area of reinforcement       $A_{s,min} = 1.037$  in<sup>2</sup>

**PASS - Area of reinforcement provided exceeds minimum**

Maximum spacing of reinf.       $s_{max} = 18$  in

**PASS - Maximum permissible reinforcement spacing exceeds actual spacing**

Depth to tension reinf.       $d = 8.688$  in

Depth of compression block       $a = 0.456$  in

Neutral axis factor       $\beta_1 = 0.85$

Depth to neutral axis       $c = 0.536$  in

Strain in tensile reinf.       $\epsilon_t = 0.04559$

**PASS - Tensile strain exceeds minimum required, 0.004**

Nominal moment capacity       $M_n = 52.449$  kip\_ft

Flexural strength red. factor       $\phi_f = 0.900$

Design moment capacity       $\phi M_n = 47.204$  kip\_ft  
**0.037**

$M_{u,x,max} / \phi M_n =$

**PASS - Design moment capacity exceeds ultimate moment load**

**One-way shear design, x direction**

Ultimate shear force       $V_{u,x} = 1.275$  kips

Depth to reinforcement       $d_v = 8.062$  in

Shear strength red. factor       $\phi_v = 0.75$


Nominal shear capacity       $V_n = 48.952$  kips

Design shear capacity       $\phi V_n = 36.714$  kips


$V_{u,x} / \phi V_n = 0.035$

**PASS - Design shear capacity exceeds ultimate shear load**


**Shear diagram, y axis (kips)**



**Moment diagram, y axis (kip\_ft)**





 Jirsa Hedrick Structural Engineers 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project			Job Ref.		
	Steamboat Schools			20191103		
	Section			Sheet no./rev.		
	SP - Footings on Grid K			10		
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

#### Moment design, y direction, positive moment

Ultimate bending moment  $M_{u,y,max} = 0.215$  kip\_ft Tension reinf. provided 4 No.5 bot. bars  
(13.7 in c/c)

Area of tension reinf. provided  $A_{s,bot,prov} = 1.24$  in<sup>2</sup> Min. area of reinforcement  $A_{s,min} = 1.037$  in<sup>2</sup>

**PASS - Area of reinforcement provided exceeds minimum**

Maximum spacing of reinf.  $s_{max} = 18$  in

**PASS - Maximum permissible reinforcement spacing exceeds actual spacing**

Depth to tension reinf.  $d = 8.062$  in Depth of compression block  $a = 0.456$  in

Neutral axis factor  $\beta_1 = 0.85$  Depth to neutral axis  $c = 0.536$  in

Strain in tensile reinf.  $\epsilon_t = 0.04210$

**PASS - Tensile strain exceeds minimum required, 0.004**

Nominal moment capacity  $M_n = 48.574$  kip\_ft Flexural strength red. factor  $\phi_f = 0.900$

Design moment capacity  $\phi M_n = 43.717$  kip\_ft  $M_{u,y,max} / \phi M_n = 0.005$

**PASS - Design moment capacity exceeds ultimate moment load**

#### Moment design, y direction, negative moment

Ultimate bending moment  $M_{u,y,min} = -0.711$  kip\_ft Tension reinf. provided 4 No.5 top bars  
(13.7 in c/c)

Area of tension reinf. provided  $A_{s,top,prov} = 1.24$  in<sup>2</sup> Min. area of reinforcement  $A_{s,min} = 1.037$  in<sup>2</sup>

**PASS - Area of reinforcement provided exceeds minimum**

Maximum spacing of reinf.  $s_{max} = 18$  in

**PASS - Maximum permissible reinforcement spacing exceeds actual spacing**

Depth to tension reinf.  $d = 8.688$  in Depth of compression block  $a = 0.456$  in

Neutral axis factor  $\beta_1 = 0.85$  Depth to neutral axis  $c = 0.536$  in

Strain in tensile reinf.  $\epsilon_t = 0.04559$

**PASS - Tensile strain exceeds minimum required, 0.004**

Nominal moment capacity  $M_n = 52.449$  kip\_ft Flexural strength red. factor  $\phi_f = 0.900$

Design moment capacity  $\phi M_n = 47.204$  kip\_ft  $abs(M_{u,y,min}) / \phi M_n = 0.015$

**PASS - Design moment capacity exceeds ultimate moment load**

#### One-way shear design, y direction

Ultimate shear force  $V_{u,y} = 0.571$  kips Depth to reinforcement  $d_v = 8.688$  in

Shear strength red. factor  $\phi_v = 0.75$  Nominal shear capacity  $V_n = 52.747$  kips

Design shear capacity  $\phi V_n = 39.56$  kips  $V_{u,y} / \phi V_n = 0.014$

**PASS - Design shear capacity exceeds ultimate shear load**


#### Two-way shear design at column 1

Depth to reinforcement  $d_{v2} = 8.375$  in Shear perimeter length  $l_{xp} = 18.375$  in

Shear perimeter width  $l_{yp} = 18.188$  in Shear perimeter  $b_o = 54.750$  in

Shear area  $A_p = 334.195$  in<sup>2</sup> Surcharge loaded area  $A_{sur} = 234.195$  in<sup>2</sup>

Ult. bearing press.  $q_{up,avg} = 0.944$  ksf Ultimate shear load  $F_{up} = 4.642$  kips

 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project				Job Ref.	
	Steamboat Schools				20191103	
	Section				Sheet no./rev.	
	SP - Footings on Grid K				11	
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

Ult. shear stress, vertical load

$v_{ug} = 10.124$  psi

Column location factor

$\alpha_s = 30$

psi

Shear strength red. factor

$\phi_v = 0.75$

Design shear stress capacity

$\phi v_n = 189.737$  psi

Column geometry factor

$\beta = 1.00$

Concrete shear strength


$v_{cp} = 252.982$

Nominal shear stress capacity

$v_n = 252.982$  psi

$v_{ug} / \phi v_n = 0.053$

**PASS - Design shear stress capacity exceeds ultimate shear stress load**





Jirsa Hedrick Structural Engineers  
8490 E Crescent Pkwy Suite 250  
Greenwood Village, CO 80111

Project				Job Ref.	
Steamboat Schools				20191103	
Section				Sheet no./rev.	
Strawberry Park - Steel Framing				1	
Calc. by	Date	Chk'd by	Date	App'd by	Date
VSW	4/3/2020				


## STEEL BEAM - GRID 9.7-11.5

## STEEL FRAMING AT REMODEL ALONG GRID H

### STEEL BEAM ANALYSIS & DESIGN (AISC360-10)

In accordance with AISC360-10 using the LRFD method

Tedds calculation version 3.0.14



### Support conditions

Support A

Vertically restrained

Rotationally free

Support B

Vertically restrained

Rotationally free

### Applied loading

Beam loads

Dead self weight of beam  $\times 1$

DL - Dead full UDL 0.48 kips/ft

SL - Snow full UDL 1.2 kips/ft

### Load combinations

Load combination 1

Support A

Dead  $\times 1.20$

Live  $\times 1.60$

Roof live  $\times 1.60$

Project				Job Ref.	
Steamboat Schools				20191103	
Section				Sheet no./rev.	
Strawberry Park - Steel Framing				2	
Calc. by	Date	Chk'd by	Date	App'd by	Date
VSW	4/3/2020				

### Support B

Snow  $\times 1.60$   
Dead  $\times 1.20$   
Live  $\times 1.60$   
Roof live  $\times 1.60$   
Snow  $\times 1.60$   
Dead  $\times 1.20$   
Live  $\times 1.60$   
Roof live  $\times 1.60$   
Snow  $\times 1.60$

### Analysis results

Maximum moment

$M_{\max} = 216 \text{ kips\_ft}$

$M_{\min} = 0 \text{ kips\_ft}$

Maximum shear

$V_{\max} = 33.2 \text{ kips}$

$V_{\min} = -33.2 \text{ kips}$

Deflection

$\delta_{\max} = 0.8 \text{ in}$

$\delta_{\min} = 0 \text{ in}$

Maximum reaction at support A

$R_{A_{\max}} = 33.2 \text{ kips}$

$R_{A_{\min}} = 33.2 \text{ kips}$

Unfactored dead load reaction at support A

$R_{A_{\text{Dead}}} = 6.9 \text{ kips}$

Unfactored snow load reaction at support A

$R_{A_{\text{Snow}}} = 15.6 \text{ kips}$

Maximum reaction at support B

$R_{B_{\max}} = 33.2 \text{ kips}$

$R_{B_{\min}} = 33.2 \text{ kips}$

Unfactored dead load reaction at support B

$R_{B_{\text{Dead}}} = 6.9 \text{ kips}$

Unfactored snow load reaction at support B

$R_{B_{\text{Snow}}} = 15.6 \text{ kips}$

### Section details

Section type

**W 18x50 (AISC 15th Edn (v15.0))**

ASTM steel designation

**A992**

Steel yield stress


$F_y = 50 \text{ ksi}$

Steel tensile stress

$F_u = 65 \text{ ksi}$

Modulus of elasticity

$E = 29000 \text{ ksi}$



### Resistance factors

Resistance factor for tensile yielding


$\phi_{ty} = 0.90$

Resistance factor for tensile rupture

$\phi_{tr} = 0.75$

Resistance factor for compression

$\phi_c = 0.90$

 Jirsa Hedrick Structural Engineers 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project				Job Ref.	
	Steamboat Schools				20191103	
	Section				Sheet no./rev.	
	Strawberry Park - Steel Framing				3	
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

Resistance factor for flexure  $\phi_b = 0.90$

#### Lateral bracing

Span 1 has continuous lateral bracing

#### Classification of sections for local buckling - Section B4.1

##### Classification of flanges in flexure - Table B4.1b (case 10)

Width to thickness ratio  $b_f / (2 \times t_f) = 6.58$

Limiting ratio for compact section  $\lambda_{pff} = 0.38 \times \sqrt{E / F_y} = 9.15$

Limiting ratio for non-compact section  $\lambda_{rff} = 1.0 \times \sqrt{E / F_y} = 24.08$  Compact

##### Classification of web in flexure - Table B4.1b (case 15)

Width to thickness ratio  $(d - 2 \times k) / t_w = 45.23$

Limiting ratio for compact section  $\lambda_{pwf} = 3.76 \times \sqrt{E / F_y} = 90.55$

Limiting ratio for non-compact section  $\lambda_{rwf} = 5.70 \times \sqrt{E / F_y} = 137.27$  Compact

**Section is compact in flexure**

#### Design of members for shear - Chapter G

Required shear strength  $V_r = \max(\text{abs}(V_{\max}), \text{abs}(V_{\min})) = 33.228$  kips

Web area  $A_w = d \times t_w = 6.39$  in<sup>2</sup>

Web plate buckling coefficient  $k_v = 5$

Web shear coefficient - eq G2-3  $C_v = 1$

Nominal shear strength – eq G2-1  $V_n = 0.6 \times F_y \times A_w \times C_v = 191.700$  kips

Resistance factor for shear  $\phi_v = 1.00$

Design shear strength  $V_c = \phi_v \times V_n = 191.700$  kips

**PASS - Design shear strength exceeds required shear strength**

#### Design of members for flexure in the major axis - Chapter F

Required flexural strength  $M_r = \max(\text{abs}(M_{s1\_max}), \text{abs}(M_{s1\_min})) = 215.984$  kips\_ft

##### Yielding - Section F2.1

Nominal flexural strength for yielding - eq F2-1  $M_{nyld} = M_p = F_y \times Z_x = 420.833$  kips\_ft

Nominal flexural strength  $M_n = M_{nyld} = 420.833$  kips\_ft

Design flexural strength  $M_c = \phi_b \times M_n = 378.750$  kips\_ft

**PASS - Design flexural strength exceeds required flexural strength**

#### Design of members for vertical deflection

Consider deflection due to dead, live, roof live and snow loads

Limiting deflection  $\delta_{lim} = L_{s1} / 360 = 0.867$  in

Maximum deflection span 1  $\delta = \max(\text{abs}(\delta_{\max}), \text{abs}(\delta_{\min})) = 0.767$  in

**PASS - Maximum deflection does not exceed deflection limit**



Jirsa Hedrick Structural Engineers  
8490 E Crescent Pkwy Suite 250  
Greenwood Village, CO 80111


Project				Job Ref.	
Steamboat Schools				20191103	
Section				Sheet no./rev.	
Strawberry Park - Steel Framing				4	
Calc. by	Date	Chk'd by	Date	App'd by	Date
VSW	4/3/2020				

## STEEL BEAM - GRID 8 - 9.7

### STEEL BEAM ANALYSIS & DESIGN (AISC360-10)

In accordance with AISC360-10 using the LRFD method

Tedds calculation version 3.0.14



#### Support conditions

Support A	Vertically restrained
	Rotationally free
Support B	Vertically restrained
	Rotationally free

#### Applied loading

Beam loads	Dead self weight of beam $\times$ 1
	DL - Dead full UDL 0.48 kips/ft
	SL - Snow partial UDL 1.2 kips/ft from 120.00 in to 312.00 in
	Drift - Snow partial VDL 2 kips/ft at 0.00 in to 1.2 kips/ft at 120.00 in

#### Load combinations

Load combination 1	Support A	Dead $\times$ 1.20
--------------------	-----------	--------------------

Project				Job Ref.	
Steamboat Schools				20191103	
Section				Sheet no./rev.	
Strawberry Park - Steel Framing				5	
Calc. by	Date	Chk'd by	Date	App'd by	Date
VSW	4/3/2020				

### Support B

Live  $\times 1.60$   
Roof live  $\times 1.60$   
Snow  $\times 1.60$   
Dead  $\times 1.20$   
Live  $\times 1.60$   
Roof live  $\times 1.60$   
Snow  $\times 1.60$   
Dead  $\times 1.20$   
Live  $\times 1.60$   
Roof live  $\times 1.60$   
Snow  $\times 1.60$

### Analysis results

Maximum moment

$M_{max} = 226.8$  kips\_ft

$M_{min} = 0$  kips\_ft

Maximum shear

$V_{max} = 38.8$  kips

$V_{min} = -34$  kips

Deflection

$\delta_{max} = 0.8$  in

$\delta_{min} = 0$  in

Maximum reaction at support A

$R_{A_{max}} = 38.8$  kips

$R_{A_{min}} = 38.8$  kips

Unfactored dead load reaction at support A

$R_{A_{Dead}} = 6.9$  kips

Unfactored snow load reaction at support A

$R_{A_{Snow}} = 19.1$  kips

Maximum reaction at support B

$R_{B_{max}} = 34$  kips

$R_{B_{min}} = 34$  kips

Unfactored dead load reaction at support B

$R_{B_{Dead}} = 6.9$  kips

Unfactored snow load reaction at support B

$R_{B_{Snow}} = 16.1$  kips

### Section details

Section type

W 18x50 (AISC 15th Edn (v15.0))

ASTM steel designation

A992

Steel yield stress


$F_y = 50$  ksi

Steel tensile stress

$F_u = 65$  ksi

Modulus of elasticity


$E = 29000$  ksi



### Resistance factors

Resistance factor for tensile yielding

$\phi_{ty} = 0.90$

 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project				Job Ref.	
	Steamboat Schools				20191103	
	Section				Sheet no./rev.	
	Strawberry Park - Steel Framing				6	
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

Resistance factor for tensile rupture  $\phi_{tr} = \mathbf{0.75}$

Resistance factor for compression  $\phi_c = \mathbf{0.90}$

Resistance factor for flexure  $\phi_b = \mathbf{0.90}$

#### Lateral bracing

Span 1 has continuous lateral bracing

#### Classification of sections for local buckling - Section B4.1

##### Classification of flanges in flexure - Table B4.1b (case 10)

Width to thickness ratio  $b_f / (2 \times t_f) = \mathbf{6.58}$

Limiting ratio for compact section  $\lambda_{pff} = 0.38 \times \sqrt{E / F_y} = \mathbf{9.15}$

Limiting ratio for non-compact section  $\lambda_{rff} = 1.0 \times \sqrt{E / F_y} = \mathbf{24.08}$  Compact

##### Classification of web in flexure - Table B4.1b (case 15)

Width to thickness ratio  $(d - 2 \times k) / t_w = \mathbf{45.23}$

Limiting ratio for compact section  $\lambda_{pwf} = 3.76 \times \sqrt{E / F_y} = \mathbf{90.55}$

Limiting ratio for non-compact section  $\lambda_{rwf} = 5.70 \times \sqrt{E / F_y} = \mathbf{137.27}$  Compact

**Section is compact in flexure**

#### Design of members for shear - Chapter G

Required shear strength  $V_r = \max(\text{abs}(V_{\max}), \text{abs}(V_{\min})) = \mathbf{38.808}$  kips

Web area  $A_w = d \times t_w = \mathbf{6.39}$  in<sup>2</sup>

Web plate buckling coefficient  $k_v = \mathbf{5}$

Web shear coefficient - eq G2-3  $C_v = \mathbf{1}$

Nominal shear strength – eq G2-1  $V_n = 0.6 \times F_y \times A_w \times C_v = \mathbf{191.700}$  kips

Resistance factor for shear  $\phi_v = \mathbf{1.00}$

Design shear strength  $V_c = \phi_v \times V_n = \mathbf{191.700}$  kips

**PASS - Design shear strength exceeds required shear strength**

#### Design of members for flexure in the major axis - Chapter F

Required flexural strength  $M_r = \max(\text{abs}(M_{s1\_max}), \text{abs}(M_{s1\_min})) = \mathbf{226.782}$  kips\_ft

##### Yielding - Section F2.1

Nominal flexural strength for yielding - eq F2-1  $M_{nyld} = M_p = F_y \times Z_x = \mathbf{420.833}$  kips\_ft

Nominal flexural strength  $M_n = M_{nyld} = \mathbf{420.833}$  kips\_ft

Design flexural strength  $M_c = \phi_b \times M_n = \mathbf{378.750}$  kips\_ft

**PASS - Design flexural strength exceeds required flexural strength**

#### Design of members for vertical deflection

Consider deflection due to dead, live, roof live and snow loads

Limiting deflection  $\delta_{lim} = L_{s1} / 360 = \mathbf{0.867}$  in

Maximum deflection span 1  $\delta = \max(\text{abs}(\delta_{\max}), \text{abs}(\delta_{\min})) = \mathbf{0.806}$  in

**PASS - Maximum deflection does not exceed deflection limit**





Jirsa Hedrick Structural Engineers  
8490 E Crescent Pkwy Suite 250  
Greenwood Village, CO 80111


Project				Job Ref.	
Steamboat Schools				20191103	
Section				Sheet no./rev.	
Strawberry Park - Steel Framing				7	
Calc. by	Date	Chk'd by	Date	App'd by	Date
VSW	4/3/2020				

## STEEL BEAM - GRID G-I

### STEEL BEAM ANALYSIS & DESIGN (AISC360-10)

In accordance with AISC360-10 using the LRFD method

Tedds calculation version 3.0.14



#### **Support conditions**

Support A

Vertically restrained

Rotationally free

Support B

Vertically restrained

Rotationally free

#### **Applied loading**

Beam loads


Dead self weight of beam  $\times 1$

DL - Dead partial UDL 1.085 kips/ft from 0.00 in to 135.00 in

SL - Snow partial UDL 1.2 kips/ft from 0.00 in to 135.00 in

Pd - Dead point load 6.9 kips at 135.00 in

Ps - Snow point load 19.1 kips at 135.00 in

 Jirsa Hedrick Structural Engineers 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project				Job Ref.	
	Steamboat Schools				20191103	
	Section				Sheet no./rev.	
	Strawberry Park - Steel Framing				8	
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

DL - Dead partial UDL 0.83 kips/ft from 135.00 in to 216.00 in

SL - Snow partial UDL 0.12 kips/ft from 135.00 in to 216.00 in

#### Load combinations

Load combination 1

Support A

Dead  $\times$  1.20

Live  $\times$  1.60

Roof live  $\times$  1.60

Snow  $\times$  1.60

Dead  $\times$  1.20

Live  $\times$  1.60

Roof live  $\times$  1.60

Snow  $\times$  1.60

Support B

Dead  $\times$  1.20

Live  $\times$  1.60

Roof live  $\times$  1.60

Snow  $\times$  1.60

#### Analysis results

Maximum moment

$M_{\max} = 261.1$  kips<sub>ft</sub>

$M_{\min} = 0$  kips<sub>ft</sub>

Maximum shear

$V_{\max} = 41.9$  kips

$V_{\min} = -43$  kips

Deflection

$\delta_{\max} = 0.3$  in

$\delta_{\min} = 0$  in

Maximum reaction at support A

$R_{A_{\max}} = 41.9$  kips

$R_{A_{\min}} = 41.9$  kips

Unfactored dead load reaction at support A

$R_{A_{\text{Dead}}} = 12.8$  kips

Unfactored snow load reaction at support A

$R_{A_{\text{Snow}}} = 16.6$  kips

Maximum reaction at support B

$R_{B_{\max}} = 43$  kips

$R_{B_{\min}} = 43$  kips

Unfactored dead load reaction at support B

$R_{B_{\text{Dead}}} = 13.5$  kips

Unfactored snow load reaction at support B

$R_{B_{\text{Snow}}} = 16.8$  kips

#### Section details

Section type

**2 x MC 18x42.7 (AISC 15th Edn (v15.0))**

ASTM steel designation

**A992**

Steel yield stress

$F_y = 50$  ksi

Steel tensile stress

$F_u = 65$  ksi


Modulus of elasticity

$E = 29000$  ksi



Jirsa Hedrick Structural Engineers  
8490 E Crescent Pkwy Suite 250  
Greenwood Village, CO 80111

Project				Job Ref.	
Steamboat Schools				20191103	
Section				Sheet no./rev.	
Strawberry Park - Steel Framing				9	
Calc. by	Date	Chk'd by	Date	App'd by	Date
VSW	4/3/2020				



#### Resistance factors

Resistance factor for tensile yielding	$\phi_{ty} = 0.90$
Resistance factor for tensile rupture	$\phi_{tr} = 0.75$
Resistance factor for compression	$\phi_c = 0.90$
Resistance factor for flexure	$\phi_b = 0.90$

#### Lateral bracing

Span 1 has continuous lateral bracing

#### Classification of sections for local buckling - Section B4.1

##### Classification of flanges in flexure - Table B4.1b (case 10)

Width to thickness ratio	$b_f / t_f = 6.32$	
Limiting ratio for compact section	$\lambda_{pff} = 0.38 \times \sqrt{E / F_y} = 9.15$	
Limiting ratio for non-compact section	$\lambda_{rff} = 1.0 \times \sqrt{E / F_y} = 24.08$	Compact

##### Classification of web in flexure - Table B4.1b (case 15)


Width to thickness ratio	$(d - 2 \times k) / t_w = 33.60$	
Limiting ratio for compact section	$\lambda_{pwf} = 3.76 \times \sqrt{E / F_y} = 90.55$	
Limiting ratio for non-compact section	$\lambda_{rwf} = 5.70 \times \sqrt{E / F_y} = 137.27$	Compact

**Section is compact in flexure**

#### Design of members for shear - Chapter G

Required shear strength	$V_r = \max(\text{abs}(V_{\max}), \text{abs}(V_{\min})) = 43.044$ kips
Web area	$A_w = d \times t_w = 8.1$ in <sup>2</sup>
Web plate buckling coefficient	$k_v = 5$
Web shear coefficient - eq G2-3	$C_v = 1$
Nominal shear strength – eq G2-1	$V_n = 0.6 \times F_y \times N \times A_w \times C_v = 486.000$ kips
Resistance factor for shear	$\phi_v = 0.90$
Design shear strength	$V_c = \phi_v \times V_n = 437.400$ kips

**PASS - Design shear strength exceeds required shear strength**

 Jirsa Hedrick Structural Engineers 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project				Job Ref.	
	Steamboat Schools				20191103	
	Section				Sheet no./rev.	
	Strawberry Park - Steel Framing				10	
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

### Design of members for flexure in the major axis - Chapter F

Required flexural strength  $M_r = \max(\text{abs}(M_{s1\_max}), \text{abs}(M_{s1\_min})) = 261.138 \text{ kips\_ft}$

### Yielding - Section F2.1

Nominal flexural strength for yielding - eq F2-1  $M_{nyld} = M_p = F_y \times N \times Z_x = 625.833 \text{ kips\_ft}$

Nominal flexural strength  $M_n = M_{nyld} = 625.833 \text{ kips\_ft}$

Design flexural strength  $M_c = \phi_b \times M_n = 563.250 \text{ kips\_ft}$

**PASS - Design flexural strength exceeds required flexural strength**

### Design of members for vertical deflection

Consider deflection due to dead, live, roof live and snow loads

Limiting deflection  $\delta_{lim} = L_{s1} / 600 = 0.36 \text{ in}$

Maximum deflection span 1  $\delta = \max(\text{abs}(\delta_{max}), \text{abs}(\delta_{min})) = 0.3 \text{ in}$

**PASS - Maximum deflection does not exceed deflection limit**



Jirsa Hedrick Structural Engineers  
8490 E Crescent Pkwy Suite 250  
Greenwood Village, CO 80111


Project				Job Ref.	
Steamboat Schools				20191103	
Section				Sheet no./rev.	
Strawberry Park - Steel Framing				11	
Calc. by	Date	Chk'd by	Date	App'd by	Date
VSW	4/3/2020				

## STEEL BEAM - GRID 11.5

### STEEL BEAM ANALYSIS & DESIGN (AISC360-10)

In accordance with AISC360-10 using the LRFD method

Tedds calculation version 3.0.14



#### Support conditions

Support A

Vertically restrained

Rotationally free

Support B

Vertically restrained

Rotationally free

#### Applied loading

Beam loads

Dead self weight of beam  $\times 1$

DL - Dead full UDL 0.26 kips/ft

SL - Snow full UDL 1.17 kips/ft

Project				Job Ref.	
Steamboat Schools				20191103	
Section				Sheet no./rev.	
Strawberry Park - Steel Framing				12	
Calc. by	Date	Chk'd by	Date	App'd by	Date
VSW	4/3/2020				

### Load combinations

Load combination 1

Support A

Dead  $\times$  1.20  
Live  $\times$  1.60  
Roof live  $\times$  1.60  
Snow  $\times$  1.60  
Dead  $\times$  1.20  
Live  $\times$  1.60  
Roof live  $\times$  1.60  
Snow  $\times$  1.60  
Support B  
Dead  $\times$  1.20  
Live  $\times$  1.60  
Roof live  $\times$  1.60  
Snow  $\times$  1.60

### Analysis results

Maximum moment

$M_{\max} = 159.9$  kips<sub>ft</sub>

$M_{\min} = 0$  kips<sub>ft</sub>

Maximum shear

$V_{\max} = 26.7$  kips

$V_{\min} = -26.7$  kips

Deflection

$\delta_{\max} = 1$  in

$\delta_{\min} = 0$  in

Maximum reaction at support A

$R_{A_{\max}} = 26.7$  kips

$R_{A_{\min}} = 26.7$  kips

Unfactored dead load reaction at support A

$R_{A_{\text{Dead}}} = 3.5$  kips

Unfactored snow load reaction at support A

$R_{A_{\text{Snow}}} = 14$  kips

Maximum reaction at support B

$R_{B_{\max}} = 26.7$  kips

$R_{B_{\min}} = 26.7$  kips

Unfactored dead load reaction at support B

$R_{B_{\text{Dead}}} = 3.5$  kips

Unfactored snow load reaction at support B

$R_{B_{\text{Snow}}} = 14$  kips

### Section details

Section type

**W 16x31 (AISC 15th Edn (v15.0))**

ASTM steel designation

**A992**

Steel yield stress


$F_y = 50$  ksi


Steel tensile stress

$F_u = 65$  ksi

Modulus of elasticity

$E = 29000$  ksi



 Jirsa Hedrick Structural Engineers 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project				Job Ref.	
	Steamboat Schools				20191103	
	Section				Sheet no./rev.	
	Strawberry Park - Steel Framing				13	
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

### Resistance factors

Resistance factor for tensile yielding	$\phi_{ty} = 0.90$
Resistance factor for tensile rupture	$\phi_{tr} = 0.75$
Resistance factor for compression	$\phi_c = 0.90$
Resistance factor for flexure	$\phi_b = 0.90$

### Lateral bracing

Span 1 has continuous lateral bracing

### Classification of sections for local buckling - Section B4.1

#### Classification of flanges in flexure - Table B4.1b (case 10)

Width to thickness ratio	$b_f / (2 \times t_f) = 6.28$	
Limiting ratio for compact section	$\lambda_{pff} = 0.38 \times \sqrt{E / F_y} = 9.15$	
Limiting ratio for non-compact section	$\lambda_{rff} = 1.0 \times \sqrt{E / F_y} = 24.08$	Compact

#### Classification of web in flexure - Table B4.1b (case 15)

Width to thickness ratio	$(d - 2 \times k) / t_w = 51.69$	
Limiting ratio for compact section	$\lambda_{pwf} = 3.76 \times \sqrt{E / F_y} = 90.55$	
Limiting ratio for non-compact section	$\lambda_{rwf} = 5.70 \times \sqrt{E / F_y} = 137.27$	Compact

**Section is compact in flexure**

### Design of members for shear - Chapter G

Required shear strength	$V_r = \max(\text{abs}(V_{\max}), \text{abs}(V_{\min})) = 26.655 \text{ kips}$
Web area	$A_w = d \times t_w = 4.373 \text{ in}^2$
Web plate buckling coefficient	$k_v = 5$
Web shear coefficient - eq G2-3	$C_v = 1$
Nominal shear strength - eq G2-1	$V_n = 0.6 \times F_y \times A_w \times C_v = 131.175 \text{ kips}$
Resistance factor for shear	$\phi_v = 1.00$
Design shear strength	$V_c = \phi_v \times V_n = 131.175 \text{ kips}$

**PASS - Design shear strength exceeds required shear strength**

### Design of members for flexure in the major axis - Chapter F

Required flexural strength	$M_r = \max(\text{abs}(M_{s1\_max}), \text{abs}(M_{s1\_min})) = 159.932 \text{ kips\_ft}$
----------------------------	---

#### Yielding - Section F2.1

Nominal flexural strength for yielding - eq F2-1	$M_{nyld} = M_p = F_y \times Z_x = 225 \text{ kips\_ft}$
Nominal flexural strength	$M_n = M_{nyld} = 225.000 \text{ kips\_ft}$
Design flexural strength	$M_c = \phi_b \times M_n = 202.500 \text{ kips\_ft}$

**PASS - Design flexural strength exceeds required flexural strength**

### Design of members for vertical deflection

Consider deflection due to dead, live, roof live and snow loads

Limiting deflection	$\delta_{lim} = L_{s1} / 250 = 1.152 \text{ in}$
Maximum deflection span 1	$\delta = \max(\text{abs}(\delta_{\max}), \text{abs}(\delta_{\min})) = 1.003 \text{ in}$

**PASS - Maximum deflection does not exceed deflection limit**



Jirsa Hedrick Structural Engineers  
8490 E Crescent Pkwy Suite 250  
Greenwood Village, CO 80111


Project Steamboat Schools				Job Ref. 20191103	
Section Strawberry Park - Steel Framing				Sheet no./rev. 14	
Calc. by VSW	Date 4/3/2020	Chk'd by	Date	App'd by	Date

## STEEL COLUMN AT H/9.7

### STEEL COLUMN DESIGN

In accordance with AISC360-10 and the LRFD method

Tedds calculation version 1.0.10



### Column and loading details

#### Column details

Column section

**HSS 5x5x5/16**

#### Design loading

Required axial strength

$P_r = 114$  kips (Compression)

Moment about x axis at end 1

$M_{x1} = 0.0$  kips\_ft

Moment about x axis at end 2

$M_{x2} = 0.0$  kips\_ft

Maximum moment about x axis

$M_x = \max(\text{abs}(M_{x1}), \text{abs}(M_{x2})) = 0.0$  kips\_ft

Moment about y axis at end 1

$M_{y1} = 0.0$  kips\_ft

Moment about y axis at end 2

$M_{y2} = 0.0$  kips\_ft

Maximum moment about y axis

$M_y = \max(\text{abs}(M_{y1}), \text{abs}(M_{y2})) = 0.0$  kips\_ft

Maximum shear force parallel to y axis

$V_{ry} = 0.0$  kips

Maximum shear force parallel to x axis

$V_{rx} = 0.0$  kips

#### Material details

Steel grade

**A500 Gr. B**

Yield strength

$F_y = 46$  ksi

Ultimate strength

$F_u = 58$  ksi

Modulus of elasticity

$E = 29000$  ksi

Shear modulus of elasticity


$G = 11200$  ksi

#### Unbraced lengths

For buckling about x axis

$L_x = 156$  in



 Jirsa Hedrick Structural Engineers 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project				Job Ref.	
	Steamboat Schools				20191103	
	Section				Sheet no./rev.	
	Strawberry Park - Steel Framing				15	
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

For buckling about y axis  $L_y = 12$  in

For torsional buckling  $L_z = 12$  in

#### Effective length factors

For buckling about x axis  $K_x = 1.00$

For buckling about y axis  $K_y = 13.00$

For torsional buckling  $K_z = 1.00$

#### Section classification

##### Section classification for local buckling (cl. B4)

Critical flange width  $b = b_f - 3 \times t = 4.127$  in

Critical web width  $h = d - 3 \times t = 4.127$  in

Width to thickness ratio of flange (compression)  $\lambda_{f_c} = b / t = 14.182$

Width to thickness ratio of web (compression)  $\lambda_{w_c} = h / t = 14.182$

Width to thickness ratio of flange (major flexure)  $\lambda_{f_{fx}} = b / t = 14.182$

Width to thickness ratio of web (major flexure)  $\lambda_{w_{fx}} = h / t = 14.182$

Width to thickness ratio of flange (minor flexure)  $\lambda_{f_{fy}} = h / t = 14.182$

Width to thickness ratio of web (minor flexure)  $\lambda_{w_{fy}} = b / t = 14.182$

#### Compression

Limit for nonslender section  $\lambda_{r_c} = 1.40 \times \sqrt{E / F_y} = 35.152$

*The section is nonslender in compression*

#### Slenderness

##### Member slenderness

Slenderness ratio about x axis  $SR_x = K_x \times L_x / r_x = 82.1$

Slenderness ratio about y axis  $SR_y = K_y \times L_y / r_y = 82.1$

#### Reduction factor for slender elements

##### Reduction factor for slender elements (E7)

The section does not contain any slender elements therefore:-

Slender element reduction factor  $Q = 1.0$

#### Compressive strength

##### Flexural buckling about x axis (cl. E3)

Elastic critical buckling stress  $F_{ex} = (\pi^2 \times E) / (SR_x)^2 = 42.5$  ksi

Reduction factor  $Q_x = Q = 1.000$

Flexural buckling stress about x axis  $F_{crx} = Q_x \times (0.658^{Q_x \times F_y / F_{ex}}) \times F_y = 29.2$  ksi

Nominal flexural buckling strength  $P_{nx} = F_{crx} \times A_g = 153.7$  kips


##### Flexural buckling about y axis (cl. E3)

Elastic critical buckling stress  $F_{ey} = (\pi^2 \times E) / (SR_y)^2 = 42.5$  ksi

Reduction factor  $Q_y = Q = 1.000$

Flexural buckling stress about y axis  $F_{cry} = Q_y \times (0.658^{Q_y \times F_y / F_{ey}}) \times F_y = 29.2$  ksi

Nominal flexural buckling strength  $P_{ny} = F_{cry} \times A_g = 153.7$  kips

 Jirsa Hedrick Structural Engineers 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project				Job Ref.	
	Steamboat Schools				20191103	
	Section				Sheet no./rev.	
	Strawberry Park - Steel Framing				16	
	Calc. by	Date	Chk'd by	Date	App'd by	Date
	VSW	4/3/2020				

### Design compressive strength (cl.E1)

Resistance factor for compression

$$\phi_c = 0.90$$

Design compressive strength

$$P_c = \phi_c \times \min(P_{nx}, P_{ny}) = 138.4 \text{ kips}$$

**PASS - The design compressive strength exceeds the required compressive strength**



REQUIRED COLUMN SECTION IS LARGER THAN EXISTING.  
SEE BUILT UP COLUMN DESIGN CALCULATIONS ON  
FOLLOWING PAGES



Jirsa Hedrick Structural Engineers  
8490 E Crescent Pkwy Suite 250  
Greenwood Village, CO 80111


Project Steamboat Schools				Job Ref. 20191103	
Section Strawberry Park - Steel Framing				Sheet no./rev. 17	
Calc. by VSW	Date 4/3/2020	Chk'd by	Date	App'd by	Date

## STEEL COLUMN AT H/11.5

### STEEL COLUMN DESIGN

In accordance with AISC360-10 and the LRFD method

Tedds calculation version 1.0.10



### Column and loading details

#### Column details

Column section

**HSS 5x5x5/16**

#### Design loading

Required axial strength

$P_r = 50$  kips (Compression)

Moment about x axis at end 1

$M_{x1} = 17.0$  kips\_ft

Moment about x axis at end 2

$M_{x2} = 0.0$  kips\_ft

#### Single curvature bending about x axis

Maximum moment about x axis

$M_x = \max(\text{abs}(M_{x1}), \text{abs}(M_{x2})) = 17.0$  kips\_ft

Moment about y axis at end 1

$M_{y1} = 0.0$  kips\_ft

Moment about y axis at end 2

$M_{y2} = 0.0$  kips\_ft

Maximum moment about y axis

$M_y = \max(\text{abs}(M_{y1}), \text{abs}(M_{y2})) = 0.0$  kips\_ft

Maximum shear force parallel to y axis

$V_{ry} = 0.0$  kips

Maximum shear force parallel to x axis

$V_{rx} = 0.0$  kips

#### Material details

Steel grade

**A500 Gr. B**

Yield strength

$F_y = 46$  ksi

Ultimate strength

$F_u = 58$  ksi

Modulus of elasticity

$E = 29000$  ksi

Shear modulus of elasticity

$G = 11200$  ksi


#### Unbraced lengths

For buckling about x axis

$L_x = 156$  in

For buckling about y axis

$L_y = 12$  in

 Jirsa Hedrick Structural Engineers 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project Steamboat Schools				Job Ref. 20191103	
	Section Strawberry Park - Steel Framing				Sheet no./rev. 18	
	Calc. by VSW	Date 4/3/2020	Chk'd by	Date	App'd by	Date

For torsional buckling  $L_z = 12$  in

#### Effective length factors

For buckling about x axis  $K_x = 1.00$

For buckling about y axis  $K_y = 13.00$

For torsional buckling  $K_z = 1.00$

#### Section classification

##### Section classification for local buckling (cl. B4)

Critical flange width  $b = b_f - 3 \times t = 4.127$  in

Critical web width  $h = d - 3 \times t = 4.127$  in

Width to thickness ratio of flange (compression)  $\lambda_{f_c} = b / t = 14.182$

Width to thickness ratio of web (compression)  $\lambda_{w_c} = h / t = 14.182$

Width to thickness ratio of flange (major flexure)  $\lambda_{f_{fx}} = b / t = 14.182$

Width to thickness ratio of web (major flexure)  $\lambda_{w_{fx}} = h / t = 14.182$

Width to thickness ratio of flange (minor flexure)  $\lambda_{f_{fy}} = h / t = 14.182$

Width to thickness ratio of web (minor flexure)  $\lambda_{w_{fy}} = b / t = 14.182$

#### Compression

Limit for nonslender section  $\lambda_{r_c} = 1.40 \times \sqrt{E / F_y} = 35.152$

*The section is nonslender in compression*

#### Flexure

Limit for compact flange  $\lambda_{pf_f} = 1.12 \times \sqrt{E / F_y} = 28.121$

Limit for noncompact flange  $\lambda_{rf_f} = 1.40 \times \sqrt{E / F_y} = 35.152$

Limit for compact web  $\lambda_{pw_f} = 2.42 \times \sqrt{E / F_y} = 60.762$

Limit for noncompact web  $\lambda_{rw_f} = 5.70 \times \sqrt{E / F_y} = 143.118$

*The section is compact in flexure about the major axis*

#### Slenderness

##### Member slenderness

Slenderness ratio about x axis  $SR_x = K_x \times L_x / r_x = 82.1$

Slenderness ratio about y axis  $SR_y = K_y \times L_y / r_y = 82.1$

#### Second order effects

##### Second order effects for bending about x axis (cl. App 8.1)

Coefficient  $C_m$   $C_{mx} = 0.6 + 0.4 \times M_{x2} / M_{x1} = 0.600$

Coefficient  $\alpha$   $\alpha = 1.0$

Elastic critical buckling stress  $P_{e1x} = \pi^2 \times E \times I_x / (K_{1x} \times L_x)^2 = 223.5$  kips

P- $\delta$  amplifier  $B_{1x} = \max(1.0, C_{mx} / (1 - \alpha \times P_r / P_{e1x})) = 1.000$


Required flexural strength  $M_{rx} = B_{1x} \times M_x = 17.0$  kips<sub>ft</sub>

##### Second order effects for bending about y axis (cl. App 8.1)

Coefficient  $C_m$   $C_{my} = 0.6 + 0.4 \times M_{y1} / M_{y2} = 0.600$

Coefficient  $\alpha$   $\alpha = 1.0$

Elastic critical buckling stress  $P_{e1y} = \pi^2 \times E \times I_y / (K_{1y} \times L_y)^2 = 37764.9$  kips

 Jirsa Hedrick Structural Engineers 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project Steamboat Schools				Job Ref. 20191103	
	Section Strawberry Park - Steel Framing				Sheet no./rev. 19	
	Calc. by VSW	Date 4/3/2020	Chk'd by	Date	App'd by	Date

P-δ amplifier  $B_{1y} = \max(1.0, C_{my} / (1 - \alpha \times P_r / P_{e1y})) = 1.000$

Required flexural strength  $M_{ry} = B_{1y} \times M_y = 0.0 \text{ kips\_ft}$

#### Reduction factor for slender elements

#### **Reduction factor for slender elements (E7)**

The section does not contain any slender elements therefore:-

Slender element reduction factor  $Q = 1.0$

#### Compressive strength

#### **Flexural buckling about x axis (cl. E3)**

Elastic critical buckling stress  $F_{ex} = (\pi^2 \times E) / (SR_x)^2 = 42.5 \text{ ksi}$

Reduction factor  $Q_x = Q = 1.000$

Flexural buckling stress about x axis  $F_{crx} = Q_x \times (0.658^{Q_x \times F_y / F_{ex}}) \times F_y = 29.2 \text{ ksi}$

Nominal flexural buckling strength  $P_{nx} = F_{crx} \times A_g = 153.7 \text{ kips}$

#### **Flexural buckling about y axis (cl. E3)**

Elastic critical buckling stress  $F_{ey} = (\pi^2 \times E) / (SR_y)^2 = 42.5 \text{ ksi}$

Reduction factor  $Q_y = Q = 1.000$

Flexural buckling stress about y axis  $F_{cry} = Q_y \times (0.658^{Q_y \times F_y / F_{ey}}) \times F_y = 29.2 \text{ ksi}$

Nominal flexural buckling strength  $P_{ny} = F_{cry} \times A_g = 153.7 \text{ kips}$

#### **Design compressive strength (cl. E1)**

Resistance factor for compression  $\phi_c = 0.90$

Design compressive strength  $P_c = \phi_c \times \min(P_{nx}, P_{ny}) = 138.4 \text{ kips}$

**PASS - The design compressive strength exceeds the required compressive strength**

#### Flexural strength about the major axis

#### **Yielding (cl. F7.1)**

Nominal flexural strength  $M_{nx\_yld} = M_{px} = F_y \times Z_x = 35.1 \text{ kips\_ft}$

#### **Design flexural strength about the major axis (cl. F1)**

Resistance factor for flexure  $\phi_b = 0.90$

Allowable flexural strength  $M_{cx} = \phi_b \times \min(M_{nx\_yld}) = 31.602 \text{ kip\_ft}$

**PASS - The allowable flexural strength about the major axis exceeds the required flexural strength**


#### Combined forces

#### **Member utilization (cl. H1.1)**

Equation H1-1a  $UR = \text{abs}(P_r) / P_c + 8 / 9 \times (M_{rx} / M_{cx} + M_{ry} / M_{cy}) = 0.840$


**PASS - The member is adequate for the combined forces**

REQUIRED COLUMN SECTION IS LARGER THAN EXISTING.  
SEE BUILT UP COLUMN DESIGN CALCULATIONS ON  
FOLLOWING PAGES

 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project Steamboat Schools				Job Ref. 20191103	
	Section SP - Built Up Column Properties				Sheet no./rev. 1	
	Calc. by VSW	Date 3/16/2020	Chk'd by	Date	App'd by	Date

### CALCULATION OF SECTION PROPERTIES

Tedds calculation version 2.0.07



#### Area

$$A = 7.54 \text{ in}^2$$

#### 2<sup>nd</sup> moment of area

$$I_{uu} = 31.5 \text{ in}^4$$

$$I_{vv} = 16.5 \text{ in}^4$$

$$I_{xx} = 31.5 \text{ in}^4$$

$$I_{yy} = 16.5 \text{ in}^4$$

#### Radius of gyration

$$r_{uu} = 2.04 \text{ in}$$

$$r_{vv} = 1.48 \text{ in}$$

$$r_{xx} = 2.04 \text{ in}$$

$$r_{yy} = 1.48 \text{ in}$$

#### Plastic section modulus (only shapes with all rectangles at 90 degs)

$$Z_{xx} = 14.8 \text{ in}^3$$

$$Z_{yy} = 9.84 \text{ in}^3$$

#### Distance to combined centroid

$$X_e = 0.00 \text{ in}$$

$$Y_e = 0.00 \text{ in}$$

#### Distance to equal axis area (only shapes with all rectangles at 90 degs)

$$X_p = 0.00 \text{ in}$$

$$Y_p = 0.00 \text{ in}$$

#### Elastic section modulus

$$S_{xx} = 12.6 \text{ in}^3$$

$$S_{yy} = 6.59 \text{ in}^3$$

COLUMNS ON GRID H

HSS4x4x3/16 ,  $P_u = 114K$

PER AISC SECTION E4:

$$HSS4x4x3/16 \rightarrow r = 1.55 \text{ IN}$$

$$PL3/8 \times 5 : r = \sqrt{\frac{I}{A}} = 0.108 \text{ IN}$$

$$I = \frac{5'' \cdot 3.75''^3}{12} = .022 \text{ IN}^4$$

$$A = 5'' \cdot 3.75'' = 1.875 \text{ IN}^2$$

FOR 2" WELDS @ 8" OC  $\rightarrow a = 8''$

$$a/r_i = 8'' / .108'' = 74 \Rightarrow \text{EQN E4-2b GOVERNS}$$

$$\begin{aligned} \left( \frac{KL}{r} \right)_m &= \sqrt{\left( \frac{KL}{r} \right)_o^2 + \left( \frac{Kia}{r_i} \right)^2} \\ &= \sqrt{\left( \frac{1(13' \cdot 12'')}{1.49''} \right)^2 + \left( \frac{1(8'')}{.108''} \right)^2} \\ &= 128 \end{aligned}$$

$b/t = 20$  FOR BARE COLUMN

$$\text{SLENDERNESS LIMIT} = 1.4 \sqrt{E/F_y} = 35$$

PER SECTION E3:

$$\phi P_n = \phi F_c r A_g$$

$$1.71 \sqrt{E/F_y} = 118 \text{ (FOR 46 KSI)}$$

$$F_c r = 0.877 F_e \text{ (E3-3)}$$

$$F_e = \frac{\pi^2 E}{\left(\frac{KL}{r}\right)^2} = \frac{\pi^2 29000 \text{ KSI}}{128^2} = 17.46 \text{ KSI}$$

$$F_{cr} = 0.877 (17.46 \text{ KSI}) = 15.3 \text{ KSI}$$

$$\begin{aligned} \phi F_{cr} A_g &= 0.9 (15.3 \text{ KSI}) (6.29 \text{ IN}^2) \\ &= 86 \text{ K} \rightarrow \text{NG} \end{aligned}$$

TRY 1/2" PLATES

$$\left. \begin{aligned} I &= \frac{5^4 \cdot .5^3}{12} = .052 \text{ IN}^4 \\ A &= 5^2 \cdot .5^2 = 2.5 \text{ IN}^2 \end{aligned} \right\} r = .144"$$

$$a/r_i = 55$$

$$\left(\frac{KL}{r}\right)_m = \sqrt{\left(\frac{1 \times (13 \times 12^2)}{2.04^2}\right)^2 + \left(\frac{1 (8^2)}{.144^2}\right)^2}$$

$$= 94.4 < 118$$

$$F_{cr} = .658^{F_y/F_e} \times F_y$$

$$F_e = \frac{\pi^2 29000 \text{ KSI}}{94^2} = 32 \text{ KSI}$$

$$F_{cr} = .658^{36/32} \times 36 = 22.5 \text{ KSI}$$

$$\phi P_c = .9 (22.5 \text{ KSI}) (7.54 \text{ IN}^2) = 153 \text{ K OK}$$

ADD 5" x 1/2" PLATES 2 SIDES



SP-(E) COLUMN

GRID 2B

- COLUMN = HSS 8x8x3/8

- FOOTING = 7'-6"  $\Phi$  x 1'-4"

↳ ASSUME Q = 3000psf

$$P_{MAX} = 3000psf (7.5')^2 = 169K$$

$$P_u = 1.5(169K) = 254K$$

2 CHANNELS  $\rightarrow$  1 EA SIDE

$$P_u = 254K / 2 = 127K, P = 85K$$

$$L = 8.67'$$

$$M_n = F_y Z_x$$

$$M = \frac{PL}{4} = \frac{85K(8.67' \times 12'')}{4} = 2211K-IN$$

$$1.67(2211K-IN) = 50KSI \times Z_{req}$$

$$Z = 74IN^3$$

$$FOR \Delta = 1/240 = 0.43' :$$

$$.43' = \frac{85K(8.67' \times 12'')^3}{48(29000KSI)I}$$

$$I_{req} = 160IN^4$$

$$MC18 \times 51.9 \rightarrow REACTION = 43K \text{ EA END}$$

$$HSS 8 \times 8 \times 3/16$$


$$P/\Omega = 117K$$

# Lateral Analysis

# SP - Lateral Plan

Red lines = braced frames

Wind load per foot = 250 plf (ASD), 425 plf (LRFD)  
 Diaphragm shear (north-south) =  $4k/79' = 51$  plf  
 Diaphragm shear (north-south) =  $10k/79' = 127$  plf  
 Diaphragm shear (east-west) =  $5.4k/23' = 235$  plf  
 Diaphragm shear (east-west) =  $15k/46' = 326$  plf  
 Diaphragm shear capacity = 550 plf (ASD)





RAM Structural System



Database: Strawberry Park - East Addition

## Loads and Applied Forces

04/06/20 08:55:29

### LOAD CASE: Wind

Wind ASCE 7-10  
 Exposure: C  
 Basic Wind Speed (mph): 120.0  
 Apply Directionality Factor,  $K_d = 0.85$   
 Use Topography Factor,  $K_{zt} = 1.00$   
 Use Calculated Frequency for X-Dir.  
 Use Calculated Frequency for Y-Dir.  
 Gust Factor for Rigid Structures, G: Use Calculated G for X-Dir.  
 Gust Factor for Rigid Structures, G: Use Calculated G for Y-Dir.  
 Damping Ratio for Flexible Structures = 0.01  
 Mean Roof Height (ft): Top Story Height + Parapet = 21.42  
 Ground Level: Base

### WIND PRESSURES:

X-Direction: Natural Frequency = 19.217 Structure is Rigid  
 Y-Direction: Natural Frequency = 8.851 Structure is Rigid  
 $C_p$  Windward = 0.80  $q$  Leeward ( $q_h$ ) = 28.67 psf  
 $G C_{pn}$  (Parapet): Windward = 1.50 Leeward = -1.00

Height ft	$K_z$	$K_{zt}$	$q_z$ psf	Gust Factor G		$C_p$ Leeward		Pressure (psf)	
				X	Y	X	Y	X	Y
21.42	0.915	1.000	28.671	0.892	0.893	-0.500	-0.466	33.248	32.412
14.67	0.849	1.000	26.599	----	----	----	----	66.498	66.498
12.67	0.849	1.000	26.599	0.879	0.868	-0.357	-0.500	27.702	30.910
0.00	0.849	1.000	26.599	0.879	0.868	-0.357	-0.500	27.702	30.910

### APPLIED DIAPHRAGM FORCES

Type: Wind\_ASCE710\_1\_X

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	0.00	15.92	16.00
Roof	1	12.67	17.08	0.00	38.87	29.00

### APPLIED STORY FORCES

Type: Wind\_ASCE710\_1\_X

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	17.08	0.00
		17.08	0.00

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**Loads and Applied Forces****APPLIED DIAPHRAGM FORCES**

Type: Wind\_ASCE710\_1\_Y

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	0.00	15.92	16.00
Roof	1	12.67	0.00	29.16	40.60	29.96

**APPLIED STORY FORCES**

Type: Wind\_ASCE710\_1\_Y

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	0.00	29.16
		0.00	29.16

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: Wind\_ASCE710\_2\_X+E

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	0.00	15.92	18.55
Roof	1	12.67	12.81	0.00	38.87	35.57

**APPLIED STORY FORCES**

Type: Wind\_ASCE710\_2\_X+E

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	12.81	0.00
		12.81	0.00

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: Wind\_ASCE710\_2\_X-E

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
-------	---------	----------	------------	------------	---------	---------



RAM Structural System



RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Page 3/23

04/06/20 08:55:29

Penthouse	1	21.42	0.00	0.00	15.92	13.45
Roof	1	12.67	12.81	0.00	38.87	22.44

**APPLIED STORY FORCES**

Type: Wind\_ASCE710\_2\_X-E

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	12.81	0.00
		<hr/> 12.81	<hr/> 0.00

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: Wind\_ASCE710\_2\_Y+E

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	0.00	18.09	16.00
Roof	1	12.67	0.00	21.87	52.24	29.96

**APPLIED STORY FORCES**

Type: Wind\_ASCE710\_2\_Y+E

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	0.00	21.87
		<hr/> 0.00	<hr/> 21.87

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: Wind\_ASCE710\_2\_Y-E

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	0.00	13.74	16.00
Roof	1	12.67	0.00	21.87	28.95	29.96



RAM Structural System



DataBase: Strawberry Park - East Addition

## Loads and Applied Forces

Page 4/23

04/06/20 08:55:29

### APPLIED STORY FORCES

Type: Wind\_ASCE710\_2\_Y-E

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	0.00	21.87
		<hr/> 0.00	<hr/> 21.87

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: Wind\_ASCE710\_3\_X+Y

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	0.00	15.92	16.00
Roof	1	12.67	12.16	22.39	40.02	29.69

### APPLIED STORY FORCES

Type: Wind\_ASCE710\_3\_X+Y

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	12.16	22.39
		<hr/> 12.16	<hr/> 22.39

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: Wind\_ASCE710\_3\_X-Y

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	-0.00	15.92	16.00
Roof	1	12.67	12.16	-22.39	40.02	29.69

### APPLIED STORY FORCES

Type: Wind\_ASCE710\_3\_X-Y

Level	Ht ft	Fx kips	Fy kips
-------	----------	------------	------------

Strawberry Park - Lateral Analysis

Page 5 of 69



RAM Structural System



RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Page 5/23

04/06/20 08:55:29

## Loads and Applied Forces

Penthouse	21.42	0.00	0.00
Roof	12.67	12.16	-22.39
		<hr/> 12.16	<hr/> -22.39

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: Wind\_ASCE710\_4\_X+Y\_CW

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	0.00	13.74	18.55
Roof	1	12.67	9.12	16.79	28.60	36.47

### APPLIED STORY FORCES

Type: Wind\_ASCE710\_4\_X+Y\_CW

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	9.12	16.79
		<hr/> 9.12	<hr/> 16.79

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: Wind\_ASCE710\_4\_X+Y\_CCW

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	0.00	18.09	13.45
Roof	1	12.67	9.12	16.79	51.45	22.92

### APPLIED STORY FORCES

Type: Wind\_ASCE710\_4\_X+Y\_CCW

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	9.12	16.79
		<hr/> 9.12	<hr/> 16.79



**Loads and Applied Forces**

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: Wind\_ASCE710\_4\_X-Y\_CW

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	-0.00	18.09	18.55
Roof	1	12.67	9.12	-16.79	51.45	36.47

**APPLIED STORY FORCES**

Type: Wind\_ASCE710\_4\_X-Y\_CW

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	9.12	-16.79
		<hr/> 9.12	<hr/> -16.79

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: Wind\_ASCE710\_4\_X-Y\_CCW

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	-0.00	13.74	13.45
Roof	1	12.67	9.12	-16.79	28.60	22.92

**APPLIED STORY FORCES**

Type: Wind\_ASCE710\_4\_X-Y\_CCW

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	9.12	-16.79
		<hr/> 9.12	<hr/> -16.79

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.



RAM Structural System



Database: Strawberry Park - East Addition

## Loads and Applied Forces

Page 7/23

04/06/20 08:55:29

### LOAD CASE: Seismic

Seismic ASCE 7-10 Equivalent Lateral Force  
 Site Class: D Importance Factor: 1.25 Ss: 0.270 g S1: 0.074 g TL: 4.00 s  
 Fa: 1.584 Fv: 2.400 SDs: 0.285 g SD1: 0.118 g  
 Occupancy Category: III Seismic Design Category: B  
 Provisions for: Force  
 Ground Level: Base

Dir	Eccent	R	Ta Equation	Building Period-T
X	+ And -	3.3	Std,Ct=0.020,x=0.75	Calculated
Y	+ And -	3.3	Std,Ct=0.020,x=0.75	Calculated

Dir	Ta	Cu	T	T-used	Cs	Cs(max)	Cs(min)	Cs-used	k
					Eq12.8-2	Eq12.8-3	Eq12.8-5		
X	0.199	1.663	0.052	0.052	0.110	0.875	0.016	0.110	1.000
Dir	Ta	Cu	T	T-used	Cs	Cs(max)	Cs(min)	Cs-used	k
					Eq12.8-2	Eq12.8-3	Eq12.8-5		
Y	0.199	1.663	0.113	0.113	0.110	0.403	0.016	0.110	1.000

Total Building Weight (kips) = 107.19

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_X+E\_F

Level	Diaph.#	Ht	Fx	Fy	X	Y
		ft	kips	kips	ft	ft
Penthouse	1	21.42	0.00	0.00	17.66	16.85
Roof	1	12.67	11.75	0.00	33.98	31.08

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_X+E\_F

Level	Ht	Fx	Fy
	ft	kips	kips
Penthouse	21.42	0.00	0.00
Roof	12.67	11.75	0.00
		11.75	0.00

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_X-E\_F

Level	Diaph.#	Fx	Fy	X	Y
-------	---------	----	----	---	---



RAM Structural System



RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Page 8/23

04/06/20 08:55:29

		ft	kips	kips	ft	ft
Penthouse	1	21.42	0.00	0.00	17.66	15.15
Roof	1	12.67	11.75	0.00	33.98	26.72

**APPLIED STORY FORCES**

Type: EQ\_ASCE710\_X\_-E\_F

Level	Ht	Fx	Fy
	ft	kips	kips
Penthouse	21.42	0.00	0.00
Roof	12.67	11.75	0.00
		<hr/>	<hr/>
		11.75	0.00

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: EQ\_ASCE710\_Y\_+E\_F

Level	Diaph.#	Ht	Fx	Fy	X	Y
		ft	kips	kips	ft	ft
Penthouse	1	21.42	0.00	0.00	18.38	16.00
Roof	1	12.67	0.00	11.75	37.61	28.90

**APPLIED STORY FORCES**

Type: EQ\_ASCE710\_Y\_+E\_F

Level	Ht	Fx	Fy
	ft	kips	kips
Penthouse	21.42	0.00	0.00
Roof	12.67	0.00	11.75
		<hr/>	<hr/>
		0.00	11.75

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: EQ\_ASCE710\_Y\_-E\_F

Level	Diaph.#	Ht	Fx	Fy	X	Y
		ft	kips	kips	ft	ft
Penthouse	1	21.42	0.00	0.00	16.93	16.00
Roof	1	12.67	0.00	11.75	30.34	28.90



RAM Structural System



RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Page 9/23

04/06/20 08:55:29

## Loads and Applied Forces

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_Y\_-E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	0.00	11.75
		<hr/> 0.00	<hr/> 11.75

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_X\_+E\_0.3Y\_+E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	0.00	18.38	16.85
Roof	1	12.67	11.75	3.53	37.61	31.08

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_X\_+E\_0.3Y\_+E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	11.75	3.53
		<hr/> 11.75	<hr/> 3.53

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_X\_+E\_-0.3Y\_+E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	-0.00	18.38	16.85
Roof	1	12.67	11.75	-3.53	37.61	31.08

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_X\_+E\_-0.3Y\_+E\_F

Level	Ht ft	Fx kips	Fy kips
-------	----------	------------	------------

Strawberry Park - Lateral Analysis

Page 10 of 69



RAM Structural System



RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Page 10/23

04/06/20 08:55:29

## Loads and Applied Forces

Penthouse	21.42	0.00	0.00
Roof	12.67	11.75	-3.53
		<hr/> 11.75	<hr/> -3.53

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_-X\_+E\_0.3Y\_+E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	-0.00	0.00	18.38	16.85
Roof	1	12.67	-11.75	3.53	37.61	31.08

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_-X\_+E\_0.3Y\_+E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	-11.75	3.53
		<hr/> -11.75	<hr/> 3.53

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_-X\_+E\_-0.3Y\_+E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	-0.00	-0.00	18.38	16.85
Roof	1	12.67	-11.75	-3.53	37.61	31.08

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_-X\_+E\_-0.3Y\_+E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	-11.75	-3.53
		<hr/> -11.75	<hr/> -3.53

**Loads and Applied Forces**

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: EQ\_ASCE710\_0.3X\_+E\_Y\_+E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	0.00	18.38	16.85
Roof	1	12.67	3.53	11.75	37.61	31.08

**APPLIED STORY FORCES**

Type: EQ\_ASCE710\_0.3X\_+E\_Y\_+E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	3.53	11.75
		<hr/> 3.53	<hr/> 11.75

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: EQ\_ASCE710\_0.3X\_+E\_-Y\_+E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	-0.00	18.38	16.85
Roof	1	12.67	3.53	-11.75	37.61	31.08

**APPLIED STORY FORCES**

Type: EQ\_ASCE710\_0.3X\_+E\_-Y\_+E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	3.53	-11.75
		<hr/> 3.53	<hr/> -11.75

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.



RAM Structural System



RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

## Loads and Applied Forces

Page 12/23

04/06/20 08:55:29

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_-0.3X\_+E\_Y\_+E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	-0.00	0.00	18.38	16.85
Roof	1	12.67	-3.53	11.75	37.61	31.08

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_-0.3X\_+E\_Y\_+E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	-3.53	11.75
		<u>-3.53</u>	<u>11.75</u>

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_-0.3X\_+E\_-Y\_+E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	-0.00	-0.00	18.38	16.85
Roof	1	12.67	-3.53	-11.75	37.61	31.08

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_-0.3X\_+E\_-Y\_+E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	-3.53	-11.75
		<u>-3.53</u>	<u>-11.75</u>

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_X\_+E\_0.3Y\_-E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
-------	---------	----------	------------	------------	---------	---------

Strawberry Park - Lateral Analysis

Page 13 of 69



RAM Structural System



RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Page 13/23

04/06/20 08:55:29

Penthouse	1	21.42	0.00	0.00	16.93	16.85
Roof	1	12.67	11.75	3.53	30.34	31.08

**APPLIED STORY FORCES**

Type: EQ\_ASCE710\_X\_+E\_0.3Y\_-E\_F

Level	Ht	Fx	Fy
	ft	kips	kips
Penthouse	21.42	0.00	0.00
Roof	12.67	11.75	3.53
		11.75	3.53

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: EQ\_ASCE710\_X\_+E\_-0.3Y\_-E\_F

Level	Diaph.#	Ht	Fx	Fy	X	Y
		ft	kips	kips	ft	ft
Penthouse	1	21.42	0.00	-0.00	16.93	16.85
Roof	1	12.67	11.75	-3.53	30.34	31.08

**APPLIED STORY FORCES**

Type: EQ\_ASCE710\_X\_+E\_-0.3Y\_-E\_F

Level	Ht	Fx	Fy
	ft	kips	kips
Penthouse	21.42	0.00	0.00
Roof	12.67	11.75	-3.53
		11.75	-3.53

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: EQ\_ASCE710\_-X\_+E\_0.3Y\_-E\_F

Level	Diaph.#	Ht	Fx	Fy	X	Y
		ft	kips	kips	ft	ft
Penthouse	1	21.42	-0.00	0.00	16.93	16.85
Roof	1	12.67	-11.75	3.53	30.34	31.08





RAM Structural System



RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Page 14/23

04/06/20 08:55:29

## Loads and Applied Forces

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_-X\_+E\_0.3Y\_-E\_F

Level	Ht	Fx	Fy
	ft	kips	kips
Penthouse	21.42	0.00	0.00
Roof	12.67	-11.75	3.53
		<hr/> -11.75	<hr/> 3.53

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_-X\_+E\_-0.3Y\_-E\_F

Level	Diaph.#	Ht	Fx	Fy	X	Y
		ft	kips	kips	ft	ft
Penthouse	1	21.42	-0.00	-0.00	16.93	16.85
Roof	1	12.67	-11.75	-3.53	30.34	31.08

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_-X\_+E\_-0.3Y\_-E\_F

Level	Ht	Fx	Fy
	ft	kips	kips
Penthouse	21.42	0.00	0.00
Roof	12.67	-11.75	-3.53
		<hr/> -11.75	<hr/> -3.53

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_0.3X\_+E\_Y\_-E\_F

Level	Diaph.#	Ht	Fx	Fy	X	Y
		ft	kips	kips	ft	ft
Penthouse	1	21.42	0.00	0.00	16.93	16.85
Roof	1	12.67	3.53	11.75	30.34	31.08

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_0.3X\_+E\_Y\_-E\_F

Level	Ht	Fx	Fy
	ft	kips	kips

Strawberry Park - Lateral Analysis



RAM Structural System



RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Page 15/23

04/06/20 08:55:29

## Loads and Applied Forces

Penthouse	21.42	0.00	0.00
Roof	12.67	3.53	11.75
		<hr/> 3.53	<hr/> 11.75

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_0.3X\_+E\_-Y\_-E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	-0.00	16.93	16.85
Roof	1	12.67	3.53	-11.75	30.34	31.08

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_0.3X\_+E\_-Y\_-E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	3.53	-11.75
		<hr/> 3.53	<hr/> -11.75

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_-0.3X\_+E\_Y\_-E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	-0.00	0.00	16.93	16.85
Roof	1	12.67	-3.53	11.75	30.34	31.08

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_-0.3X\_+E\_Y\_-E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	-3.53	11.75
		<hr/> -3.53	<hr/> 11.75



Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: EQ\_ASCE710\_-0.3X\_+E\_-Y\_-E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	-0.00	-0.00	16.93	16.85
Roof	1	12.67	-3.53	-11.75	30.34	31.08

**APPLIED STORY FORCES**

Type: EQ\_ASCE710\_-0.3X\_+E\_-Y\_-E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	-3.53	-11.75
		<hr/> -3.53	<hr/> -11.75

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: EQ\_ASCE710\_X\_-E\_0.3Y\_+E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	0.00	18.38	15.15
Roof	1	12.67	11.75	3.53	37.61	26.72

**APPLIED STORY FORCES**

Type: EQ\_ASCE710\_X\_-E\_0.3Y\_+E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	11.75	3.53
		<hr/> 11.75	<hr/> 3.53

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.



RAM Structural System



DataBase: Strawberry Park - East Addition

## Loads and Applied Forces

Page 17/23

04/06/20 08:55:29

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_X\_-E\_-0.3Y\_+E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	-0.00	18.38	15.15
Roof	1	12.67	11.75	-3.53	37.61	26.72

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_X\_-E\_-0.3Y\_+E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	11.75	-3.53
		<u>11.75</u>	<u>-3.53</u>

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_-X\_-E\_0.3Y\_+E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	-0.00	0.00	18.38	15.15
Roof	1	12.67	-11.75	3.53	37.61	26.72

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_-X\_-E\_0.3Y\_+E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	-11.75	3.53
		<u>-11.75</u>	<u>3.53</u>

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_-X\_-E\_-0.3Y\_+E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
-------	---------	----------	------------	------------	---------	---------

Strawberry Park - Lateral Analysis

Page 18 of 69



RAM Structural System



RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Page 18/23

04/06/20 08:55:29

Penthouse	1	21.42	-0.00	-0.00	18.38	15.15
Roof	1	12.67	-11.75	-3.53	37.61	26.72

**APPLIED STORY FORCES**

Type: EQ\_ASCE710\_-X\_-E\_-0.3Y\_+E\_F

Level	Ht	Fx	Fy
	ft	kips	kips
Penthouse	21.42	0.00	0.00
Roof	12.67	-11.75	-3.53
		<hr/>	<hr/>
		-11.75	-3.53

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: EQ\_ASCE710\_0.3X\_-E\_Y\_+E\_F

Level	Diaph.#	Ht	Fx	Fy	X	Y
		ft	kips	kips	ft	ft
Penthouse	1	21.42	0.00	0.00	18.38	15.15
Roof	1	12.67	3.53	11.75	37.61	26.72

**APPLIED STORY FORCES**

Type: EQ\_ASCE710\_0.3X\_-E\_Y\_+E\_F

Level	Ht	Fx	Fy
	ft	kips	kips
Penthouse	21.42	0.00	0.00
Roof	12.67	3.53	11.75
		<hr/>	<hr/>
		3.53	11.75

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: EQ\_ASCE710\_0.3X\_-E\_-Y\_+E\_F

Level	Diaph.#	Ht	Fx	Fy	X	Y
		ft	kips	kips	ft	ft
Penthouse	1	21.42	0.00	-0.00	18.38	15.15
Roof	1	12.67	3.53	-11.75	37.61	26.72



RAM Structural System



DataBase: Strawberry Park - East Addition

## Loads and Applied Forces

Page 19/23

04/06/20 08:55:29

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_-0.3X\_-E\_-Y\_+E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	3.53	-11.75
		<u>3.53</u>	<u>-11.75</u>

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_-0.3X\_-E\_Y\_+E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	-0.00	0.00	18.38	15.15
Roof	1	12.67	-3.53	11.75	37.61	26.72

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_-0.3X\_-E\_Y\_+E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	-3.53	11.75
		<u>-3.53</u>	<u>11.75</u>

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_-0.3X\_-E\_-Y\_+E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	-0.00	-0.00	18.38	15.15
Roof	1	12.67	-3.53	-11.75	37.61	26.72

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_-0.3X\_-E\_-Y\_+E\_F

Level	Ht ft	Fx kips	Fy kips
-------	----------	------------	------------

Strawberry Park - Lateral Analysis

Page 20 of 69



RAM Structural System



Bentley DataBase: Strawberry Park - East Addition

## Loads and Applied Forces

RAM Frame 17.00.01.09

Page 20/23

04/06/20 08:55:29

Penthouse	21.42	0.00	0.00
Roof	12.67	-3.53	-11.75
		<hr/> -3.53	<hr/> -11.75

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_X\_-E\_0.3Y\_-E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	0.00	16.93	15.15
Roof	1	12.67	11.75	3.53	30.34	26.72

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_X\_-E\_0.3Y\_-E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	11.75	3.53
		<hr/> 11.75	<hr/> 3.53

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_X\_-E\_-0.3Y\_-E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	-0.00	16.93	15.15
Roof	1	12.67	11.75	-3.53	30.34	26.72

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_X\_-E\_-0.3Y\_-E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	11.75	-3.53
		<hr/> 11.75	<hr/> -3.53

**Loads and Applied Forces**

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: EQ\_ASCE710\_-X\_-E\_0.3Y\_-E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	-0.00	0.00	16.93	15.15
Roof	1	12.67	-11.75	3.53	30.34	26.72

**APPLIED STORY FORCES**

Type: EQ\_ASCE710\_-X\_-E\_0.3Y\_-E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	-11.75	3.53
		<hr/> -11.75	<hr/> 3.53

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: EQ\_ASCE710\_-X\_-E\_-0.3Y\_-E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	-0.00	-0.00	16.93	15.15
Roof	1	12.67	-11.75	-3.53	30.34	26.72

**APPLIED STORY FORCES**

Type: EQ\_ASCE710\_-X\_-E\_-0.3Y\_-E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	-11.75	-3.53
		<hr/> -11.75	<hr/> -3.53

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.





RAM Structural System



RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Page 22/23

04/06/20 08:55:29

## Loads and Applied Forces

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_0.3X\_-E\_Y\_-E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	0.00	16.93	15.15
Roof	1	12.67	3.53	11.75	30.34	26.72

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_0.3X\_-E\_Y\_-E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	3.53	11.75
		<u>3.53</u>	<u>11.75</u>

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_0.3X\_-E\_-Y\_-E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
Penthouse	1	21.42	0.00	-0.00	16.93	15.15
Roof	1	12.67	3.53	-11.75	30.34	26.72

### APPLIED STORY FORCES

Type: EQ\_ASCE710\_0.3X\_-E\_-Y\_-E\_F

Level	Ht ft	Fx kips	Fy kips
Penthouse	21.42	0.00	0.00
Roof	12.67	3.53	-11.75
		<u>3.53</u>	<u>-11.75</u>

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

### APPLIED DIAPHRAGM FORCES

Type: EQ\_ASCE710\_-0.3X\_-E\_Y\_-E\_F

Level	Diaph.#	Ht ft	Fx kips	Fy kips	X ft	Y ft
-------	---------	----------	------------	------------	---------	---------

Strawberry Park - Lateral Analysis

Page 23 of 69



RAM Structural System



RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Page 23/23

04/06/20 08:55:29

Penthouse	1	21.42	-0.00	0.00	16.93	15.15
Roof	1	12.67	-3.53	11.75	30.34	26.72

**APPLIED STORY FORCES**

Type: EQ\_ASCE710\_-0.3X\_-E\_Y\_-E\_F

Level	Ht	Fx	Fy
	ft	kips	kips
Penthouse	21.42	0.00	0.00
Roof	12.67	-3.53	11.75
		<hr/>	<hr/>
		-3.53	11.75

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.

**APPLIED DIAPHRAGM FORCES**

Type: EQ\_ASCE710\_-0.3X\_-E\_-Y\_-E\_F

Level	Diaph.#	Ht	Fx	Fy	X	Y
		ft	kips	kips	ft	ft
Penthouse	1	21.42	-0.00	-0.00	16.93	15.15
Roof	1	12.67	-3.53	-11.75	30.34	26.72

**APPLIED STORY FORCES**

Type: EQ\_ASCE710\_-0.3X\_-E\_-Y\_-E\_F

Level	Ht	Fx	Fy
	ft	kips	kips
Penthouse	21.42	0.00	0.00
Roof	12.67	-3.53	-11.75
		<hr/>	<hr/>
		-3.53	-11.75

Note: Diaphragm (or Diaphragms) at Top Story Found with No Lateral Members. Calculated Story Forces for Wind or Seismic Load Cases at This Level Combined to Story Below by the Program. It is also Assumed for This Level that Center of Rigidity is at the Center of Mass.



RAM Structural System



# Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

04/06/20 08:57:09

Building Code: IBC

## STEEL COLUMN INFORMATION:

**Column Number: 9****Frame Number: 1**

Level Top: Roof

Column Line (39.25,48.00)

Bot: Base

Fy (ksi) = 50.00

Column Size = HSS4X4X5/16

Elastic Modulus (ksi) = 29000

Orientation (deg) = 0.00

Length (ft) = 12.67

## INPUT PARAMETERS:

		<b>Top</b>	<b>Bottom</b>
Fixity	Major Axis:	Fix	Fix
	Minor Axis:	Fix	Fix
	Torsion:	Fix	Fix
Joint Face Dist (in):			
	Major:	5.10	0.00
	Minor:	0.00	0.00
Rigid End Zone (in):			
	Major:	0.00	0.00 (Ignore)
	Minor:	0.00	0.00 (Ignore)

Member Force Output:

At Face of Joint

P-Delta: Yes

Scale Factor: 1.00

Ground Level: Base

## LOAD CASE DEFINITIONS:

D	DeadLoad	RAMUSER
Sp	PosSnowLoad	RAMUSER
W1	Wind	Wind_ASCE710_1_X
W2	Wind	Wind_ASCE710_1_Y
W3	Wind	Wind_ASCE710_2_X+E
W4	Wind	Wind_ASCE710_2_X-E
W5	Wind	Wind_ASCE710_2_Y+E
W6	Wind	Wind_ASCE710_2_Y-E
W7	Wind	Wind_ASCE710_3_X+Y
W8	Wind	Wind_ASCE710_3_X-Y
W9	Wind	Wind_ASCE710_4_X+Y_CW
W10	Wind	Wind_ASCE710_4_X+Y_CCW
W11	Wind	Wind_ASCE710_4_X-Y_CW
W12	Wind	Wind_ASCE710_4_X-Y_CCW
E1	Seismic	EQ_ASCE710_X_+E_F
E2	Seismic	EQ_ASCE710_X_-E_F
E3	Seismic	EQ_ASCE710_Y_+E_F
E4	Seismic	EQ_ASCE710_Y_-E_F
E5	Seismic	EQ_ASCE710_X_+E_0.3Y_+E_F
E6	Seismic	EQ_ASCE710_X_+E_-0.3Y_+E_F
E7	Seismic	EQ_ASCE710_-X_+E_0.3Y_+E_F
E8	Seismic	EQ_ASCE710_-X_+E_-0.3Y_+E_F



RAM Structural System



# Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 2/24

04/06/20 08:57:09

E9	Seismic	EQ_ASCE710_0.3X_+E_Y_+E_F
E10	Seismic	EQ_ASCE710_0.3X_+E_-Y_+E_F
E11	Seismic	EQ_ASCE710_-0.3X_+E_Y_+E_F
E12	Seismic	EQ_ASCE710_-0.3X_+E_-Y_+E_F
E13	Seismic	EQ_ASCE710_X_+E_0.3Y_-E_F
E14	Seismic	EQ_ASCE710_X_+E_-0.3Y_-E_F
E15	Seismic	EQ_ASCE710_-X_+E_0.3Y_-E_F
E16	Seismic	EQ_ASCE710_-X_+E_-0.3Y_-E_F
E17	Seismic	EQ_ASCE710_0.3X_+E_Y_-E_F
E18	Seismic	EQ_ASCE710_0.3X_+E_-Y_-E_F
E19	Seismic	EQ_ASCE710_-0.3X_+E_Y_-E_F
E20	Seismic	EQ_ASCE710_-0.3X_+E_-Y_-E_F
E21	Seismic	EQ_ASCE710_X_-E_0.3Y_+E_F
E22	Seismic	EQ_ASCE710_X_-E_-0.3Y_+E_F
E23	Seismic	EQ_ASCE710_-X_-E_0.3Y_+E_F
E24	Seismic	EQ_ASCE710_-X_-E_-0.3Y_+E_F
E25	Seismic	EQ_ASCE710_0.3X_-E_Y_+E_F
E26	Seismic	EQ_ASCE710_0.3X_-E_-Y_+E_F
E27	Seismic	EQ_ASCE710_-0.3X_-E_Y_+E_F
E28	Seismic	EQ_ASCE710_-0.3X_-E_-Y_+E_F
E29	Seismic	EQ_ASCE710_X_-E_0.3Y_-E_F
E30	Seismic	EQ_ASCE710_X_-E_-0.3Y_-E_F
E31	Seismic	EQ_ASCE710_-X_-E_0.3Y_-E_F
E32	Seismic	EQ_ASCE710_-X_-E_-0.3Y_-E_F
E33	Seismic	EQ_ASCE710_0.3X_-E_Y_-E_F
E34	Seismic	EQ_ASCE710_0.3X_-E_-Y_-E_F
E35	Seismic	EQ_ASCE710_-0.3X_-E_Y_-E_F
E36	Seismic	EQ_ASCE710_-0.3X_-E_-Y_-E_F

## LOAD COMBINATIONS: IBC 2015 / ASCE 7-10 LRFD

No. of Generated Combinations: 314

No. of Generated Combinations Selected to Use: 314

## MEMBER FORCE MAXIMA AND MINIMA

	P	Mmajor	Mminor	Vmajor	Vminor	Tors
	kips	kip-ft	kip-ft	kips	kips	kip-ft
Max @ T:	13.56	0.74	0.00	0.01	0.01	0.01
LC:	25	25	31	85	28	31
Max @ B:	13.56	0.12	0.17	0.01	0.01	0.01
LC:	25	85	28	85	28	31
Maximum:	13.56	0.74	0.17	0.01	0.01	0.01
LC:	25	25	28	85	28	31
@ (ft):	0.43	0.43	12.67	0.43	0.00	0.43



RAM Structural System



## Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 3/24

04/06/20 08:57:09

---

	<b>P</b>	<b>Mmajor</b>	<b>Mminor</b>	<b>Vmajor</b>	<b>Vminor</b>	<b>Tors</b>
<b>Min @ T:</b>	-5.44	-0.03	-0.00	-0.10	-0.01	-0.01
<b>LC:</b>	85	85	91	25	88	91
<b>Min @ B:</b>	-5.44	-0.49	-0.14	-0.10	-0.01	-0.01
<b>LC:</b>	85	25	88	25	88	91
<b>Minimum:</b>	-5.44	-0.49	-0.14	-0.10	-0.01	-0.01
<b>LC:</b>	85	25	88	25	88	91
<b>@ (ft):</b>	0.43	12.67	12.67	0.43	0.00	0.43



RAM Structural System



# Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 4/24

04/06/20 08:57:09

## STEEL COLUMN INFORMATION:

**Column Number: 16****Frame Number: 1**

Level Top: Roof

Column Line (46.25,48.00)

Bot: Base

Fy (ksi) = 46.00

Column Size = HSS4X4X5/16

Elastic Modulus (ksi) = 29000

Orientation (deg) = 0.00

Length (ft) = 12.67

## INPUT PARAMETERS:

		<b>Top</b>	<b>Bottom</b>
Fixity	Major Axis:	Fix	Fix
	Minor Axis:	Fix	Fix
	Torsion:	Fix	Fix
Joint Face Dist (in):			
	Major:	5.10	0.00
	Minor:	0.00	0.00
Rigid End Zone (in):			
	Major:	0.00	0.00 (Ignore)
	Minor:	0.00	0.00 (Ignore)

Member Force Output:

At Face of Joint

P-Delta: Yes

Scale Factor: 1.00

Ground Level: Base

## LOAD CASE DEFINITIONS:

D	DeadLoad	RAMUSER
Sp	PosSnowLoad	RAMUSER
W1	Wind	Wind_ASCE710_1_X
W2	Wind	Wind_ASCE710_1_Y
W3	Wind	Wind_ASCE710_2_X+E
W4	Wind	Wind_ASCE710_2_X-E
W5	Wind	Wind_ASCE710_2_Y+E
W6	Wind	Wind_ASCE710_2_Y-E
W7	Wind	Wind_ASCE710_3_X+Y
W8	Wind	Wind_ASCE710_3_X-Y
W9	Wind	Wind_ASCE710_4_X+Y_CW
W10	Wind	Wind_ASCE710_4_X+Y_CCW
W11	Wind	Wind_ASCE710_4_X-Y_CW
W12	Wind	Wind_ASCE710_4_X-Y_CCW
E1	Seismic	EQ_ASCE710_X_+E_F
E2	Seismic	EQ_ASCE710_X_-E_F
E3	Seismic	EQ_ASCE710_Y_+E_F
E4	Seismic	EQ_ASCE710_Y_-E_F
E5	Seismic	EQ_ASCE710_X_+E_0.3Y_+E_F
E6	Seismic	EQ_ASCE710_X_+E_-0.3Y_+E_F
E7	Seismic	EQ_ASCE710_-X_+E_0.3Y_+E_F
E8	Seismic	EQ_ASCE710_-X_+E_-0.3Y_+E_F



RAM Structural System



# Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 5/24

04/06/20 08:57:09

E9	Seismic	EQ_ASCE710_0.3X_+E_Y_+E_F
E10	Seismic	EQ_ASCE710_0.3X_+E_-Y_+E_F
E11	Seismic	EQ_ASCE710_-0.3X_+E_Y_+E_F
E12	Seismic	EQ_ASCE710_-0.3X_+E_-Y_+E_F
E13	Seismic	EQ_ASCE710_X_+E_0.3Y_-E_F
E14	Seismic	EQ_ASCE710_X_+E_-0.3Y_-E_F
E15	Seismic	EQ_ASCE710_-X_+E_0.3Y_-E_F
E16	Seismic	EQ_ASCE710_-X_+E_-0.3Y_-E_F
E17	Seismic	EQ_ASCE710_0.3X_+E_Y_-E_F
E18	Seismic	EQ_ASCE710_0.3X_+E_-Y_-E_F
E19	Seismic	EQ_ASCE710_-0.3X_+E_Y_-E_F
E20	Seismic	EQ_ASCE710_-0.3X_+E_-Y_-E_F
E21	Seismic	EQ_ASCE710_X_-E_0.3Y_+E_F
E22	Seismic	EQ_ASCE710_X_-E_-0.3Y_+E_F
E23	Seismic	EQ_ASCE710_-X_-E_0.3Y_+E_F
E24	Seismic	EQ_ASCE710_-X_-E_-0.3Y_+E_F
E25	Seismic	EQ_ASCE710_0.3X_-E_Y_+E_F
E26	Seismic	EQ_ASCE710_0.3X_-E_-Y_+E_F
E27	Seismic	EQ_ASCE710_-0.3X_-E_Y_+E_F
E28	Seismic	EQ_ASCE710_-0.3X_-E_-Y_+E_F
E29	Seismic	EQ_ASCE710_X_-E_0.3Y_-E_F
E30	Seismic	EQ_ASCE710_X_-E_-0.3Y_-E_F
E31	Seismic	EQ_ASCE710_-X_-E_0.3Y_-E_F
E32	Seismic	EQ_ASCE710_-X_-E_-0.3Y_-E_F
E33	Seismic	EQ_ASCE710_0.3X_-E_Y_-E_F
E34	Seismic	EQ_ASCE710_0.3X_-E_-Y_-E_F
E35	Seismic	EQ_ASCE710_-0.3X_-E_Y_-E_F
E36	Seismic	EQ_ASCE710_-0.3X_-E_-Y_-E_F

## LOAD COMBINATIONS: IBC 2015 / ASCE 7-10 LRFD

No. of Generated Combinations: 314

No. of Generated Combinations Selected to Use: 314

## MEMBER FORCE MAXIMA AND MINIMA

	P	Mmajor	Mminor	Vmajor	Vminor	Tors
	kips	kip-ft	kip-ft	kips	kips	kip-ft
Max @ T:	25.95	0.10	0.00	0.04	0.02	0.01
LC:	13	97	91	13	28	31
Max @ B:	25.95	0.21	0.20	0.04	0.02	0.01
LC:	13	37	28	13	28	31
Maximum:	25.95	0.21	0.20	0.04	0.02	0.01
LC:	13	37	28	13	28	31
@ (ft):	0.43	12.67	12.67	0.43	0.00	0.43



RAM Structural System



## Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 6/24

04/06/20 08:57:09

---

	<b>P</b>	<b>Mmajor</b>	<b>Mminor</b>	<b>Vmajor</b>	<b>Vminor</b>	<b>Tors</b>
<b>Min @ T:</b>	3.80	-0.31	-0.00	-0.02	-0.01	-0.01
<b>LC:</b>	249	13	31	97	88	91
<b>Min @ B:</b>	3.80	-0.17	-0.16	-0.02	-0.01	-0.01
<b>LC:</b>	249	97	88	97	88	91
<b>Minimum:</b>	3.80	-0.31	-0.16	-0.02	-0.01	-0.01
<b>LC:</b>	249	13	88	97	88	91
<b>@ (ft):</b>	0.43	0.43	12.67	0.43	0.00	0.43





RAM Structural System



# Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 7/24

04/06/20 08:57:09

## STEEL BEAM INFORMATION:

**Beam Number: 44**

Level: Roof

Fy (ksi) = 50.00

Length (ft) = 7.00

Elastic Modulus (ksi) = 29000

**Frame Number: 1**

I-End (39.25,48.00)

J-End (46.25,48.00)

Beam Size = W10X22

## INPUT PARAMETERS:

Fixity Major Axis:

Minor Axis:

Torsion:

Rigid End Zone (in):

**I-End**

Fix

Fix

Fix

0.00

**J-End**

Fix

Fix

Fix

0.00 (Ignore)

Member Force Output:

P-Delta: Yes

Ground Level: Base

At Face of Joint

Scale Factor: 1.00

## LOAD CASE DEFINITIONS:

D	DeadLoad	RAMUSER
Sp	PosSnowLoad	RAMUSER
W1	Wind	Wind_ASCE710_1_X
W2	Wind	Wind_ASCE710_1_Y
W3	Wind	Wind_ASCE710_2_X+E
W4	Wind	Wind_ASCE710_2_X-E
W5	Wind	Wind_ASCE710_2_Y+E
W6	Wind	Wind_ASCE710_2_Y-E
W7	Wind	Wind_ASCE710_3_X+Y
W8	Wind	Wind_ASCE710_3_X-Y
W9	Wind	Wind_ASCE710_4_X+Y_CW
W10	Wind	Wind_ASCE710_4_X+Y_CCW
W11	Wind	Wind_ASCE710_4_X-Y_CW
W12	Wind	Wind_ASCE710_4_X-Y_CCW
E1	Seismic	EQ_ASCE710_X_+E_F
E2	Seismic	EQ_ASCE710_X_-E_F
E3	Seismic	EQ_ASCE710_Y_+E_F
E4	Seismic	EQ_ASCE710_Y_-E_F
E5	Seismic	EQ_ASCE710_X_+E_0.3Y_+E_F
E6	Seismic	EQ_ASCE710_X_+E_-0.3Y_+E_F
E7	Seismic	EQ_ASCE710_-X_+E_0.3Y_+E_F
E8	Seismic	EQ_ASCE710_-X_+E_-0.3Y_+E_F
E9	Seismic	EQ_ASCE710_0.3X_+E_Y_+E_F
E10	Seismic	EQ_ASCE710_0.3X_+E_-Y_+E_F
E11	Seismic	EQ_ASCE710_-0.3X_+E_Y_+E_F
E12	Seismic	EQ_ASCE710_-0.3X_+E_-Y_+E_F
E13	Seismic	EQ_ASCE710_X_+E_0.3Y_-E_F



RAM Structural System



# Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 8/24

04/06/20 08:57:09

E14	Seismic	EQ_ASCE710_X_+E_-0.3Y_-E_F
E15	Seismic	EQ_ASCE710_-X_+E_0.3Y_-E_F
E16	Seismic	EQ_ASCE710_-X_+E_-0.3Y_-E_F
E17	Seismic	EQ_ASCE710_0.3X_+E_Y_-E_F
E18	Seismic	EQ_ASCE710_0.3X_+E_-Y_-E_F
E19	Seismic	EQ_ASCE710_-0.3X_+E_Y_-E_F
E20	Seismic	EQ_ASCE710_-0.3X_+E_-Y_-E_F
E21	Seismic	EQ_ASCE710_X_-E_0.3Y_+E_F
E22	Seismic	EQ_ASCE710_X_-E_-0.3Y_+E_F
E23	Seismic	EQ_ASCE710_-X_-E_0.3Y_+E_F
E24	Seismic	EQ_ASCE710_-X_-E_-0.3Y_+E_F
E25	Seismic	EQ_ASCE710_0.3X_-E_Y_+E_F
E26	Seismic	EQ_ASCE710_0.3X_-E_-Y_+E_F
E27	Seismic	EQ_ASCE710_-0.3X_-E_Y_+E_F
E28	Seismic	EQ_ASCE710_-0.3X_-E_-Y_+E_F
E29	Seismic	EQ_ASCE710_X_-E_0.3Y_-E_F
E30	Seismic	EQ_ASCE710_X_-E_-0.3Y_-E_F
E31	Seismic	EQ_ASCE710_-X_-E_0.3Y_-E_F
E32	Seismic	EQ_ASCE710_-X_-E_-0.3Y_-E_F
E33	Seismic	EQ_ASCE710_0.3X_-E_Y_-E_F
E34	Seismic	EQ_ASCE710_0.3X_-E_-Y_-E_F
E35	Seismic	EQ_ASCE710_-0.3X_-E_Y_-E_F
E36	Seismic	EQ_ASCE710_-0.3X_-E_-Y_-E_F

## LOAD COMBINATIONS: IBC 2015 / ASCE 7-10 LRFD

No. of Generated Combinations: 314

No. of Generated Combinations Selected to Use: 314

## MEMBER FORCE MAXIMA AND MINIMA

	P	Mmajor	Mminor	Vmajor	Vminor	Tors
	kips	kip-ft	kip-ft	kips	kips	kip-ft
Max @ i:	0.00	0.12	0.00	3.71	0.00	0.00
LC:	243	85	72	25	28	91
Max @ j:	0.00	0.42	0.00	-0.51	0.00	0.00
LC:	243	25	58	249	28	91
Maximum:	0.00	11.43	0.00	3.71	0.00	0.00
LC:	243	2	58	25	28	91
@ (ft):	0.00	3.50	6.83	0.17	0.17	0.00
Min @ i:	-0.00	-0.18	-0.00	0.53	-0.00	-0.00
LC:	107	49	36	248	88	31
Min @ j:	-0.00	-0.08	-0.00	-3.63	-0.00	-0.00
LC:	107	85	46	13	88	31



RAM Structural System



## Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 9/24

04/06/20 08:57:09

---

	<b>P</b>	<b>Mmajor</b>	<b>Mminor</b>	<b>Vmajor</b>	<b>Vminor</b>	<b>Tors</b>
<b>Minimum:</b>	-0.00	-0.17	-0.00	-3.63	-0.00	-0.00
<b>LC:</b>	107	49	46	13	88	31
<b>@ (ft):</b>	0.00	0.17	6.83	6.83	0.17	0.00



RAM Structural System



RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

## Member Force Envelope

Page 10/24

04/06/20 08:57:09

### STEEL BRACE INFORMATION:

**Brace Number: 2**

Story Top: Roof

Bot: Base

Fy (ksi) = 46.00

Length (ft) = 14.48

Elastic Modulus (ksi) = 29000

**Frame Number: 1**

I-End (ft): (39.25,48.00)

J-End (ft): (46.25,48.00)

Brace Size = HSS4X4X3/8

### INPUT PARAMETERS:

		<b>Top</b>	<b>Bottom</b>
Fixity	Major Axis:	Pin	Pin
	Minor Axis:	Pin	Pin
	Torsion:	Pin	Pin
Member Force Output:		At Centerline of Joint	
P-Delta:	Yes	Scale Factor:	1.00
Ground Level:	Base		

### LOAD CASE DEFINITIONS:

D	DeadLoad	RAMUSER
Sp	PosSnowLoad	RAMUSER
W1	Wind	Wind_ASCE710_1_X
W2	Wind	Wind_ASCE710_1_Y
W3	Wind	Wind_ASCE710_2_X+E
W4	Wind	Wind_ASCE710_2_X-E
W5	Wind	Wind_ASCE710_2_Y+E
W6	Wind	Wind_ASCE710_2_Y-E
W7	Wind	Wind_ASCE710_3_X+Y
W8	Wind	Wind_ASCE710_3_X-Y
W9	Wind	Wind_ASCE710_4_X+Y_CW
W10	Wind	Wind_ASCE710_4_X+Y_CCW
W11	Wind	Wind_ASCE710_4_X-Y_CW
W12	Wind	Wind_ASCE710_4_X-Y_CCW
E1	Seismic	EQ_ASCE710_X_+E_F
E2	Seismic	EQ_ASCE710_X_-E_F
E3	Seismic	EQ_ASCE710_Y_+E_F
E4	Seismic	EQ_ASCE710_Y_-E_F
E5	Seismic	EQ_ASCE710_X_+E_0.3Y_+E_F
E6	Seismic	EQ_ASCE710_X_+E_-0.3Y_+E_F
E7	Seismic	EQ_ASCE710_-X_+E_0.3Y_+E_F
E8	Seismic	EQ_ASCE710_-X_+E_-0.3Y_+E_F
E9	Seismic	EQ_ASCE710_0.3X_+E_Y_+E_F
E10	Seismic	EQ_ASCE710_0.3X_+E_-Y_+E_F
E11	Seismic	EQ_ASCE710_-0.3X_+E_Y_+E_F
E12	Seismic	EQ_ASCE710_-0.3X_+E_-Y_+E_F
E13	Seismic	EQ_ASCE710_X_+E_0.3Y_-E_F
E14	Seismic	EQ_ASCE710_X_+E_-0.3Y_-E_F



RAM Structural System



# Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 11/24

04/06/20 08:57:09

E15	Seismic	EQ_ASCE710_-X_+E_0.3Y_-E_F
E16	Seismic	EQ_ASCE710_-X_+E_-0.3Y_-E_F
E17	Seismic	EQ_ASCE710_0.3X_+E_Y_-E_F
E18	Seismic	EQ_ASCE710_0.3X_+E_-Y_-E_F
E19	Seismic	EQ_ASCE710_-0.3X_+E_Y_-E_F
E20	Seismic	EQ_ASCE710_-0.3X_+E_-Y_-E_F
E21	Seismic	EQ_ASCE710_X_-E_0.3Y_+E_F
E22	Seismic	EQ_ASCE710_X_-E_-0.3Y_+E_F
E23	Seismic	EQ_ASCE710_-X_-E_0.3Y_+E_F
E24	Seismic	EQ_ASCE710_-X_-E_-0.3Y_+E_F
E25	Seismic	EQ_ASCE710_0.3X_-E_Y_+E_F
E26	Seismic	EQ_ASCE710_0.3X_-E_-Y_+E_F
E27	Seismic	EQ_ASCE710_-0.3X_-E_Y_+E_F
E28	Seismic	EQ_ASCE710_-0.3X_-E_-Y_+E_F
E29	Seismic	EQ_ASCE710_X_-E_0.3Y_-E_F
E30	Seismic	EQ_ASCE710_X_-E_-0.3Y_-E_F
E31	Seismic	EQ_ASCE710_-X_-E_0.3Y_-E_F
E32	Seismic	EQ_ASCE710_-X_-E_-0.3Y_-E_F
E33	Seismic	EQ_ASCE710_0.3X_-E_Y_-E_F
E34	Seismic	EQ_ASCE710_0.3X_-E_-Y_-E_F
E35	Seismic	EQ_ASCE710_-0.3X_-E_Y_-E_F
E36	Seismic	EQ_ASCE710_-0.3X_-E_-Y_-E_F

## LOAD COMBINATIONS: IBC 2015 / ASCE 7-10 LRFD

No. of Generated Combinations: 314

No. of Generated Combinations Selected to Use: 314

## MEMBER FORCE MAXIMA AND MINIMA

	P	Mmajor	Mminor	Vmajor	Vminor	Tors
	kips	kip-ft	kip-ft	kips	kips	kip-ft
Max @ T:	9.24	0.00	0.00	0.00	0.00	0.00
LC:	37	1	1	85	28	1
Max @ B:	9.24	0.00	0.00	0.00	0.00	0.00
LC:	37	1	1	85	28	1
Maximum:	9.24	0.00	0.00	0.00	0.00	0.00
LC:	37	1	1	85	28	1
@ (ft):	0.00	0.00	0.00	0.00	0.00	0.00
Min @ T:	-7.64	0.00	0.00	-0.00	-0.00	0.00
LC:	97	1	1	49	88	1
Min @ B:	-7.64	0.00	0.00	-0.00	-0.00	0.00
LC:	97	1	1	49	88	1
Minimum:	-7.64	0.00	0.00	-0.00	-0.00	0.00

Strawberry Park - Lateral Analysis

Page 35 of 69



RAM Structural System



## Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 12/24

04/06/20 08:57:09

---

	<b>P</b>	<b>Mmajor</b>	<b>Mminor</b>	<b>Vmajor</b>	<b>Vminor</b>	<b>Tors</b>
<b>LC:</b>	97	1	1	49	88	1
<b>@ (ft):</b>	0.00	0.00	0.00	0.00	0.00	0.00



RAM Structural System



# Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 13/24

04/06/20 08:57:09

## STEEL COLUMN INFORMATION:

**Column Number: 10****Frame Number: 2**

Level Top: Roof

Column Line (82.67,48.00)

Bot: Base

Fy (ksi) = 50.00

Column Size = HSS4X4X5/16

Elastic Modulus (ksi) = 29000

Orientation (deg) = 90.00

Length (ft) = 12.67

## INPUT PARAMETERS:

		<b>Top</b>	<b>Bottom</b>
Fixity	Major Axis:	Fix	Fix
	Minor Axis:	Fix	Fix
	Torsion:	Fix	Fix
Joint Face Dist (in):			
	Major:	5.10	0.00
	Minor:	0.00	0.00
Rigid End Zone (in):			
	Major:	0.00	0.00 (Ignore)
	Minor:	0.00	0.00 (Ignore)

Member Force Output:

At Face of Joint

P-Delta: Yes

Scale Factor: 1.00

Ground Level: Base

## LOAD CASE DEFINITIONS:

D	DeadLoad	RAMUSER
Sp	PosSnowLoad	RAMUSER
W1	Wind	Wind_ASCE710_1_X
W2	Wind	Wind_ASCE710_1_Y
W3	Wind	Wind_ASCE710_2_X+E
W4	Wind	Wind_ASCE710_2_X-E
W5	Wind	Wind_ASCE710_2_Y+E
W6	Wind	Wind_ASCE710_2_Y-E
W7	Wind	Wind_ASCE710_3_X+Y
W8	Wind	Wind_ASCE710_3_X-Y
W9	Wind	Wind_ASCE710_4_X+Y_CW
W10	Wind	Wind_ASCE710_4_X+Y_CCW
W11	Wind	Wind_ASCE710_4_X-Y_CW
W12	Wind	Wind_ASCE710_4_X-Y_CCW
E1	Seismic	EQ_ASCE710_X_+E_F
E2	Seismic	EQ_ASCE710_X_-E_F
E3	Seismic	EQ_ASCE710_Y_+E_F
E4	Seismic	EQ_ASCE710_Y_-E_F
E5	Seismic	EQ_ASCE710_X_+E_0.3Y_+E_F
E6	Seismic	EQ_ASCE710_X_+E_-0.3Y_+E_F
E7	Seismic	EQ_ASCE710_-X_+E_0.3Y_+E_F
E8	Seismic	EQ_ASCE710_-X_+E_-0.3Y_+E_F



RAM Structural System



# Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 14/24

04/06/20 08:57:09

E9	Seismic	EQ_ASCE710_0.3X_+E_Y_+E_F
E10	Seismic	EQ_ASCE710_0.3X_+E_-Y_+E_F
E11	Seismic	EQ_ASCE710_-0.3X_+E_Y_+E_F
E12	Seismic	EQ_ASCE710_-0.3X_+E_-Y_+E_F
E13	Seismic	EQ_ASCE710_X_+E_0.3Y_-E_F
E14	Seismic	EQ_ASCE710_X_+E_-0.3Y_-E_F
E15	Seismic	EQ_ASCE710_-X_+E_0.3Y_-E_F
E16	Seismic	EQ_ASCE710_-X_+E_-0.3Y_-E_F
E17	Seismic	EQ_ASCE710_0.3X_+E_Y_-E_F
E18	Seismic	EQ_ASCE710_0.3X_+E_-Y_-E_F
E19	Seismic	EQ_ASCE710_-0.3X_+E_Y_-E_F
E20	Seismic	EQ_ASCE710_-0.3X_+E_-Y_-E_F
E21	Seismic	EQ_ASCE710_X_-E_0.3Y_+E_F
E22	Seismic	EQ_ASCE710_X_-E_-0.3Y_+E_F
E23	Seismic	EQ_ASCE710_-X_-E_0.3Y_+E_F
E24	Seismic	EQ_ASCE710_-X_-E_-0.3Y_+E_F
E25	Seismic	EQ_ASCE710_0.3X_-E_Y_+E_F
E26	Seismic	EQ_ASCE710_0.3X_-E_-Y_+E_F
E27	Seismic	EQ_ASCE710_-0.3X_-E_Y_+E_F
E28	Seismic	EQ_ASCE710_-0.3X_-E_-Y_+E_F
E29	Seismic	EQ_ASCE710_X_-E_0.3Y_-E_F
E30	Seismic	EQ_ASCE710_X_-E_-0.3Y_-E_F
E31	Seismic	EQ_ASCE710_-X_-E_0.3Y_-E_F
E32	Seismic	EQ_ASCE710_-X_-E_-0.3Y_-E_F
E33	Seismic	EQ_ASCE710_0.3X_-E_Y_-E_F
E34	Seismic	EQ_ASCE710_0.3X_-E_-Y_-E_F
E35	Seismic	EQ_ASCE710_-0.3X_-E_Y_-E_F
E36	Seismic	EQ_ASCE710_-0.3X_-E_-Y_-E_F

## LOAD COMBINATIONS: IBC 2015 / ASCE 7-10 LRFD

No. of Generated Combinations: 314

No. of Generated Combinations Selected to Use: 314

## MEMBER FORCE MAXIMA AND MINIMA

	P	Mmajor	Mminor	Vmajor	Vminor	Tors
	kips	kip-ft	kip-ft	kips	kips	kip-ft
<b>Max @ T:</b>	26.77	0.36	0.00	0.10	0.01	0.01
<b>LC:</b>	31	91	91	31	49	31
<b>Max @ B:</b>	26.77	0.66	0.13	0.10	0.01	0.01
<b>LC:</b>	31	31	49	31	49	31
<b>Maximum:</b>	26.77	0.66	0.13	0.10	0.01	0.01
<b>LC:</b>	31	31	49	31	49	31
<b>@ (ft):</b>	0.43	12.67	12.67	0.43	0.00	0.43





RAM Structural System



## Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 15/24

04/06/20 08:57:09

---

	<b>P</b>	<b>Mmajor</b>	<b>Mminor</b>	<b>Vmajor</b>	<b>Vminor</b>	<b>Tors</b>
<b>Min @ T:</b>	-16.92	-0.51	-0.00	-0.07	-0.01	-0.01
<b>LC:</b>	91	31	31	91	85	91
<b>Min @ B:</b>	-16.92	-0.50	-0.10	-0.07	-0.01	-0.01
<b>LC:</b>	91	91	85	91	85	91
<b>Minimum:</b>	-16.92	-0.51	-0.10	-0.07	-0.01	-0.01
<b>LC:</b>	91	31	85	91	85	91
<b>@ (ft):</b>	0.43	0.43	12.67	0.43	0.00	0.43



RAM Structural System



# Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 16/24

04/06/20 08:57:09

## STEEL COLUMN INFORMATION:

**Column Number: 15**

Level Top: Roof

Bot: Base

Fy (ksi) = 50.00

Elastic Modulus (ksi) = 29000

Orientation (deg) = 90.00

**Frame Number: 2**

Column Line (82.67,42.00)

Column Size = HSS4X4X5/16

Length (ft) = 12.67

## INPUT PARAMETERS:

		<b>Top</b>	<b>Bottom</b>
Fixity	Major Axis:	Fix	Fix
	Minor Axis:	Fix	Fix
	Torsion:	Fix	Fix
Joint Face Dist (in):			
	Major:	5.10	0.00
	Minor:	0.00	0.00
Rigid End Zone (in):			
	Major:	0.00	0.00 (Ignore)
	Minor:	0.00	0.00 (Ignore)

Member Force Output:

At Face of Joint

P-Delta: Yes

Scale Factor: 1.00

Ground Level: Base

## LOAD CASE DEFINITIONS:

D	DeadLoad	RAMUSER
Sp	PosSnowLoad	RAMUSER
W1	Wind	Wind_ASCE710_1_X
W2	Wind	Wind_ASCE710_1_Y
W3	Wind	Wind_ASCE710_2_X+E
W4	Wind	Wind_ASCE710_2_X-E
W5	Wind	Wind_ASCE710_2_Y+E
W6	Wind	Wind_ASCE710_2_Y-E
W7	Wind	Wind_ASCE710_3_X+Y
W8	Wind	Wind_ASCE710_3_X-Y
W9	Wind	Wind_ASCE710_4_X+Y_CW
W10	Wind	Wind_ASCE710_4_X+Y_CCW
W11	Wind	Wind_ASCE710_4_X-Y_CW
W12	Wind	Wind_ASCE710_4_X-Y_CCW
E1	Seismic	EQ_ASCE710_X_+E_F
E2	Seismic	EQ_ASCE710_X_-E_F
E3	Seismic	EQ_ASCE710_Y_+E_F
E4	Seismic	EQ_ASCE710_Y_-E_F
E5	Seismic	EQ_ASCE710_X_+E_0.3Y_+E_F
E6	Seismic	EQ_ASCE710_X_+E_-0.3Y_+E_F
E7	Seismic	EQ_ASCE710_-X_+E_0.3Y_+E_F
E8	Seismic	EQ_ASCE710_-X_+E_-0.3Y_+E_F



RAM Structural System



# Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 17/24

04/06/20 08:57:09

E9	Seismic	EQ_ASCE710_0.3X_+E_Y_+E_F
E10	Seismic	EQ_ASCE710_0.3X_+E_-Y_+E_F
E11	Seismic	EQ_ASCE710_-0.3X_+E_Y_+E_F
E12	Seismic	EQ_ASCE710_-0.3X_+E_-Y_+E_F
E13	Seismic	EQ_ASCE710_X_+E_0.3Y_-E_F
E14	Seismic	EQ_ASCE710_X_+E_-0.3Y_-E_F
E15	Seismic	EQ_ASCE710_-X_+E_0.3Y_-E_F
E16	Seismic	EQ_ASCE710_-X_+E_-0.3Y_-E_F
E17	Seismic	EQ_ASCE710_0.3X_+E_Y_-E_F
E18	Seismic	EQ_ASCE710_0.3X_+E_-Y_-E_F
E19	Seismic	EQ_ASCE710_-0.3X_+E_Y_-E_F
E20	Seismic	EQ_ASCE710_-0.3X_+E_-Y_-E_F
E21	Seismic	EQ_ASCE710_X_-E_0.3Y_+E_F
E22	Seismic	EQ_ASCE710_X_-E_-0.3Y_+E_F
E23	Seismic	EQ_ASCE710_-X_-E_0.3Y_+E_F
E24	Seismic	EQ_ASCE710_-X_-E_-0.3Y_+E_F
E25	Seismic	EQ_ASCE710_0.3X_-E_Y_+E_F
E26	Seismic	EQ_ASCE710_0.3X_-E_-Y_+E_F
E27	Seismic	EQ_ASCE710_-0.3X_-E_Y_+E_F
E28	Seismic	EQ_ASCE710_-0.3X_-E_-Y_+E_F
E29	Seismic	EQ_ASCE710_X_-E_0.3Y_-E_F
E30	Seismic	EQ_ASCE710_X_-E_-0.3Y_-E_F
E31	Seismic	EQ_ASCE710_-X_-E_0.3Y_-E_F
E32	Seismic	EQ_ASCE710_-X_-E_-0.3Y_-E_F
E33	Seismic	EQ_ASCE710_0.3X_-E_Y_-E_F
E34	Seismic	EQ_ASCE710_0.3X_-E_-Y_-E_F
E35	Seismic	EQ_ASCE710_-0.3X_-E_Y_-E_F
E36	Seismic	EQ_ASCE710_-0.3X_-E_-Y_-E_F

## LOAD COMBINATIONS: IBC 2015 / ASCE 7-10 LRFD

No. of Generated Combinations: 314

No. of Generated Combinations Selected to Use: 314

## MEMBER FORCE MAXIMA AND MINIMA

	P	Mmajor	Mminor	Vmajor	Vminor	Tors
	kips	kip-ft	kip-ft	kips	kips	kip-ft
<b>Max @ T:</b>	6.20	0.39	0.00	0.08	0.01	0.01
<b>LC:</b>	19	91	31	31	49	31
<b>Max @ B:</b>	6.20	0.61	0.10	0.08	0.01	0.01
<b>LC:</b>	19	31	49	31	49	31
<b>Maximum:</b>	6.20	0.61	0.10	0.08	0.01	0.01
<b>LC:</b>	19	31	49	31	49	31
<b>@ (ft):</b>	0.43	12.67	12.67	0.43	0.00	0.43



RAM Structural System



## Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 18/24

04/06/20 08:57:09

---

	<b>P</b>	<b>Mmajor</b>	<b>Mminor</b>	<b>Vmajor</b>	<b>Vminor</b>	<b>Tors</b>
<b>Min @ T:</b>	1.03	-0.42	-0.00	-0.07	-0.01	-0.01
<b>LC:</b>	79	31	91	91	85	91
<b>Min @ B:</b>	1.03	-0.51	-0.08	-0.07	-0.01	-0.01
<b>LC:</b>	79	91	85	91	85	91
<b>Minimum:</b>	1.03	-0.51	-0.08	-0.07	-0.01	-0.01
<b>LC:</b>	79	91	85	91	85	91
<b>@ (ft):</b>	0.43	12.67	12.67	0.43	0.00	0.43



RAM Structural System



# Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 19/24

04/06/20 08:57:09

## STEEL BEAM INFORMATION:

**Beam Number: 15**

Level: Roof

Fy (ksi) = 50.00

Length (ft) = 6.00

Elastic Modulus (ksi) = 29000

**Frame Number: 2**

I-End (82.67,42.00)

J-End (82.67,48.00)

Beam Size = W10X22

## INPUT PARAMETERS:

		<b>I-End</b>	<b>J-End</b>
Fixity	Major Axis:	Fix	Fix
	Minor Axis:	Fix	Fix
	Torsion:	Fix	Fix
Rigid End Zone (in):		0.00	0.00 (Ignore)

Member Force Output:

At Face of Joint

P-Delta: Yes

Scale Factor: 1.00

Ground Level: Base

## LOAD CASE DEFINITIONS:

D	DeadLoad	RAMUSER
Sp	PosSnowLoad	RAMUSER
W1	Wind	Wind_ASCE710_1_X
W2	Wind	Wind_ASCE710_1_Y
W3	Wind	Wind_ASCE710_2_X+E
W4	Wind	Wind_ASCE710_2_X-E
W5	Wind	Wind_ASCE710_2_Y+E
W6	Wind	Wind_ASCE710_2_Y-E
W7	Wind	Wind_ASCE710_3_X+Y
W8	Wind	Wind_ASCE710_3_X-Y
W9	Wind	Wind_ASCE710_4_X+Y_CW
W10	Wind	Wind_ASCE710_4_X+Y_CCW
W11	Wind	Wind_ASCE710_4_X-Y_CW
W12	Wind	Wind_ASCE710_4_X-Y_CCW
E1	Seismic	EQ_ASCE710_X_+E_F
E2	Seismic	EQ_ASCE710_X_-E_F
E3	Seismic	EQ_ASCE710_Y_+E_F
E4	Seismic	EQ_ASCE710_Y_-E_F
E5	Seismic	EQ_ASCE710_X_+E_0.3Y_+E_F
E6	Seismic	EQ_ASCE710_X_+E_-0.3Y_+E_F
E7	Seismic	EQ_ASCE710_-X_+E_0.3Y_+E_F
E8	Seismic	EQ_ASCE710_-X_+E_-0.3Y_+E_F
E9	Seismic	EQ_ASCE710_0.3X_+E_Y_+E_F
E10	Seismic	EQ_ASCE710_0.3X_+E_-Y_+E_F
E11	Seismic	EQ_ASCE710_-0.3X_+E_Y_+E_F
E12	Seismic	EQ_ASCE710_-0.3X_+E_-Y_+E_F
E13	Seismic	EQ_ASCE710_X_+E_0.3Y_-E_F



RAM Structural System



# Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 20/24

04/06/20 08:57:09

E14	Seismic	EQ_ASCE710_X_+E_-0.3Y_-E_F
E15	Seismic	EQ_ASCE710_-X_+E_0.3Y_-E_F
E16	Seismic	EQ_ASCE710_-X_+E_-0.3Y_-E_F
E17	Seismic	EQ_ASCE710_0.3X_+E_Y_-E_F
E18	Seismic	EQ_ASCE710_0.3X_+E_-Y_-E_F
E19	Seismic	EQ_ASCE710_-0.3X_+E_Y_-E_F
E20	Seismic	EQ_ASCE710_-0.3X_+E_-Y_-E_F
E21	Seismic	EQ_ASCE710_X_-E_0.3Y_+E_F
E22	Seismic	EQ_ASCE710_X_-E_-0.3Y_+E_F
E23	Seismic	EQ_ASCE710_-X_-E_0.3Y_+E_F
E24	Seismic	EQ_ASCE710_-X_-E_-0.3Y_+E_F
E25	Seismic	EQ_ASCE710_0.3X_-E_Y_+E_F
E26	Seismic	EQ_ASCE710_0.3X_-E_-Y_+E_F
E27	Seismic	EQ_ASCE710_-0.3X_-E_Y_+E_F
E28	Seismic	EQ_ASCE710_-0.3X_-E_-Y_+E_F
E29	Seismic	EQ_ASCE710_X_-E_0.3Y_-E_F
E30	Seismic	EQ_ASCE710_X_-E_-0.3Y_-E_F
E31	Seismic	EQ_ASCE710_-X_-E_0.3Y_-E_F
E32	Seismic	EQ_ASCE710_-X_-E_-0.3Y_-E_F
E33	Seismic	EQ_ASCE710_0.3X_-E_Y_-E_F
E34	Seismic	EQ_ASCE710_0.3X_-E_-Y_-E_F
E35	Seismic	EQ_ASCE710_-0.3X_-E_Y_-E_F
E36	Seismic	EQ_ASCE710_-0.3X_-E_-Y_-E_F

## LOAD COMBINATIONS: IBC 2015 / ASCE 7-10 LRFD

No. of Generated Combinations: 314

No. of Generated Combinations Selected to Use: 314

## MEMBER FORCE MAXIMA AND MINIMA

	P	Mmajor	Mminor	Vmajor	Vminor	Tors
	kips	kip-ft	kip-ft	kips	kips	kip-ft
Max @ i:	0.00	0.54	0.00	1.37	0.00	0.00
LC:	49	31	29	19	37	91
Max @ j:	0.00	0.41	0.00	-0.11	0.00	0.00
LC:	49	91	37	91	37	91
Maximum:	0.00	2.06	0.00	1.37	0.00	0.00
LC:	49	7	37	19	37	91
@ (ft):	0.00	2.83	5.83	0.17	0.17	0.00
Min @ i:	-0.00	-0.36	-0.00	0.09	-0.00	-0.00
LC:	37	91	41	79	49	31
Min @ j:	-0.00	-0.41	-0.00	-1.47	-0.00	-0.00
LC:	37	31	49	7	49	31



RAM Structural System



## Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 21/24

04/06/20 08:57:09

---

	<b>P</b>	<b>Mmajor</b>	<b>Mminor</b>	<b>Vmajor</b>	<b>Vminor</b>	<b>Tors</b>
<b>Minimum:</b>	-0.00	-0.41	-0.00	-1.47	-0.00	-0.00
<b>LC:</b>	37	31	49	7	49	31
<b>@ (ft):</b>	0.00	5.83	5.83	5.83	0.17	0.00



RAM Structural System



# Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 22/24

04/06/20 08:57:09

## STEEL BRACE INFORMATION:

**Brace Number: 3**

Story Top: Roof

Bot: Base

Fy (ksi) = 46.00

Length (ft) = 14.02

Elastic Modulus (ksi) = 29000

**Frame Number: 2**

I-End (ft): (82.67,48.00)

J-End (ft): (82.67,42.00)

Brace Size = HSS4X4X3/8

## INPUT PARAMETERS:

		Top	Bottom
Fixity	Major Axis:	Pin	Pin
	Minor Axis:	Pin	Pin
	Torsion:	Pin	Pin
Member Force Output:		At Centerline of Joint	
P-Delta:	Yes	Scale Factor:	1.00
Ground Level:	Base		

## LOAD CASE DEFINITIONS:

D	DeadLoad	RAMUSER
Sp	PosSnowLoad	RAMUSER
W1	Wind	Wind_ASCE710_1_X
W2	Wind	Wind_ASCE710_1_Y
W3	Wind	Wind_ASCE710_2_X+E
W4	Wind	Wind_ASCE710_2_X-E
W5	Wind	Wind_ASCE710_2_Y+E
W6	Wind	Wind_ASCE710_2_Y-E
W7	Wind	Wind_ASCE710_3_X+Y
W8	Wind	Wind_ASCE710_3_X-Y
W9	Wind	Wind_ASCE710_4_X+Y_CW
W10	Wind	Wind_ASCE710_4_X+Y_CCW
W11	Wind	Wind_ASCE710_4_X-Y_CW
W12	Wind	Wind_ASCE710_4_X-Y_CCW
E1	Seismic	EQ_ASCE710_X_+E_F
E2	Seismic	EQ_ASCE710_X_-E_F
E3	Seismic	EQ_ASCE710_Y_+E_F
E4	Seismic	EQ_ASCE710_Y_-E_F
E5	Seismic	EQ_ASCE710_X_+E_0.3Y_+E_F
E6	Seismic	EQ_ASCE710_X_+E_-0.3Y_+E_F
E7	Seismic	EQ_ASCE710_-X_+E_0.3Y_+E_F
E8	Seismic	EQ_ASCE710_-X_+E_-0.3Y_+E_F
E9	Seismic	EQ_ASCE710_0.3X_+E_Y_+E_F
E10	Seismic	EQ_ASCE710_0.3X_+E_-Y_+E_F
E11	Seismic	EQ_ASCE710_-0.3X_+E_Y_+E_F
E12	Seismic	EQ_ASCE710_-0.3X_+E_-Y_+E_F
E13	Seismic	EQ_ASCE710_X_+E_0.3Y_-E_F
E14	Seismic	EQ_ASCE710_X_+E_-0.3Y_-E_F





RAM Structural System



# Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 23/24

04/06/20 08:57:09

E15	Seismic	EQ_ASCE710_-X_+E_0.3Y_-E_F
E16	Seismic	EQ_ASCE710_-X_+E_-0.3Y_-E_F
E17	Seismic	EQ_ASCE710_0.3X_+E_Y_-E_F
E18	Seismic	EQ_ASCE710_0.3X_+E_-Y_-E_F
E19	Seismic	EQ_ASCE710_-0.3X_+E_Y_-E_F
E20	Seismic	EQ_ASCE710_-0.3X_+E_-Y_-E_F
E21	Seismic	EQ_ASCE710_X_-E_0.3Y_+E_F
E22	Seismic	EQ_ASCE710_X_-E_-0.3Y_+E_F
E23	Seismic	EQ_ASCE710_-X_-E_0.3Y_+E_F
E24	Seismic	EQ_ASCE710_-X_-E_-0.3Y_+E_F
E25	Seismic	EQ_ASCE710_0.3X_-E_Y_+E_F
E26	Seismic	EQ_ASCE710_0.3X_-E_-Y_+E_F
E27	Seismic	EQ_ASCE710_-0.3X_-E_Y_+E_F
E28	Seismic	EQ_ASCE710_-0.3X_-E_-Y_+E_F
E29	Seismic	EQ_ASCE710_X_-E_0.3Y_-E_F
E30	Seismic	EQ_ASCE710_X_-E_-0.3Y_-E_F
E31	Seismic	EQ_ASCE710_-X_-E_0.3Y_-E_F
E32	Seismic	EQ_ASCE710_-X_-E_-0.3Y_-E_F
E33	Seismic	EQ_ASCE710_0.3X_-E_Y_-E_F
E34	Seismic	EQ_ASCE710_0.3X_-E_-Y_-E_F
E35	Seismic	EQ_ASCE710_-0.3X_-E_Y_-E_F
E36	Seismic	EQ_ASCE710_-0.3X_-E_-Y_-E_F

## LOAD COMBINATIONS: IBC 2015 / ASCE 7-10 LRFD

No. of Generated Combinations: 314

No. of Generated Combinations Selected to Use: 314

## MEMBER FORCE MAXIMA AND MINIMA

	P	Mmajor	Mminor	Vmajor	Vminor	Tors
	kips	kip-ft	kip-ft	kips	kips	kip-ft
<b>Max @ T:</b>	21.29	0.00	0.00	0.00	0.00	0.00
<b>LC:</b>	91	1	1	91	85	1
<b>Max @ B:</b>	21.29	0.00	0.00	0.00	0.00	0.00
<b>LC:</b>	91	1	1	91	85	1
<b>Maximum:</b>	21.29	0.00	0.00	0.00	0.00	0.00
<b>LC:</b>	91	1	1	91	85	1
<b>@ (ft):</b>	0.00	0.00	0.00	0.00	0.00	0.00
<b>Min @ T:</b>	-21.89	0.00	0.00	-0.00	-0.00	0.00
<b>LC:</b>	31	1	1	31	49	1
<b>Min @ B:</b>	-21.89	0.00	0.00	-0.00	-0.00	0.00
<b>LC:</b>	31	1	1	31	49	1
<b>Minimum:</b>	-21.89	0.00	0.00	-0.00	-0.00	0.00

Strawberry Park - Lateral Analysis

Page 47 of 69



RAM Structural System



## Member Force Envelope

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 24/24

04/06/20 08:57:09

---

	<b>P</b>	<b>Mmajor</b>	<b>Mminor</b>	<b>Vmajor</b>	<b>Vminor</b>	<b>Tors</b>
<b>LC:</b>	31	1	1	31	49	1
<b>@ (ft):</b>	0.00	0.00	0.00	0.00	0.00	0.00



RAM Structural System



# Code Check Summary

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

04/06/20 08:57:09

Steel Code: AISC360-16 LRFD

## CRITERIA:

Rigid End Zones: Ignore Effects  
 Member Force Output: At Face of Joint  
 P-Delta: Yes Scale Factor: 1.00  
 Ground Level: Base  
 Mesh Criteria :  
     Max. Distance Between Nodes on Mesh Line (ft) : 4.00  
     Merge Node Tolerance (in) : 0.0100  
     Geometry Tolerance (in) : 0.0050  
 Walls Out-of-plane Stiffness Not Included in Analysis.  
 Sign considered for Dynamic Load Case Results.  
 Rigid Links Included at Fixed Beam-to-Wall Locations  
 Eigenvalue Analysis : Eigen Vectors (Subspace Iteration)

## LOAD COMBINATION CRITERIA:

Snow Factor f2 Use Full Factor (f2 = 0.7) on Snow in Combination with Seismic  
 Live Load factor f1 (0.5 or 1.0) 0.500  
 Sds (for Ev) 0.285  
 RhoX 1.000  
 RhoY 1.000

## LOAD CASE DEFINITIONS:

D	DeadLoad	RAMUSER
Sp	PosSnowLoad	RAMUSER
W1	Wind	Wind_ASCE710_1_X
W2	Wind	Wind_ASCE710_1_Y
W3	Wind	Wind_ASCE710_2_X+E
W4	Wind	Wind_ASCE710_2_X-E
W5	Wind	Wind_ASCE710_2_Y+E
W6	Wind	Wind_ASCE710_2_Y-E
W7	Wind	Wind_ASCE710_3_X+Y
W8	Wind	Wind_ASCE710_3_X-Y
W9	Wind	Wind_ASCE710_4_X+Y_CW
W10	Wind	Wind_ASCE710_4_X+Y_CCW
W11	Wind	Wind_ASCE710_4_X-Y_CW
W12	Wind	Wind_ASCE710_4_X-Y_CCW
E1	Seismic	EQ_ASCE710_X_+E_F
E2	Seismic	EQ_ASCE710_X_-E_F
E3	Seismic	EQ_ASCE710_Y_+E_F
E4	Seismic	EQ_ASCE710_Y_-E_F
E5	Seismic	EQ_ASCE710_X_+E_0.3Y_+E_F
E6	Seismic	EQ_ASCE710_X_+E_-0.3Y_+E_F
E7	Seismic	EQ_ASCE710_-X_+E_0.3Y_+E_F
E8	Seismic	EQ_ASCE710_-X_+E_-0.3Y_+E_F
E9	Seismic	EQ_ASCE710_0.3X_+E_Y_+E_F
E10	Seismic	EQ_ASCE710_0.3X_+E_-Y_+E_F
E11	Seismic	EQ_ASCE710_-0.3X_+E_Y_+E_F



RAM Structural System



# Code Check Summary

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 2/10

04/06/20 08:57:09

Steel Code: AISC360-16 LRFD

E12	Seismic	EQ_ASCE710_-0.3X_+E_-Y_+E_F
E13	Seismic	EQ_ASCE710_X_+E_0.3Y_-E_F
E14	Seismic	EQ_ASCE710_X_+E_-0.3Y_-E_F
E15	Seismic	EQ_ASCE710_-X_+E_0.3Y_-E_F
E16	Seismic	EQ_ASCE710_-X_+E_-0.3Y_-E_F
E17	Seismic	EQ_ASCE710_0.3X_+E_Y_-E_F
E18	Seismic	EQ_ASCE710_0.3X_+E_-Y_-E_F
E19	Seismic	EQ_ASCE710_-0.3X_+E_Y_-E_F
E20	Seismic	EQ_ASCE710_-0.3X_+E_-Y_-E_F
E21	Seismic	EQ_ASCE710_X_-E_0.3Y_+E_F
E22	Seismic	EQ_ASCE710_X_-E_-0.3Y_+E_F
E23	Seismic	EQ_ASCE710_-X_-E_0.3Y_+E_F
E24	Seismic	EQ_ASCE710_-X_-E_-0.3Y_+E_F
E25	Seismic	EQ_ASCE710_0.3X_-E_Y_+E_F
E26	Seismic	EQ_ASCE710_0.3X_-E_-Y_+E_F
E27	Seismic	EQ_ASCE710_-0.3X_-E_Y_+E_F
E28	Seismic	EQ_ASCE710_-0.3X_-E_-Y_+E_F
E29	Seismic	EQ_ASCE710_X_-E_0.3Y_-E_F
E30	Seismic	EQ_ASCE710_X_-E_-0.3Y_-E_F
E31	Seismic	EQ_ASCE710_-X_-E_0.3Y_-E_F
E32	Seismic	EQ_ASCE710_-X_-E_-0.3Y_-E_F
E33	Seismic	EQ_ASCE710_0.3X_-E_Y_-E_F
E34	Seismic	EQ_ASCE710_0.3X_-E_-Y_-E_F
E35	Seismic	EQ_ASCE710_-0.3X_-E_Y_-E_F
E36	Seismic	EQ_ASCE710_-0.3X_-E_-Y_-E_F

## LOAD COMBINATIONS: IBC 2015 / ASCE 7-10 LRFD

1	*	1.400 D
2	*	1.200 D + 1.600 Sp
3	*	1.200 D + 1.600 Sp + 0.500 W1
4	*	1.200 D + 1.600 Sp + 0.500 W2
5	*	1.200 D + 1.600 Sp + 0.500 W3
6	*	1.200 D + 1.600 Sp + 0.500 W4
7	*	1.200 D + 1.600 Sp + 0.500 W5
8	*	1.200 D + 1.600 Sp + 0.500 W6
9	*	1.200 D + 1.600 Sp + 0.500 W7
10	*	1.200 D + 1.600 Sp + 0.500 W8
11	*	1.200 D + 1.600 Sp + 0.500 W9
12	*	1.200 D + 1.600 Sp + 0.500 W10
13	*	1.200 D + 1.600 Sp + 0.500 W11
14	*	1.200 D + 1.600 Sp + 0.500 W12
15	*	1.200 D + 1.600 Sp - 0.500 W1
16	*	1.200 D + 1.600 Sp - 0.500 W2
17	*	1.200 D + 1.600 Sp - 0.500 W3
18	*	1.200 D + 1.600 Sp - 0.500 W4
19	*	1.200 D + 1.600 Sp - 0.500 W5

Strawberry Park - Lateral Analysis



RAM Structural System



## Code Check Summary

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 3/10

04/06/20 08:57:09

Steel Code: AISC360-16 LRFD

---

20	*	1.200 D + 1.600 Sp - 0.500 W6
21	*	1.200 D + 1.600 Sp - 0.500 W7
22	*	1.200 D + 1.600 Sp - 0.500 W8
23	*	1.200 D + 1.600 Sp - 0.500 W9
24	*	1.200 D + 1.600 Sp - 0.500 W10
25	*	1.200 D + 1.600 Sp - 0.500 W11
26	*	1.200 D + 1.600 Sp - 0.500 W12
27	*	1.200 D + 0.500 Sp + 1.000 W1
28	*	1.200 D + 0.500 Sp + 1.000 W2
29	*	1.200 D + 0.500 Sp + 1.000 W3
30	*	1.200 D + 0.500 Sp + 1.000 W4
31	*	1.200 D + 0.500 Sp + 1.000 W5
32	*	1.200 D + 0.500 Sp + 1.000 W6
33	*	1.200 D + 0.500 Sp + 1.000 W7
34	*	1.200 D + 0.500 Sp + 1.000 W8
35	*	1.200 D + 0.500 Sp + 1.000 W9
36	*	1.200 D + 0.500 Sp + 1.000 W10
37	*	1.200 D + 0.500 Sp + 1.000 W11
38	*	1.200 D + 0.500 Sp + 1.000 W12
39	*	1.200 D + 0.500 Sp - 1.000 W1
40	*	1.200 D + 0.500 Sp - 1.000 W2
41	*	1.200 D + 0.500 Sp - 1.000 W3
42	*	1.200 D + 0.500 Sp - 1.000 W4
43	*	1.200 D + 0.500 Sp - 1.000 W5
44	*	1.200 D + 0.500 Sp - 1.000 W6
45	*	1.200 D + 0.500 Sp - 1.000 W7
46	*	1.200 D + 0.500 Sp - 1.000 W8
47	*	1.200 D + 0.500 Sp - 1.000 W9
48	*	1.200 D + 0.500 Sp - 1.000 W10
49	*	1.200 D + 0.500 Sp - 1.000 W11
50	*	1.200 D + 0.500 Sp - 1.000 W12
51	*	1.200 D + 1.000 W1
52	*	1.200 D + 1.000 W2
53	*	1.200 D + 1.000 W3
54	*	1.200 D + 1.000 W4
55	*	1.200 D + 1.000 W5
56	*	1.200 D + 1.000 W6
57	*	1.200 D + 1.000 W7
58	*	1.200 D + 1.000 W8
59	*	1.200 D + 1.000 W9
60	*	1.200 D + 1.000 W10
61	*	1.200 D + 1.000 W11
62	*	1.200 D + 1.000 W12
63	*	1.200 D - 1.000 W1
64	*	1.200 D - 1.000 W2
65	*	1.200 D - 1.000 W3



RAM Structural System



# Code Check Summary

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 4/10

04/06/20 08:57:09

Steel Code: AISC360-16 LRFD

---

66	*	1.200 D - 1.000 W4
67	*	1.200 D - 1.000 W5
68	*	1.200 D - 1.000 W6
69	*	1.200 D - 1.000 W7
70	*	1.200 D - 1.000 W8
71	*	1.200 D - 1.000 W9
72	*	1.200 D - 1.000 W10
73	*	1.200 D - 1.000 W11
74	*	1.200 D - 1.000 W12
75	*	0.900 D + 1.000 W1
76	*	0.900 D + 1.000 W2
77	*	0.900 D + 1.000 W3
78	*	0.900 D + 1.000 W4
79	*	0.900 D + 1.000 W5
80	*	0.900 D + 1.000 W6
81	*	0.900 D + 1.000 W7
82	*	0.900 D + 1.000 W8
83	*	0.900 D + 1.000 W9
84	*	0.900 D + 1.000 W10
85	*	0.900 D + 1.000 W11
86	*	0.900 D + 1.000 W12
87	*	0.900 D - 1.000 W1
88	*	0.900 D - 1.000 W2
89	*	0.900 D - 1.000 W3
90	*	0.900 D - 1.000 W4
91	*	0.900 D - 1.000 W5
92	*	0.900 D - 1.000 W6
93	*	0.900 D - 1.000 W7
94	*	0.900 D - 1.000 W8
95	*	0.900 D - 1.000 W9
96	*	0.900 D - 1.000 W10
97	*	0.900 D - 1.000 W11
98	*	0.900 D - 1.000 W12
99	*	1.257 D + 0.700 Sp + 1.000 E1
100	*	1.257 D + 0.700 Sp + 1.000 E2
101	*	1.257 D + 0.700 Sp + 1.000 E3
102	*	1.257 D + 0.700 Sp + 1.000 E4
103	*	1.257 D + 0.700 Sp + 1.000 E5
104	*	1.257 D + 0.700 Sp + 1.000 E6
105	*	1.257 D + 0.700 Sp + 1.000 E7
106	*	1.257 D + 0.700 Sp + 1.000 E8
107	*	1.257 D + 0.700 Sp + 1.000 E9
108	*	1.257 D + 0.700 Sp + 1.000 E10
109	*	1.257 D + 0.700 Sp + 1.000 E11
110	*	1.257 D + 0.700 Sp + 1.000 E12
111	*	1.257 D + 0.700 Sp + 1.000 E13



RAM Structural System



## Code Check Summary

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 5/10

04/06/20 08:57:09

Steel Code: AISC360-16 LRFD

---

112	*	1.257 D + 0.700 Sp + 1.000 E14
113	*	1.257 D + 0.700 Sp + 1.000 E15
114	*	1.257 D + 0.700 Sp + 1.000 E16
115	*	1.257 D + 0.700 Sp + 1.000 E17
116	*	1.257 D + 0.700 Sp + 1.000 E18
117	*	1.257 D + 0.700 Sp + 1.000 E19
118	*	1.257 D + 0.700 Sp + 1.000 E20
119	*	1.257 D + 0.700 Sp + 1.000 E21
120	*	1.257 D + 0.700 Sp + 1.000 E22
121	*	1.257 D + 0.700 Sp + 1.000 E23
122	*	1.257 D + 0.700 Sp + 1.000 E24
123	*	1.257 D + 0.700 Sp + 1.000 E25
124	*	1.257 D + 0.700 Sp + 1.000 E26
125	*	1.257 D + 0.700 Sp + 1.000 E27
126	*	1.257 D + 0.700 Sp + 1.000 E28
127	*	1.257 D + 0.700 Sp + 1.000 E29
128	*	1.257 D + 0.700 Sp + 1.000 E30
129	*	1.257 D + 0.700 Sp + 1.000 E31
130	*	1.257 D + 0.700 Sp + 1.000 E32
131	*	1.257 D + 0.700 Sp + 1.000 E33
132	*	1.257 D + 0.700 Sp + 1.000 E34
133	*	1.257 D + 0.700 Sp + 1.000 E35
134	*	1.257 D + 0.700 Sp + 1.000 E36
135	*	1.257 D + 0.700 Sp - 1.000 E1
136	*	1.257 D + 0.700 Sp - 1.000 E2
137	*	1.257 D + 0.700 Sp - 1.000 E3
138	*	1.257 D + 0.700 Sp - 1.000 E4
139	*	1.257 D + 0.700 Sp - 1.000 E5
140	*	1.257 D + 0.700 Sp - 1.000 E6
141	*	1.257 D + 0.700 Sp - 1.000 E7
142	*	1.257 D + 0.700 Sp - 1.000 E8
143	*	1.257 D + 0.700 Sp - 1.000 E9
144	*	1.257 D + 0.700 Sp - 1.000 E10
145	*	1.257 D + 0.700 Sp - 1.000 E11
146	*	1.257 D + 0.700 Sp - 1.000 E12
147	*	1.257 D + 0.700 Sp - 1.000 E13
148	*	1.257 D + 0.700 Sp - 1.000 E14
149	*	1.257 D + 0.700 Sp - 1.000 E15
150	*	1.257 D + 0.700 Sp - 1.000 E16
151	*	1.257 D + 0.700 Sp - 1.000 E17
152	*	1.257 D + 0.700 Sp - 1.000 E18
153	*	1.257 D + 0.700 Sp - 1.000 E19
154	*	1.257 D + 0.700 Sp - 1.000 E20
155	*	1.257 D + 0.700 Sp - 1.000 E21
156	*	1.257 D + 0.700 Sp - 1.000 E22
157	*	1.257 D + 0.700 Sp - 1.000 E23



RAM Structural System



## Code Check Summary

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 6/10

04/06/20 08:57:09

Steel Code: AISC360-16 LRFD

---

158	*	1.257 D + 0.700 Sp - 1.000 E24
159	*	1.257 D + 0.700 Sp - 1.000 E25
160	*	1.257 D + 0.700 Sp - 1.000 E26
161	*	1.257 D + 0.700 Sp - 1.000 E27
162	*	1.257 D + 0.700 Sp - 1.000 E28
163	*	1.257 D + 0.700 Sp - 1.000 E29
164	*	1.257 D + 0.700 Sp - 1.000 E30
165	*	1.257 D + 0.700 Sp - 1.000 E31
166	*	1.257 D + 0.700 Sp - 1.000 E32
167	*	1.257 D + 0.700 Sp - 1.000 E33
168	*	1.257 D + 0.700 Sp - 1.000 E34
169	*	1.257 D + 0.700 Sp - 1.000 E35
170	*	1.257 D + 0.700 Sp - 1.000 E36
171	*	1.257 D + 1.000 E1
172	*	1.257 D + 1.000 E2
173	*	1.257 D + 1.000 E3
174	*	1.257 D + 1.000 E4
175	*	1.257 D + 1.000 E5
176	*	1.257 D + 1.000 E6
177	*	1.257 D + 1.000 E7
178	*	1.257 D + 1.000 E8
179	*	1.257 D + 1.000 E9
180	*	1.257 D + 1.000 E10
181	*	1.257 D + 1.000 E11
182	*	1.257 D + 1.000 E12
183	*	1.257 D + 1.000 E13
184	*	1.257 D + 1.000 E14
185	*	1.257 D + 1.000 E15
186	*	1.257 D + 1.000 E16
187	*	1.257 D + 1.000 E17
188	*	1.257 D + 1.000 E18
189	*	1.257 D + 1.000 E19
190	*	1.257 D + 1.000 E20
191	*	1.257 D + 1.000 E21
192	*	1.257 D + 1.000 E22
193	*	1.257 D + 1.000 E23
194	*	1.257 D + 1.000 E24
195	*	1.257 D + 1.000 E25
196	*	1.257 D + 1.000 E26
197	*	1.257 D + 1.000 E27
198	*	1.257 D + 1.000 E28
199	*	1.257 D + 1.000 E29
200	*	1.257 D + 1.000 E30
201	*	1.257 D + 1.000 E31
202	*	1.257 D + 1.000 E32
203	*	1.257 D + 1.000 E33





RAM Structural System



## Code Check Summary

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 7/10

04/06/20 08:57:09

Steel Code: AISC360-16 LRFD

---

204	*	1.257 D + 1.000 E34
205	*	1.257 D + 1.000 E35
206	*	1.257 D + 1.000 E36
207	*	1.257 D - 1.000 E1
208	*	1.257 D - 1.000 E2
209	*	1.257 D - 1.000 E3
210	*	1.257 D - 1.000 E4
211	*	1.257 D - 1.000 E5
212	*	1.257 D - 1.000 E6
213	*	1.257 D - 1.000 E7
214	*	1.257 D - 1.000 E8
215	*	1.257 D - 1.000 E9
216	*	1.257 D - 1.000 E10
217	*	1.257 D - 1.000 E11
218	*	1.257 D - 1.000 E12
219	*	1.257 D - 1.000 E13
220	*	1.257 D - 1.000 E14
221	*	1.257 D - 1.000 E15
222	*	1.257 D - 1.000 E16
223	*	1.257 D - 1.000 E17
224	*	1.257 D - 1.000 E18
225	*	1.257 D - 1.000 E19
226	*	1.257 D - 1.000 E20
227	*	1.257 D - 1.000 E21
228	*	1.257 D - 1.000 E22
229	*	1.257 D - 1.000 E23
230	*	1.257 D - 1.000 E24
231	*	1.257 D - 1.000 E25
232	*	1.257 D - 1.000 E26
233	*	1.257 D - 1.000 E27
234	*	1.257 D - 1.000 E28
235	*	1.257 D - 1.000 E29
236	*	1.257 D - 1.000 E30
237	*	1.257 D - 1.000 E31
238	*	1.257 D - 1.000 E32
239	*	1.257 D - 1.000 E33
240	*	1.257 D - 1.000 E34
241	*	1.257 D - 1.000 E35
242	*	1.257 D - 1.000 E36
243	*	0.843 D + 1.000 E1
244	*	0.843 D + 1.000 E2
245	*	0.843 D + 1.000 E3
246	*	0.843 D + 1.000 E4
247	*	0.843 D + 1.000 E5
248	*	0.843 D + 1.000 E6
249	*	0.843 D + 1.000 E7



RAM Structural System



## Code Check Summary

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 8/10

04/06/20 08:57:09

Steel Code: AISC360-16 LRFD

---

250	*	0.843 D + 1.000 E8
251	*	0.843 D + 1.000 E9
252	*	0.843 D + 1.000 E10
253	*	0.843 D + 1.000 E11
254	*	0.843 D + 1.000 E12
255	*	0.843 D + 1.000 E13
256	*	0.843 D + 1.000 E14
257	*	0.843 D + 1.000 E15
258	*	0.843 D + 1.000 E16
259	*	0.843 D + 1.000 E17
260	*	0.843 D + 1.000 E18
261	*	0.843 D + 1.000 E19
262	*	0.843 D + 1.000 E20
263	*	0.843 D + 1.000 E21
264	*	0.843 D + 1.000 E22
265	*	0.843 D + 1.000 E23
266	*	0.843 D + 1.000 E24
267	*	0.843 D + 1.000 E25
268	*	0.843 D + 1.000 E26
269	*	0.843 D + 1.000 E27
270	*	0.843 D + 1.000 E28
271	*	0.843 D + 1.000 E29
272	*	0.843 D + 1.000 E30
273	*	0.843 D + 1.000 E31
274	*	0.843 D + 1.000 E32
275	*	0.843 D + 1.000 E33
276	*	0.843 D + 1.000 E34
277	*	0.843 D + 1.000 E35
278	*	0.843 D + 1.000 E36
279	*	0.843 D - 1.000 E1
280	*	0.843 D - 1.000 E2
281	*	0.843 D - 1.000 E3
282	*	0.843 D - 1.000 E4
283	*	0.843 D - 1.000 E5
284	*	0.843 D - 1.000 E6
285	*	0.843 D - 1.000 E7
286	*	0.843 D - 1.000 E8
287	*	0.843 D - 1.000 E9
288	*	0.843 D - 1.000 E10
289	*	0.843 D - 1.000 E11
290	*	0.843 D - 1.000 E12
291	*	0.843 D - 1.000 E13
292	*	0.843 D - 1.000 E14
293	*	0.843 D - 1.000 E15
294	*	0.843 D - 1.000 E16
295	*	0.843 D - 1.000 E17



RAM Structural System



# Code Check Summary

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 9/10

04/06/20 08:57:09

Steel Code: AISC360-16 LRFD

296	*	0.843 D - 1.000 E18
297	*	0.843 D - 1.000 E19
298	*	0.843 D - 1.000 E20
299	*	0.843 D - 1.000 E21
300	*	0.843 D - 1.000 E22
301	*	0.843 D - 1.000 E23
302	*	0.843 D - 1.000 E24
303	*	0.843 D - 1.000 E25
304	*	0.843 D - 1.000 E26
305	*	0.843 D - 1.000 E27
306	*	0.843 D - 1.000 E28
307	*	0.843 D - 1.000 E29
308	*	0.843 D - 1.000 E30
309	*	0.843 D - 1.000 E31
310	*	0.843 D - 1.000 E32
311	*	0.843 D - 1.000 E33
312	*	0.843 D - 1.000 E34
313	*	0.843 D - 1.000 E35
314	*	0.843 D - 1.000 E36

\* = Load combination currently selected to use

## Frame #1:

### Level: Roof

Col. #	Pu kip	Mux kip-ft	Muy kip-ft	Vux kip	Vuy kip	LC	Interact.	Fy ksi	Size
9	13.56	0.00	0.00	-0.10	0.01	25	0.16 Axial	50	HSS4X4X5/16
16	25.95	-0.31	0.00	0.04	-0.00	13	0.32 H1-1a	46	HSS4X4X5/16

Beam #	Pu kip	Mux kip-ft	Muy kip-ft	Vux kip	Vuy kip	LC	Interact.	Fy ksi	Size
44	0.00	11.43	0.00	3.71	-0.00	2	0.12 H1-1b	50	W10X22

Brace #	Pu kip	Mux kip-ft	Muy kip-ft	Vux kip	Vuy kip	LC	Interact.	Fy ksi	Size
2	9.24	0.00	0.00	-0.00	0.00	37	0.12 Axial	46	HSS4X4X3/8

## Frame #2:

### Level: Roof

Col. #	Pu kip	Mux kip-ft	Muy kip-ft	Vux kip	Vuy kip	LC	Interact.	Fy ksi	Size
10	26.77	0.66	0.13	0.10	0.01	31	0.34 H1-1a	50	HSS4X4X5/16
15	6.20	0.00	0.00	0.08	0.01	19	0.07 Axial	50	HSS4X4X5/16



RAM Structural System



## Code Check Summary

RAM Frame 17.00.01.09

DataBase: Strawberry Park - East Addition

Building Code: IBC

Page 10/10

04/06/20 08:57:09

Steel Code: AISC360-16 LRFD

Beam #	Pu kip	Mux kip-ft	Muy kip-ft	Vux kip	Vuy kip	LC	Interact.	Fy ksi	Size
15	0.00	2.06	0.00	-1.47	-0.00	7	0.02 H1-1b	50	W10X22

Brace #	Pu kip	Mux kip-ft	Muy kip-ft	Vux kip	Vuy kip	LC	Interact.	Fy ksi	Size
3	21.29	0.00	0.00	-0.00	-0.00	91	0.26 Axial	46	HSS4X4X3/8



# Continuous Foundation Design Envelope

RAM Foundation v17.00.01.09

DataBase: Strawberry Park - East Addition

Bentley Building Code: IBC

Date: 04/06/20 09:21:32  
Design Code: ACI318-14

Footing Mark: 15

## LONGITUDINAL DIRECTION

Location ft	Positive Flexure			Negative Flexure			Critical Section Shear		
	Mu kip-ft	Phi Mn kip-ft	As Req. in <sup>2</sup>	Mu kip-ft	Phi Mn kip-ft	As Req. in <sup>2</sup>	Vu kip	Phi Vn kip	As Req. in <sup>2</sup> /ft
0.000	0.00	215.05	1.55	-0.00	-225.85	1.55	1.93	70.23	0.00
0.367	0.59	215.05	1.55	-0.13	-225.85	1.55	4.34	70.23	0.00
<b>1.208</b>	3.67	215.05	1.55	-1.36	-225.85	1.55	5.51	70.23	0.00
<b>1.500</b>	5.21	215.05	1.55	-2.16	-225.85	1.55	9.14	70.23	0.00
<b>1.792</b>	4.03	215.05	1.55	-3.97	-225.85	1.55	9.68	70.23	0.00
2.633	2.97	215.05	1.55	-10.19	-225.85	1.55	8.80	70.23	0.00
3.000	2.93	215.05	1.55	-12.65	-225.85	1.55	7.04	70.23	0.00
3.505	3.24	215.05	1.55	-15.70	-225.85	1.55	6.50	70.23	0.00
6.495	11.93	215.05	1.55	-23.04	-225.85	1.55	8.00	70.23	0.00
7.000	12.77	215.05	1.55	-19.73	-225.85	1.55	9.77	70.23	0.00
7.367	13.22	215.05	1.55	-16.42	-225.85	1.55	13.49	70.23	0.00
<b>8.208</b>	13.57	215.05	1.55	-10.79	-225.85	1.55	16.93	70.23	0.00
<b>8.500</b>	13.84	215.05	1.55	-9.22	-225.85	1.55	16.39	70.23	0.00
<b>8.792</b>	8.68	215.05	1.55	-1.32	-225.85	1.55	13.33	70.23	0.00
9.633	1.33	215.05	1.55	-0.13	-225.85	1.55	9.53	70.23	0.00
10.000	0.00	215.05	1.55	-0.00	-225.85	1.55	3.95	70.23	0.00

Note: Locations in bold font are under a column

## TRANSVERSE DIRECTION

Location ft	Top Flexure			Bottom Flexure			Punching Shear	
	Mu kip-ft	Phi Mn kip-ft	As Req. in <sup>2</sup>	Mu kip-ft	Phi Mn kip-ft	As Req. in <sup>2</sup>	Vu kip	Phi Vn kip
0.00	1.65	153.33	2.84	4.48	145.68	2.84		
3.00	1.65	153.33	2.84	4.48	145.68	2.84	13.93	416.55
3.00	2.79	195.90	3.28	8.21	186.20	3.28		
7.00	2.79	195.90	3.28	8.21	186.20	3.28		



## Continuous Foundation Design Envelope

RAM Foundation v17.00.01.09  
DataBase: Strawberry Park - East Addition  
Building Code: IBC

Page 2/4  
Date: 04/06/20 09:21:32  
Design Code: ACI318-14

Location	Mu	Phi Mn	As Req.	Mu	Phi Mn	As Req.	Vu	Phi Vn
7.00	1.24	153.33	2.84	7.55	145.68	2.84		
10.00	1.24	153.33	2.84	7.55	145.68	2.84	35.01	416.55

Soil Stress Under Foundation								
Location	Stress	Ld Co #	Location	Stress	Ld Co #	Location	Stress	Ld Co #
ft	ksf		ft	ksf		ft	ksf	
0.00	1.19	658	0.37	1.15	658	1.21	1.07	658
<b>1.50</b>	1.08	682	<b>1.79</b>	1.09	682	2.63	1.11	682
3.00	1.12	682	3.51	1.13	682	6.49	1.55	633
7.00	1.63	633	7.37	1.71	670	<b>8.21</b>	1.90	670
<b>8.50</b>	1.97	670	<b>8.79</b>	2.04	670	9.63	2.24	670
10.00	2.32	670						

Note: Locations in bold font are under a column



# Continuous Foundation Design Envelope

Footing Mark: 16

## LONGITUDINAL DIRECTION

Location ft	Positive Flexure			Negative Flexure			Critical Section Shear		
	Mu kip-ft	Phi Mn kip-ft	As Req. in <sup>2</sup>	Mu kip-ft	Phi Mn kip-ft	As Req. in <sup>2</sup>	Vu kip	Phi Vn kip	As Req. in <sup>2</sup> /ft
0.000	0.00	323.52	2.58	-0.00	-339.72	2.58	11.23	117.04	0.00
0.995	10.03	323.52	2.58	-1.53	-339.72	2.58	13.34	117.04	0.00
1.000	10.09	323.52	2.58	-1.55	-339.72	2.58	17.18	117.04	0.00
1.870	24.16	323.52	2.58	-5.41	-339.72	2.58	20.85	117.04	0.00
<b>2.708</b>	40.82	323.52	2.58	-11.35	-339.72	2.58	21.48	117.04	0.00
<b>3.000</b>	46.99	323.52	2.58	-13.93	-339.72	2.58	20.80	117.04	0.00
<b>3.292</b>	30.63	323.52	2.58	-4.58	-339.72	2.58	10.83	117.04	0.00
4.130	38.90	323.52	2.58	-7.54	-339.72	2.58	8.89	117.04	0.00
5.000	45.75	323.52	2.58	-9.19	-339.72	2.58	6.87	117.04	0.00
5.005	45.79	323.52	2.58	-9.20	-339.72	2.58	6.85	117.04	0.00
6.995	54.83	323.52	2.58	-9.89	-339.72	2.58	5.30	117.04	0.00
7.000	54.84	323.52	2.58	-9.89	-339.72	2.58	6.08	117.04	0.00
7.870	55.89	323.52	2.58	-10.55	-339.72	2.58	8.22	117.04	0.00
<b>8.708</b>	55.25	323.52	2.58	-12.25	-339.72	2.58	9.28	117.04	0.00
<b>9.000</b>	55.73	323.52	2.58	-13.93	-339.72	2.58	23.31	117.04	0.00
<b>9.292</b>	48.83	323.52	2.58	-11.35	-339.72	2.58	23.99	117.04	0.00
10.130	29.45	323.52	2.58	-5.41	-339.72	2.58	24.08	117.04	0.00
11.000	12.47	323.52	2.58	-1.55	-339.72	2.58	20.53	117.04	0.00
11.005	12.39	323.52	2.58	-1.53	-339.72	2.58	16.23	117.04	0.00
12.000	0.00	323.52	2.58	-0.00	-339.72	2.58	13.61	117.04	0.00

Note: Locations in bold font are under a column

## TRANSVERSE DIRECTION

Location ft	Top Flexure			Bottom Flexure			Punching Shear		
	Mu kip-ft	Phi Mn kip-ft	As Req. in <sup>2</sup>	Mu kip-ft	Phi Mn kip-ft	As Req. in <sup>2</sup>	Vu kip	Phi Vn kip	
0.00	1.94	69.57	0.80	9.79	66.06	0.80			
1.00	1.94	69.57	0.80	9.79	66.06	0.80			



# Continuous Foundation Design Envelope

Page 4/4  
Date: 04/06/20 09:21:32  
Design Code: ACI318-14

RAM Foundation v17.00.01.09  
DataBase: Strawberry Park - East Addition  
Building Code: IBC

Location	Mu	Phi Mn	As Req.	Mu	Phi Mn	As Req.	Vu	Phi Vn
1.00	6.74	226.72	3.44	12.99	215.34	3.44		
5.00	6.74	226.72	3.44	12.99	215.34	3.44	30.78	414.30
5.00	2.90	139.14	1.59	5.64	132.12	1.59		
7.00	2.90	139.14	1.59	5.64	132.12	1.59		
7.00	6.74	226.72	3.44	14.19	215.34	3.44		
11.00	6.74	226.72	3.44	14.19	215.34	3.44	27.23	414.30
11.00	1.94	69.57	0.80	3.10	66.06	0.80		
12.00	1.94	69.57	0.80	3.10	66.06	0.80		

## Soil Stress Under Foundation

Location	Stress	Ld Co #	Location	Stress	Ld Co #	Location	Stress	Ld Co #
ft	ksf		ft	ksf		ft	ksf	
0.00	1.19	772	0.99	1.03	652	1.00	1.03	652
1.87	0.94	652	<b>2.71</b>	0.86	652	<b>3.00</b>	0.83	652
<b>3.29</b>	0.81	676	4.13	0.76	676	5.00	0.71	676
5.01	0.71	676	6.99	0.76	664	7.00	0.76	664
7.87	0.84	664	<b>8.71</b>	0.92	664	<b>9.00</b>	0.95	664
<b>9.29</b>	0.97	664	10.13	1.05	664	11.00	1.13	664
11.01	1.13	664	12.00	1.37	760			

Note: Locations in bold font are under a column



EXISTING LATERAL EVALUATION

EXISTING WALLS

- GRID D  
LENGTH = 52', TRIB = 112' (WIND); 17' (GRAVITY)  
PER E/S-5 & K/S-1 : 10" BLOCK, #5@8" OC  
BOND BEAM @ 11" W/4-#4  
↳ 10" WIDE
- GRID H  
LENGTH = 52', TRIB = 38'-7" (WIND); 17' (GRAVITY)  
PER J/S-5 & K/S-1 : 8" BLOCK SOLID GROUTED W/  
#5@8" OC. BOND BEAM @  
13" W/2-#4
- GRID K  
LENGTH = 48', TRIB = 43'-7" (WIND); 24' (GRAVITY)  
PER A/S-6 & K/S-1 : 12" BLOCK W/ #5@8" OC  
8" WIDE BOND BEAM @ 12"  
W/ 2-#4, HORIZ. JOINT  
REINF @ 16" OC

WIND = 115 MPH

$$P = qGCP - q(GCp_i)$$

$$q = .00256 (.85)(1)(.98)115^2 = 28 \text{ psf}$$

$$G = .85$$

$$GCp_i = \pm .18$$

$$Cp = +.8 \text{ (WW)}, -.45 \text{ (LW)}$$

$$P = 28 \text{ psf} (.85 \times .8 + .18) + 28 \text{ psf} (.85 \times .45 + .18) \\ = 40 \text{ psf (24 psf ASD)}$$

$$Pp = 2.5P = 60 \text{ psf}$$

$$V_{N-S} = 60\text{psf}(2')(212') + 40\text{psf}(11')(212') \\ = 119\text{K}$$

$$V_{E-W} = 60\text{psf}(2')(263') + 40\text{psf}(11')(263') \\ = 147\text{K}$$

$$E = 84\text{K} \Rightarrow \underline{\text{WIND CONTROLS}}$$

$$V = 60\text{psf}(2') + 40\text{psf}(8') = 440\text{plf}$$

WALL D

$$V = 440\text{plf}(112') = 49.3\text{K}$$

$$M = 49.3\text{K} \times 12' = 592\text{K-ft}$$

WALL H

$$V = 440\text{plf}(39') = 17.2\text{K}$$

$$M = 17.2\text{K}(12') = 206\text{K-ft}$$

WALL K

$$V = 440\text{plf}(64') = 28.2\text{K}$$

$$M = 28.2\text{K}(12') = 338\text{K-ft}$$

EXISTING LRFD  
SHEAR

$$\text{DIAPHRAGM LENGTH} = 51'$$

$$\text{GRID D} = 440\text{plf}(24') = 10560\# / 51' = 207\text{plf} \times 0.6 \\ = 125\text{plf ASD}$$

$$\text{GRID H} = 17.2\text{K} / 51' = 337\text{plf} \times 0.6 = 202\text{plf ASD}$$

$$\text{GRID K} = 440\text{plf}(15') = 6600\# / 51' = 130\text{plf} \times 0.6 \\ = 78\text{plf ASD}$$

EXISTING WALLS W/ DEMO @ H

• GRID D

TRIB = 151' (WIND); 17' (GRAVITY)

$$V = 440 \text{ pif}(151') = 67\text{K}$$

$$M = 67\text{K}(12') = 804\text{K-ft}$$

• GRID K

TRIB = 103' (WIND); 24' (GRAVITY)

$$V = 440 \text{ pif}(103') = 46\text{K}$$

$$M = 46\text{K}(12') = 552\text{K-ft}$$

OPTION #1

ELIMINATE GRID H & USE WALLS @ D, K, NEW AT D.8

GRID D LOAD DECREASES → WALL WORKS

GRID D.8

LOAD = 17.2K

DIAPHRAGM LOADS:

$$440 \text{ pif } (23') = 10120 \# / 51' = 198 \times 0.6 = 119 \text{ pif}$$

GRID K

$$V = 440 \text{ pif } (71.5') = 31.5K$$

DIAPHRAGM LOADS:

$$440 \text{ pif } (22') = 9680 \# / 51' = 190 \times 0.6 = 114 \text{ pif}$$

GRID F.6

15'-4" WALL SOLID GROUTED W/ #5 @ 24" OC

$$V_{dia} = 10120 \# / 15' = 675 \times 0.6 = 405 \text{ pif CONN. TO WALL}$$

GRID K

$$(E) V_{dia} = 78 \text{ pif} / 200 \text{ pif CAPACITY} = 0.39$$

$$(N) V_{dia} = 114 \text{ pif} / 200 \text{ pif CAPACITY} = 0.57$$

>10% INCREASE IN  
DEMAND/CAPACITY  
RATIO → VERIFY  
DIAPHRAGM CONN  
IS ADEQUATE FOR  
NEW CODE

GRID D.8 FOOTING

$$T = 17.2K(0.6) \times 13' / 7.5' = 18K \Rightarrow 15.7K \approx \frac{15.7K}{.6 \times .15 \text{ Kcf}} = 175 \text{ ft}^3$$

$$C = 78 \text{ psf } (13') (7.5' / 2) / 7.5' = 3.8K \times .6 = 2.3K$$

# MASONRY

## DESIGN SYSTEM FOR CONCRETE AND CLAY MASONRY

The National Concrete Masonry Association  
Western States Clay Product Association

Brick Industry Association  
International Code Council

Masonry 7.2  
(Release 7.2.1)

Prjct: Steamboat Schools  
Topic: Grid D.8 Wall  
Page:

Name: Strawberry Park  
Date: 03/19/2020  
Chkd:


### Strength Design of a Reinforced Concrete Masonry Shearwall Using the 2015 IBC Strength Design Code

#### Material and Construction Data

8 in. units, Full grout, running bond  
Wall Weight = 80.35 psf  
Type S Portland cement lime / Mortar cement Mortar, Coarse Grout  
Masonry Density = 115.0 pcf  
 $f'_m = 1,500$  psi (Specified)  
 $E_m = 900(f'_m) = 1,350,000$  psi  
 $F_y = 60,000$  psi  
 $E_s = 29,000,000$  psi

#### Shear Wall Design Details

Thickness = 7.625 in.  
Height = 176.0 in. (14.67 ft)  
Length = 90.00 in. (7.5 ft)  
 $x = 3.813$  in.  
Endzone Length:  $S_o = 16$  in = 1.333 ft (1 #5 Bars in each cell)  
Middlezone Grouted Cell Spacing: Full Grout  
Middlezone Steel Spacing: 24 in OC (1 #5 Bars in each cell with reinforcement)  
This shear wall has an aspect ratio of 1.96 and may be a deep beam following the provisions of ACI 318.  
 $A_o = 686.3$  sq.in.  
 $I_o = 886.6$  in<sup>4</sup>  
 $r_o = 2.201$  in.  
Slenderness Reduction Factor = 0.673



#### Location of Reinforcing Bars

Bar	Ri	RCi	As
1	86	41	0.31
2	78	33	0.31
3	54	9	0.31
4	36	-9	0.31
5	12	-33	0.31
6	4	-41	0.31

The following design calculations are for the specified section forces

#### Section Design Forces Used

$P_u = 9.169$  kips  
 $M_u = 2,642$  kip-in  
 $V_u = 16.94$  kips

# MASONRY

## DESIGN SYSTEM FOR CONCRETE AND CLAY MASONRY

The National Concrete Masonry Association    Brick Industry Association  
Western States Clay Product Association    International Code Council

Masonry 7.2  
(Release 7.2.1)

Prjct: Steamboat Schools  
Topic: Grid D.8 Wall  
Page:

Name: Strawberry Park  
Date: 03/19/2020  
Chkd:

### Wall Flexural Design Data

Maximum  $P_n = 442.7$  kips based on slenderness (TMS 402-13 §9.3.4.1.1)

Maximum  $P_u = 0.9(442.7) = 398.4$  kips based on slenderness (TMS 402-13 §9.3.4.1.1)

Check  $P_u$  for the load condition  $D+0.75L+0.525Q_e$ .

$P_{u \max} = 242.9$  kips for normal reinforced shear walls (TMS 402-13 §9.3.3.5)

$P_u$  for this load condition was not calculated and will need to be checked, if applicable.

$M_n = 4,794$  kip-in (399.5 kip-ft) for Design  $P_u$

$\phi M_n = 0.9(4,794) = 4,314$  kip-in (359.5 kip-ft)

### Wall Shear Design Data

Design as a normal shear wall

$V_n \max = 106.3$  kips (Section 9.3.4.1.2)

$V_{nm} = 62.09$  kips (Section 9.3.4.1.2.1)

$V_{ns} = 0$  kips

$A_v / s = 0$  in.

$\phi V_n$  is the lesser of:

$\phi V_n \max = 0.8(106.3) = 85.05$  kips

$\phi V_n \max = 0.8(62.09 + 0) = 49.67$  kips    CONTROLS

### Development and Splice Lengths for EndZone Longitudinal Reinforcement

$K = 3.5000$  in.

Required Development Length:  $l_d = 22.48$  in.

Required Lap Splice Length:  $= 22.48$  in. (Cannot be reduced TMS 402-13 §9.3.3.4(b))

Some codes may require epoxy-coated reinforcement to have longer development and splice lengths.

### Development and Splice Lengths for MidZone Longitudinal Reinforcement

$K = 3.5000$  in.

Required Development Length:  $l_d = 22.48$  in.

Required Lap Splice Length:  $= 22.48$  in. (Cannot be reduced TMS 402-13 §9.3.3.4(b))

Some codes may require epoxy-coated reinforcement to have longer development and splice lengths.

# Strawberry Park - D.8 Footing

Height of wall	13 ft	Exterior Wall Weight	50 psf	
Weight of wall	75 psf	Exterior ftg	18 in	
TOF	3.5 ft	Exterior ftg thickness	12 in	
Length of wall	7.5 ft	Effective Length	20 ft - 1/2 each side of wall	Volume of Concrete 253.125 ft^3
Footing Toe	4.5 ft	Stem wall thickness	10 in	
Width of footing	5 ft			
Thickness ftg	18 in			

Shear Load 17 kips LRFD

## Positive Wind Load acts against Exterior wall

Load at exterior wall	
Exterior wall	13.00 kips
Stem wall	11.25 kips
Soil	6.60 kips
Ftg	4.50 kips
	35.35 kips
Loads at new wall	
Wall+stem	9.28 kips
Footing	12.38 kips
Soil	20.00 kips

	0.6D+0.6W		0.6D-0.6W		D+0.6W		D-0.6W	
	arm (ft)	moment	arm (ft)	moment	arm (ft)	moment	arm (ft)	moment
	12	-93.6	0.75	5.85	12	156	0.75	9.75
	12	-81	0.75	5.0625	12	135	0.75	8.4375
	12	-47.52	0.75	2.97	12	79.2	0.75	4.95
	12	-32.4	0.75	2.025	12	54	0.75	3.375
		0		0	0	0		0
		0		0	0	0		0
		0		0	0	0		0
	8.25	-45.9422	4.916667	27.37969	8.25	76.57031	4.916667	45.63281
	6	-44.55	7.166667	53.2125	6	74.25	7.166667	88.6875
	6	-72.0166	7.166667	86.01978	6	120.0276	7.166667	143.3663
0.6D		-417.029		182.5195	0	695.0		304.1991
0.6W	13	183.6	13	-183.6	13	183.6		-132.6
SF		2.27		0.99	0	3.79		2.294111


Miscellaneous



**Lightpole base design: nonconstrained at ground surface**

**Lightpole and base geometry**

Total light fixture EPA (effective projected area)	A = 0.27 ft <sup>2</sup>
Lightpole diameter or diagonal width	m = 5.7 in
Lightpole height above base	h <sub>1</sub> = 12.0 ft
Base height above grade	h <sub>2</sub> = 3.5 ft
Diameter of round or diagonal of square footing	b = 2.0 ft



**Soil properties and wind pressure**

Description of soil class of material per UBC Table 18-I-A

5. Clay, sandy clay, silty clay, clayey silt, silt & sandy silt

Lateral soil bearing per UBC Table 18-I-A

$p_{\text{table}} = 100$  psf per ft below grade

Increased allowable bearing by a factor 2 per UBC Table 18-I-A footnote #3

$p_{\text{increased}} = 200$  psf per ft below grade

Components & cladding wind pressure

$w_{\text{wind}} = 20$  psf

**Resultant applied load**

Resultant wind force

$P_{\text{wind}} = 258$  lbs

Resultant height above grade of force

$h = 5.43$  ft

**Determine embedment depth required**

For nonconstrained base (UBC Equation 6-1)

where  
and

$d = 0.5A[1 + (1 + (4.36h/A))^{0.5}]$  but limited to 12'

$A = 2.34P/S_1b$


$S_1$  = allowable lateral soil bearing pressure based on  
1/3 embedment length of base

**Required embedment depth**

$d_{\text{req'd}} = 3.49$  ft

**Bearing pressure based on depth**


$S_1 = 233$  psf

 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project <b>Steamboat Schools</b>				Job Ref. <b>20191103</b>	
	Section <b>Strawberry Park Lintel</b>				Sheet no./rev. <b>1</b>	
	Calc. by <b>VSW</b>	Date <b>3/19/2020</b>	Chk'd by	Date	App'd by	Date

## STEEL BEAM ANALYSIS & DESIGN (AISC360-10)

In accordance with AISC360-10 using the LRFD method

Tedds calculation version 3.0.14



### Support conditions

Support A

Vertically restrained

Rotationally free

Support B

Vertically restrained

Rotationally free

### Applied loading

Beam loads

Dead self weight of beam  $\times 1$

DL - Dead full UDL 0.24 kips/ft

### Load combinations

Load combination 1

Support A


Dead  $\times 1.20$

Live  $\times 1.60$

Roof live  $\times 1.60$

Snow  $\times 1.60$

Dead  $\times 1.20$

 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project <b>Steamboat Schools</b>				Job Ref. <b>20191103</b>	
	Section <b>Strawberry Park Lintel</b>				Sheet no./rev. <b>2</b>	
	Calc. by <b>VSW</b>	Date <b>3/19/2020</b>	Chk'd by	Date	App'd by	Date

### Support B


Live  $\times 1.60$   
Roof live  $\times 1.60$   
Snow  $\times 1.60$   
Dead  $\times 1.20$   
Live  $\times 1.60$   
Roof live  $\times 1.60$   
Snow  $\times 1.60$

### Analysis results

Maximum moment	$M_{\max} = 5.5 \text{ kips\_ft}$	$M_{\min} = 0 \text{ kips\_ft}$
Maximum shear	$V_{\max} = 1.8 \text{ kips}$	$V_{\min} = -1.8 \text{ kips}$
Deflection	$\delta_{\max} = 0.1 \text{ in}$	$\delta_{\min} = 0 \text{ in}$
Maximum reaction at support A	$R_{A_{\max}} = 1.8 \text{ kips}$	$R_{A_{\min}} = 1.8 \text{ kips}$
Unfactored dead load reaction at support A	$R_{A_{\text{Dead}}} = 1.5 \text{ kips}$	
Maximum reaction at support B	$R_{B_{\max}} = 1.8 \text{ kips}$	$R_{B_{\min}} = 1.8 \text{ kips}$
Unfactored dead load reaction at support B	$R_{B_{\text{Dead}}} = 1.5 \text{ kips}$	

### Section details

Section type	<b>W 8x15 (AISC 15th Edn (v15.0))</b>
ASTM steel designation	<b>A992</b>
Steel yield stress	$F_y = 50 \text{ ksi}$
Steel tensile stress	$F_u = 65 \text{ ksi}$
Modulus of elasticity	$E = 29000 \text{ ksi}$




### Resistance factors

Resistance factor for tensile yielding	$\phi_{ty} = 0.90$
Resistance factor for tensile rupture	$\phi_{tr} = 0.75$
Resistance factor for compression	$\phi_c = 0.90$
Resistance factor for flexure	$\phi_b = 0.90$

### Lateral bracing

Span 1 has lateral bracing at supports only

 <b>Jirsa Hedrick Structural Engineers</b> 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project <b>Steamboat Schools</b>				Job Ref. <b>20191103</b>	
	Section <b>Strawberry Park Lintel</b>				Sheet no./rev. <b>3</b>	
	Calc. by <b>VSW</b>	Date <b>3/19/2020</b>	Chk'd by	Date	App'd by	Date

#### Classification of sections for local buckling - Section B4.1

##### Classification of flanges in flexure - Table B4.1b (case 10)

Width to thickness ratio	$b_f / (2 \times t_f) = \mathbf{6.38}$	
Limiting ratio for compact section	$\lambda_{pff} = 0.38 \times \sqrt{E / F_y} = \mathbf{9.15}$	
Limiting ratio for non-compact section	$\lambda_{rff} = 1.0 \times \sqrt{E / F_y} = \mathbf{24.08}$	Compact

##### Classification of web in flexure - Table B4.1b (case 15)

Width to thickness ratio	$(d - 2 \times k) / t_w = \mathbf{28.08}$	
Limiting ratio for compact section	$\lambda_{pwf} = 3.76 \times \sqrt{E / F_y} = \mathbf{90.55}$	
Limiting ratio for non-compact section	$\lambda_{rwf} = 5.70 \times \sqrt{E / F_y} = \mathbf{137.27}$	Compact

**Section is compact in flexure**

#### Design of members for shear - Chapter G

Required shear strength	$V_r = \max(\text{abs}(V_{\max}), \text{abs}(V_{\min})) = \mathbf{1.837}$ kips
Web area	$A_w = d \times t_w = \mathbf{1.987}$ in <sup>2</sup>
Web plate buckling coefficient	$k_v = \mathbf{5}$
Web shear coefficient - eq G2-3	$C_v = \mathbf{1}$
Nominal shear strength – eq G2-1	$V_n = 0.6 \times F_y \times A_w \times C_v = \mathbf{59.609}$ kips
Resistance factor for shear	$\phi_v = \mathbf{1.00}$
Design shear strength	$V_c = \phi_v \times V_n = \mathbf{59.609}$ kips

**PASS - Design shear strength exceeds required shear strength**

#### Design of members for flexure in the major axis - Chapter F

Required flexural strength	$M_r = \max(\text{abs}(M_{s1\_max}), \text{abs}(M_{s1\_min})) = \mathbf{5.51}$ kips_ft
----------------------------	--

##### Yielding - Section F2.1

Nominal flexural strength for yielding - eq F2-1	$M_{nyld} = M_p = F_y \times Z_x = \mathbf{56.667}$ kips_ft
--	---


##### Lateral-torsional buckling - Section F2.2

Unbraced length	$L_b = L_{s1} = \mathbf{144}$ in
Limiting unbraced length for yielding - eq F2-5	$L_p = 1.76 \times r_y \times \sqrt{E / F_y} = \mathbf{37.13}$ in
Distance between flange centroids	$h_o = d - t_f = \mathbf{7.795}$ in
	$c = \mathbf{1}$
	$r_{ts} = \sqrt{[(I_y \times C_w) / S_x]} = \mathbf{1.061}$ in

Limiting unbraced length for inelastic LTB - eq F2-6

$$L_r = 1.95 \times r_{ts} \times E / (0.7 \times F_y) \times \sqrt{[(J \times c / (S_x \times h_o)) + \sqrt{((J \times c / (S_x \times h_o))^2 + 6.76 \times (0.7 \times F_y / E)^2)}]} = \mathbf{120.799}$$
 in

Cross-section mono-symmetry parameter	$R_m = \mathbf{1.000}$
Moment at quarter point of segment	$M_A = \mathbf{4.133}$ kips_ft
Moment at center-line of segment	$M_B = \mathbf{5.510}$ kips_ft
Moment at three quarter point of segment	$M_C = \mathbf{4.133}$ kips_ft
Maximum moment in segment	$M_{abs} = \mathbf{5.510}$ kips_ft
Lateral torsional buckling modification factor - eq F1-1	$C_b = 12.5 \times M_{abs} / [2.5 \times M_{abs} + 3 \times M_A + 4 \times M_B + 3 \times M_C] = \mathbf{1.136}$
Critical flexural stress - eq F2-4	$F_{cr} = C_b \times \pi^2 \times E / (L_b / r_{ts})^2 \times \sqrt{[1 + 0.078 \times J \times c / (S_x \times h_o) \times (L_b / r_{ts})^2]} = \mathbf{31.299}$ ksi
Nominal flexural strength for lateral torsional buckling - eq F2-2	$M_{nlb} = F_{cr} \times S_x = \mathbf{30.778}$ kips_ft
Nominal flexural strength	$M_n = \min(M_{nyld}, M_{nlb}) = \mathbf{30.778}$ kips_ft

 Jirsa Hedrick Structural Engineers 8490 E Crescent Pkwy Suite 250 Greenwood Village, CO 80111	Project Steamboat Schools				Job Ref. 20191103	
	Section Strawberry Park Lintel				Sheet no./rev. 4	
	Calc. by VSW	Date 3/19/2020	Chk'd by	Date	App'd by	Date

Design flexural strength

$$M_c = \phi_b \times M_n = 27.700 \text{ kips\_ft}$$

**PASS - Design flexural strength exceeds required flexural strength**

#### Design of members for vertical deflection

Consider deflection due to dead, live, roof live and snow loads

Limiting deflection

$$\delta_{lim} = L_{s1} / 600 = 0.24 \text{ in}$$

Maximum deflection span 1

$$\delta = \max(\text{abs}(\delta_{max}), \text{abs}(\delta_{min})) = 0.086 \text{ in}$$

**PASS - Maximum deflection does not exceed deflection limit**