



August 5, 2020

Mr. Ted Allen  
Via e-mail: tallen@co.routt.co.us

Reference: Framing Changes  
61970 County Road 129  
Routt County, CO  
SEAD Job Number 20013  
RCRBD Permit B-20-242

Dear Mr. Allen,

Per the request of the Contractor, I, Jacob E. Mielke, P.E. of Steamboat Engineering And Design, Inc. (SEAD) reviewed and approved the following framing changes to the original SEAD permit drawings dated 03.24.2020:

- Simple span headers were used over the windows on the west side of the home, in lieu of the originally specified continuous (3) 11.875 LVL header on sheet S-2. This is acceptable, provided that the header is strapped to the trimmers and king studs with Simpson LSTA18 straps on each side.
- Rough sawn 3x10 rafters were used in lieu of the specified 2x10 DF #2 rafters on sheet S-2.

Please do not hesitate to call or email me with any questions regarding this letter.

Sincerely,



08/05/2020

Steamboat Engineering And Design, Inc.  
Jacob Mielke, PE, President  
jake@seadinc.com  
Colorado License No. 52418

**RCRBD Record Set  
T.A.**

**08/05/2020**