



Steamboat Springs
Fire Rescue
Fire Prevention Services

P.O. Box 775088
2600 Pine Grove Road, Steamboat Springs, CO 80477
Phone: (970) 871-8216 Fax: (970) 870-8030

Proudly serving the City of Steamboat Springs and the Steamboat Springs Area Fire Protection District

ALARM SYSTEM
PERMIT / INSPECTION FORM

| | | | |
|--------------------------------------|--|--------------------|---|
| Project Name | <u>2020 Addition to Strawberry Park Elem</u> | Permit No. | <u>PJ4222-1 Re-Insp Final Existing Bldg</u> |
| Address | <u>39620 Amethyst DR</u> | Alarm Reset | <u>1831</u> |
| Contractor | <u>Western Security</u> | | |
| Contact | <u>TJ Stanley</u> | Phone No. | <u>(970) 987-4015</u> |
| Date & Time of Inspection | <u>7/28/2021 1:00 PM</u> | | |

Alarm System - Rough Inspection

| | |
|--|--|
| Verify location of devices per original stamped and approved plans | |
| Location of devices comments. | |
| Verify wire support and protection | |
| Wire support and protection comments | |
| Notes: | |
| Inspection | |

Alarm System - Final Inspection

| | |
|---|-----|
| All points list | Yes |
| Comments | |
| Key lock box and keys | Yes |
| Comments | |
| Copy of elevator inspector's approved inspection form | NA |
| Comments | |
| Emergency voice alarm communication system | Yes |
| Comments | |
| Firefighter telephone communication system | NA |
| Comments | |
| Firefighter phone jack at each pull station location | NA |
| Comments | |
| Non-removable FF phone installed in main sprinkler control valve room | Yes |
| Comments | |
| Six spare telephones required at Fire Command Center | NA |
| Comments | |
| Verify Monitoring | Yes |
| Monitoring Sticker | Yes |
| Service Sticker | Yes |
| General alarm | Yes |
| Comments | |
| Sprinkler flow alarm | Yes |



Steamboat Springs
Fire Rescue
Fire Prevention Services

P.O. Box 775088
2600 Pine Grove Road, Steamboat Springs, CO 80477
Phone: (970) 871-8216 Fax: (970) 870-8030

Proudly serving the City of Steamboat Springs and the Steamboat Springs Area Fire Protection District

ALARM SYSTEM
PERMIT / INSPECTION FORM

| | |
|-------------------------------------|----------|
| Comments | |
| Sprinkler tamper supervisory alarm | NA |
| Comments | |
| Sprinkler low air supervisory alarm | NA |
| Comments | |
| System trouble | Yes |
| Comments | |
| Correct address listed | Yes |
| Comments | |
| Fire department reset code | NA |
| Comments | |
| Notes: | Passed. |
| Inspection | Approved |

I hereby confirm that the above items and conditions have been explained to me and I will comply with them.

Applicant Signature:

Inspector Signature:

Mike Middleton, Mike

Approved:

Yes

Date & Time:

7/28/2021 3:00 PM