



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Aug 26, 2021

Inspection Result: PASSED

Permit Number: M-20-783

Issuance Date: Dec 17, 2020

Property Address: 42375 RIVER DRUM TRL, ROUTT, CO 80487;

Contractor: COLORADO PLUMBING & HEATING P.O. BOX 775302 STEAMBOAT SPGS, CO 80477
(970) 846-6478

To construct: Work Description: Radiant Heat System with Boiler and Gas Piping.

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Main level hydronic tubing has been installed and fastened correctly. Pressure test good at 100 psi for 15 minutes. Approved to pour gypcrete.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347