



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Aug 27, 2021

Inspection Result: FAILED

Permit Number: B-19-499

Issuance Date: Jul 01, 2019

Property Address: no match:28300-B COUNTY ROAD 14; 28300 COUNTY ROAD 14, UNIT:B, ROUTT, CO 80467;

Contractor: Timberline COntacting / Bret Shaw PO BOX 719 CLARK, CO 80428 (970) 846-6837

To construct: Work Description: detached garage with unfinished man cave above.

ADDENDUM to finish man cave above Garage and delete airlock entry. 8.20.19. MMF

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All work completed to scope of permit EXCEPT stairs to unit and need to tighten cable rails

Corrections:

- 1 New code compliant stair need to be installed to unit and need to tighten cable rails

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us
(970) 870-5331