



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 02, 2021

Inspection Result:

PARTIAL PASS

Permit Number: PRMH210149

Issuance Date: Sep 01, 2021

Property Address: 25525 COUNTY ROAD 56, ROUTT, CO 80487;

Contractor: Ajak's Costum Carpentry 32865 Rcr22 Steamboat Springs, CO 80487 (970) 846-5814

To construct: bathroom fan vents, dry vents

On this day we have inspected your construction for **Mechanical Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All bath fan vents are installed correctly, need to add nail plates on dryer vent.

Corrections:

- 1 Need nail plates on dryer vent at top and bottom plates.

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347