



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Sep 02, 2021

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRPL210025

**Issuance Date:** Aug 19, 2021

**Property Address:** 25535 COUNTY ROAD56, ROUTT, CO 80487;

**Contractor:** ACTION MECHANICAL INC. P.O. BOX 698 CLARK, CO 80428 (970) 819-1174

**To construct:** complete plbg system

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Need to add nail plates to DWV vent line at bathroom top plates. All other DWV lines installed, supported and protected. Pressure test good at 5 psi for 15 minutes. Water lines installed, supported and protected correctly. Pressure test good at 60 psi for 15 minutes. Partial approved.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347