



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 03, 2021

Inspection Result:

PASSED

Permit Number: P-20-436

Issuance Date: Dec 17, 2020

Property Address: 42375 RIVER DRUM TRL, ROUTT, CO 80487;

Contractor: COLORADO PLUMBING & HEATING P.O. BOX 775302 STEAMBOAT SPGS, CO 80477
(970) 846-6478

To construct: Work Description: Waste, Vents, Water Piping and Fixture Trim.

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All DWV and water lines have been installed, supported and protected correctly. Pressure test good at 5 psi and 60 psi for DWV and water lines for 15 minutes. Rough approved.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347