



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 09, 2021

Inspection Result:

PASSED

Permit Number: B-21-692

Issuance Date: Jul 13, 2021

Property Address: 27225 COUNTY ROAD 14, ROUTT, CO 80467;

Contractor:

To construct: Work Description: SFR w/ attached garage
Total Valuation \$1,200,000.00

Project Cost 876,000.00

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: 4 Exterior pads with piers and 4 interior all sized to Approved Plans. All Rebar installed is sized and spaced correctly. Approved

Corrections:

Sincerely,

Ron Norton
Inspector
rnorton@co.routt.co.us
(970) 870-5331