



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 13, 2021

Inspection Result: PARTIAL PASS

Permit Number: P-21-135

Issuance Date: Feb 10, 2021

Property Address: 198 E LINCOLN AVE, HAYDEN, CO 81639;

Contractor: IQ PLUMBING & HEATING 895 RANNEY ST CRAIG, CO 81625 (970) 629-5125

To construct: Work Description: I will be doing waste, vent and water piping

On this day we have inspected your construction for **Plumbing Rough-in Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All plumbing has been completed per approved plans A & B will need water heater pans installed Also PRV plastic pipe will need support Reinspection required

Corrections:

Sincerely,

Don Marchbanks
Inspector
dmarchbanks@co.routt.co.us
(970) 870-5371