



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Sep 16, 2021

**Inspection Result:**

**PARTIAL PASS**

**Permit Number:** B-21-692

**Issuance Date:** Jul 13, 2021

**Property Address:** 27225 COUNTY ROAD 14, ROUTT, CO 80467;

**Contractor:**

**To construct:** Work Description: SFR w/ attached garage  
Total Valuation \$1,200,000.00

Project Cost 876,000.00

On this day we have inspected your construction for **Insulation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Waterproofing applied to entire foundation with 2.25 Mineral wool insulation installed around entire perimeter. Insulations runs from top of footing to top of wall. Approved

**Corrections:**

Sincerely,

Ron Norton  
Inspector  
rnorton@co.routt.co.us  
(970) 870-5331