

Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 17, 2021 Inspection Result: PASSED

Permit Number: PRAB210091 Issuance Date: Sep 13, 2021

Property Address: 50310 MOON HILL DR, ROUTT, CO 80487;

Contractor: Mr. Gumpox Industries P O Box 773434 Steamboat Springs, Co 80477 (970) 819-

6740

To construct: Detached Garage- Foundation ONLY 9.3.21

See TB-21-934 for fees and approvals

On this day we have inspected your construction for **Footing Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All footer pads have been formed and located to approved plans. All rebar is sized and spaced correctly. Approved to pour.

Corrections:

Sincerely,

Silas Ebbert Inspector sebbert@co.routt.co.us (970) 870-5347