



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Sep 21, 2021

**Inspection Result:**

**PARTIAL PASS**

**Permit Number:** TB-21-922

**Issuance Date:** Aug 25, 2021

**Property Address:** 26355 HIDDEN MESA DR, ROUTT, CO 80467;

**Contractor:** SPITELLIE CONSTRUCTION P.O. BOX 881971 STEAMBOAT SPGS, CO 80488 (970) 846-2327

**To construct:** Work Description: To add a two story great room  
. net cost is \$150,000  
Total valuation \$200,000

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** 16" OC #4 horizontals, #5 2 rows top and bottom all approves email photos of remaining ICF forms then approved to pour, addendum under review for ICF change and rebar

**Corrections:**

Sincerely,

A handwritten signature in black ink that reads 'Todd Carr'.

Todd Carr  
Building Official  
tcarr@co.routt.co.us  
(970) 870-5330