



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Sep 27, 2021

**Inspection Result:** PASSED

**Permit Number:** E-21-445

**Issuance Date:** Jul 09, 2021

**Property Address:** 198 E LINCOLN AVE, HAYDEN, CO 81639;

**Contractor:** CURRENT ELECTRICAL CONT. <NO STREET ADDRESS> (970) 291-9686

**To construct:** Work Description: All electrical

On this day we have inspected your construction for **Electrical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Unit B and C complete. final electrical approved

**Corrections:**

Sincerely,

Tom Cook  
Electrical Plan Reviewer/Inspector  
tcook@co.routt.co.us  
(970) 870-5339