



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 28, 2021

Inspection Result:

PASSED

Permit Number: PRAB210091

Issuance Date: Sep 13, 2021

Property Address: 50310 MOON HILL DR, ROUTT, CO 80487;

Contractor: Mr. Gumpox Industries P O Box 773434 Steamboat Springs, Co 80477 (970) 819-6740

To construct: Detached Garage-
See TB-21-934 for fees and approvals

On this day we have inspected your construction for **Foundation Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Sonotube piers have been formed and located to approved plans with all rebar sized and spaced correctly. Approved to pour.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347