



Proudly Serving Rural Routt County \* City of Steamboat Springs \* Town of Hayden \* Town of Oak Creek \* Town of Yampa \* Routt County School Districts

# INSPECTION REPORT

**Report Issued:** Sep 30, 2021

**Inspection Result:**

**PARTIAL PASS**

**Permit Number:** M-20-180

**Issuance Date:** Mar 05, 2020

**Property Address:** 55950 HANNAHS WAY, ROUTT, CO 80428;

**Contractor:** ACTION MECHANICAL INC. P.O. BOX 698 CLARK, CO 80428 (970) 819-1174  
ACTION MECHANICAL INC. P.O. BOX 698 CLARK, CO 80428 (970) 819-1174

**To construct:** Work Description: in-floor heating system

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

**Comments:** Need to install water hammer arrestor on ice maker supply line under kitchen sink and install sink in powder room when counter tops are installed. Can be approved for TCO.

**Corrections:**

Sincerely,

Silas Ebbert  
Inspector  
sebbert@co.routt.co.us  
(970) 870-5347