



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Sep 30, 2021

Inspection Result:

PARTIAL PASS

Permit Number: B-19-817

Issuance Date: Oct 14, 2019

Property Address: 55950 HANNAHS WAY, ROUTT, CO 80428;

Contractor: FAIR & SQUARE CONSTRUCTION 2673 Jacob Circle, Ste 700 Steamboat Springs, CO 80487 (970) 879-7725

To construct: Work Description: New Single Family Home

Total Project Value

1,500,000.00

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: Need to seal penetrations in mechanical room ceiling, install powder room counter top and install garage doors. All other life safety and final building items are approved. Can be approved for TCO when mechanical room penetrations are sealed.

Corrections:

Sincerely,

Silas Ebbert
Inspector
sebbert@co.routt.co.us
(970) 870-5347

