



Proudly Serving Rural Routt County * City of Steamboat Springs * Town of Hayden * Town of Oak Creek * Town of Yampa * Routt County School Districts

INSPECTION REPORT

Report Issued: Oct 04, 2021

Inspection Result: PASSED

Permit Number: M-20-409

Issuance Date: Jul 31, 2020

Property Address: 55950 HANNAHS WAY, ROUTT, CO 80428;

Contractor: FIN'S TIN PO BOX 697 CLARK, CO 80428 (970) 846-7640

To construct: Work Description: 2 ERV's

Hood

Make up air

Dryer Vent

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Comments: All mechanical for this permit has been completed Mechanical final complete

Corrections:

Sincerely,

Don Marchbanks
Inspector
dmarchbanks@co.routt.co.us
(970) 870-5371